

EDDYSTONE POINT, Australia

WMO: 949830

Lat: 40.9928S

Lon: 148.3467E

Elev: 21

StdP: 101.07

Time Zone: 10.00 (AUS)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	4.4	5.3	-1.2	3.4	7.1	-0.1	3.8	7.6	18.5	11.6	17.0	12.3	5.3	270	0.719

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	6.6	24.1	18.5	22.8	17.8	21.7	17.2	19.9	22.5	19.1	21.3	18.5	20.6	7.1	300

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.0	13.8	20.8	18.2	13.2	20.2	17.6	12.7	19.7	56.9	22.5	54.5	21.4	52.5	20.5	25.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.4	14.4	12.9	DB	2.3	29.8	1.0	2.9	1.6	31.9	1.0	33.6	0.5	35.2	-0.2	37.3	(4)
(5)			WB	0.5	21.3	0.8	1.0	-0.1	22.0	-0.6	22.6	-1.1	23.1	-1.7	23.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	13.9	17.7	18.1	17.1	14.8	12.7	11.1	10.3	10.4	11.5	12.9	14.4	16.0
	DBStd	3.34	2.12	2.14	2.21	2.08	1.91	1.71	1.55	1.66	1.73	1.95	2.12	2.08
	HDD10.0	47	0	0	0	0	2	8	14	15	6	1	1	0
	HDD18.3	1675	37	27	51	106	173	217	248	245	205	170	119	77
	CDD10.0	1472	238	227	220	145	87	41	26	28	51	90	133	186
	CDD18.3	59	17	21	12	1	0	0	0	0	0	1	2	5
	CDH23.3	100	36	30	14	1	0	0	0	0	0	3	4	13
CDH26.7	17	7	6	2	0	0	0	0	0	0	0	1	2	
Wind	WSAvg	6.8	6.9	6.6	6.5	6.5	6.7	6.7	6.6	6.9	7.0	7.1	6.9	7.0
Precipitation	PrecAvg	804	53	42	59	71	73	64	87	77	70	60	66	68
	PrecMax	1084	164	140	152	309	246	132	178	195	146	170	149	175
	PrecMin	331	5	2	6	4	15	24	12	12	16	5	9	2
	PrecStd	156	37	36	37	59	48	30	41	44	33	36	35	46
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	26.6	26.3	24.9	22.1	19.0	16.6	15.5	16.2	18.5	21.5	23.0	24.8
		MCWB	18.8	19.7	19.2	17.2	15.0	13.5	12.0	12.4	13.2	14.7	17.5	17.7
	2%	DB	23.8	23.8	22.8	20.2	17.6	15.6	14.6	15.1	16.8	18.6	20.6	22.1
		MCWB	18.1	18.9	18.3	16.2	14.2	12.9	11.5	11.7	12.5	13.9	16.0	16.7
	5%	DB	22.3	22.5	21.6	19.2	16.7	14.7	13.8	14.2	15.6	17.2	19.1	20.7
		MCWB	17.4	18.1	17.4	15.6	13.8	12.3	11.1	11.1	11.9	13.1	15.0	16.1
	10%	DB	21.2	21.4	20.5	18.1	15.9	14.0	13.2	13.4	14.7	16.2	18.0	19.7
		MCWB	16.8	17.4	16.8	15.0	13.4	11.8	10.7	10.8	11.4	12.6	14.2	15.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	20.5	20.9	20.8	18.3	16.3	15.0	13.1	13.5	14.3	15.8	18.2	19.1
		MCDB	23.4	23.9	23.4	20.2	17.5	15.8	14.3	14.9	16.5	18.8	20.9	22.5
	2%	WB	19.3	20.0	19.5	17.4	15.4	13.7	12.3	12.6	13.5	14.9	16.8	18.1
		MCDB	22.1	22.6	21.6	19.1	16.6	14.7	13.6	14.0	15.4	17.2	19.5	20.8
	5%	WB	18.6	19.2	18.6	16.6	14.7	13.0	11.8	12.0	12.8	14.2	15.9	17.3
		MCDB	21.0	21.3	20.4	18.3	16.1	14.1	13.2	13.5	14.7	16.2	18.2	19.5
	10%	WB	18.0	18.6	17.8	15.8	13.9	12.3	11.2	11.4	12.1	13.4	15.0	16.5
		MCDB	20.0	20.5	19.7	17.6	15.6	13.6	12.8	13.0	14.1	15.6	17.1	18.6
Mean Daily Temperature Range	5% DB	MDBR	7.0	6.6	6.8	6.5	5.9	5.4	5.7	6.2	6.8	7.1	7.0	7.3
		MCDBR	8.9	8.0	7.6	7.3	6.6	5.8	6.1	6.7	7.8	8.3	8.5	8.7
		MCWBR	4.8	4.4	4.5	4.6	4.5	4.1	4.2	4.5	4.9	4.9	4.9	5.1
	5% WB	MCDBR	7.5	6.9	6.5	6.3	5.5	4.7	5.2	5.6	6.6	7.3	7.5	7.8
		MCWBR	4.6	4.3	4.3	4.4	4.2	3.6	3.9	4.1	4.6	4.7	4.7	5.0
Clear-Sky Solar Irradiance	taub	0.352	0.347	0.337	0.321	0.307	0.301	0.298	0.312	0.331	0.338	0.355	0.345	
	taud	2.517	2.549	2.570	2.595	2.601	2.607	2.622	2.580	2.516	2.509	2.479	2.524	
	Ebn at Noon	976	955	921	870	816	788	819	867	912	954	967	988	
	Edh at Noon	110	101	91	76	65	59	62	76	94	104	113	110	
All-Sky Solar Radiation	RadAvg	6.69	5.69	4.54	3.11	2.10	1.66	1.88	2.74	4.02	5.28	6.15	6.93	
	RadStd	0.43	0.30	0.23	0.16	0.11	0.12	0.08	0.18	0.27	0.25	0.39	0.40	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (15 neighbors)	+0.31	N/A	N/A	+0.72	+0.41	N/A	N/A	-78	+93	+14

Nomenclature: See separate page