

NORFOLK ISLAND, Norfolk Island

WMO: 949960

Lat: 29.0389S

Lon: 167.9408E

Elev: 117

StdP: 99.93

Time Zone: 11.00 (PCN)

Period: 97-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	12.4	13.0	4.7	5.4	14.8	5.6	5.7	15.0	12.2	16.0	11.2	16.0	3.0	90	0.467

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	4.1	25.8	22.1	25.1	21.5	24.4	21.0	23.4	24.6	22.8	24.0	22.3	23.7	5.9	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
23.0	18.0	24.0	22.2	17.1	23.5	21.8	16.7	23.3	70.1	24.3	68.0	24.5	65.9	23.5	26.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
11.0	9.9	9.1	11.0	27.0	0.7	0.8	10.6	27.5	10.2	28.0	9.8	28.4	9.3	29.0		
			7.9	24.1	0.6	0.8	7.4	24.7	7.0	25.2	6.7	25.7	6.2	26.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	19.0	21.9	22.5	21.9	20.4	18.8	17.2	16.2	15.9	16.6	17.6	18.8	20.7
	DBStd	2.57	1.16	1.17	1.11	1.17	1.27	1.20	1.21	1.21	1.19	1.21	1.30	1.39
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	281	0	0	0	1	9	38	66	76	52	31	9	1
	CDD10.0	3293	367	349	369	313	272	216	193	183	199	235	264	333
	CDD18.3	534	109	116	111	63	23	4	1	1	1	7	23	75
	CDH23.3	512	133	198	109	18	0	0	0	0	0	0	2	51
	CDH26.7	2	1	1	1	0	0	0	0	0	0	0	0	0
Wind	WSAvg	5.1	5.3	5.6	5.3	5.0	5.1	5.1	5.4	5.1	5.1	5.0	4.8	4.9
Precipitation	PrecAvg	1240	81	96	100	119	115	145	125	109	94	74	83	91
	PrecMax	2009	301	437	350	429	328	401	288	242	335	333	446	473
	PrecMin	784	11	10	12	15	25	22	31	36	15	15	6	7
	PrecStd	341	69	90	66	91	71	76	61	52	61	55	73	90
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	26.2	26.8	26.0	25.0	23.0	21.2	20.2	20.1	21.1	22.1	23.8	25.2
		MCWB	22.1	23.4	22.3	22.0	19.9	18.3	17.5	16.9	17.7	19.0	19.9	21.8
	2%	DB	25.2	25.9	25.1	23.9	22.1	20.3	19.6	19.2	20.1	21.1	22.8	24.6
		MCWB	21.4	22.4	21.5	20.5	19.1	17.7	16.7	16.0	17.0	18.0	19.2	21.2
	5%	DB	24.8	25.1	24.3	23.1	21.4	20.0	19.0	18.8	19.4	20.5	22.0	23.9
		MCWB	21.1	21.8	20.7	19.6	18.4	17.4	15.9	15.6	16.2	17.4	18.7	20.6
	10%	DB	24.1	24.6	23.9	22.3	21.0	19.2	18.2	18.1	19.0	19.9	21.2	23.1
		MCWB	20.5	21.3	20.4	19.1	18.1	16.4	15.1	14.9	15.7	16.8	17.9	19.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	23.6	24.5	23.6	22.9	21.4	20.0	19.0	18.3	18.9	20.1	21.3	23.1
		MCDB	24.7	25.7	24.8	24.1	22.1	20.6	19.8	19.3	20.1	21.2	22.5	24.4
	2%	WB	22.9	23.6	22.8	21.8	20.4	19.0	17.7	17.4	18.0	19.1	20.4	22.4
		MCDB	24.0	24.8	24.1	23.0	21.4	19.9	19.0	18.6	19.3	20.4	21.7	23.8
	5%	WB	22.3	23.1	22.3	20.9	19.6	18.2	16.7	16.6	17.3	18.5	19.6	21.7
		MCDB	23.7	24.2	23.6	22.2	20.9	19.4	18.3	18.0	18.8	19.9	21.2	23.2
	10%	WB	21.7	22.4	21.6	20.2	18.7	17.4	16.0	15.7	16.5	17.6	18.9	21.1
		MCDB	23.3	23.9	23.1	21.8	20.4	19.0	17.7	17.5	18.3	19.3	20.7	22.6
Mean Daily Temperature Range	5% DB	MDBR	4.3	4.1	4.1	4.0	3.8	3.7	3.8	4.2	4.3	4.4	4.7	4.6
		MCDBR	4.8	4.5	4.4	4.4	4.0	4.0	4.1	4.5	4.6	4.7	5.1	4.8
		MCWBR	2.6	2.5	2.7	2.8	3.0	3.2	3.3	3.4	3.4	3.3	3.1	2.7
	5% WB	MCDBR	3.9	3.5	3.8	3.6	3.1	3.2	3.7	3.8	4.3	4.2	4.4	4.0
		MCWBR	2.7	2.6	2.7	2.9	2.9	3.3	3.7	3.7	3.6	3.6	3.1	2.7
Clear-Sky Solar Irradiance	taub	0.358	0.351	0.342	0.330	0.314	0.312	0.306	0.313	0.328	0.334	0.333	0.346	
	taud	2.604	2.640	2.659	2.683	2.702	2.688	2.696	2.659	2.596	2.594	2.623	2.636	
	Ebn at Noon	983	973	951	916	887	866	887	920	950	979	1002	997	
	Edh at Noon	104	97	90	80	71	68	70	80	94	101	101	101	
All-Sky Solar Radiation	RadAvg	7.01	6.41	5.47	4.40	3.35	2.84	3.21	4.10	5.29	6.28	7.10	7.21	
	RadStd	0.54	0.53	0.35	0.21	0.18	0.23	0.17	0.22	0.28	0.39	0.34	0.60	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	+0.29	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page