

TRUSCOTT, Australia

WMO: 951010

Lat: 14.0900S

Lon: 126.3867E

Elev: 53

StdP: 100.70

Time Zone: 8.00 (E08)

Period: 04-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.3	17.4	-2.4	3.1	24.3	-0.3	3.7	23.9	7.4	26.1	7.0	26.5	2.2	140	0.375

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11	7.4	35.1	24.2	34.4	24.4	33.8	24.5	27.4	31.2	27.1	30.9	26.7	30.6	4.7	290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.6	22.3	29.0	26.2	21.7	28.9	25.8	21.2	28.8	87.5	31.2	86.0	31.0	84.5	30.7	28.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.4	6.7	6.2	DB	14.0	37.2	1.8	0.8	12.7	37.7	11.6	38.2	10.6	38.6	9.2	39.2	(4)
(5)			WB	8.0	28.1	1.1	0.3	7.3	28.3	6.6	28.4	6.0	28.6	5.2	28.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	27.6	28.4	28.6	28.6	28.4	26.5	24.6	24.5	25.1	27.2	29.1	30.3	29.9	(6)
(7)		DBStd	2.44	1.43	1.46	1.24	1.35	1.67	2.07	1.76	1.35	1.56	1.11	1.05	1.57	(7)
(8)		HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
(10)		CDD10.0	6421	571	522	576	551	511	439	448	467	517	593	608	618	(10)
(11)		CDD18.3	3379	313	288	318	301	253	189	190	209	267	335	358	359	(11)
(12)		CDH23.3	37101	3697	3389	3693	3348	2337	1470	1502	1752	2647	3943	4669	4655	(12)
(13)	CDH26.7	15562	1421	1328	1428	1372	925	495	521	662	1079	1718	2338	2275	(13)	
(14)	Wind	WSAvg	3.1	3.9	3.3	2.9	2.6	2.9	3.1	3.0	2.9	3.0	3.1	3.1	3.2	(14)
(15)	Precipitation	PrecAvg	1254	309	271	204	65	20	3	3	1	8	41	89	240	(15)
(16)		PrecMax	1979	702	551	465	294	154	56	31	4	31	228	196	503	(16)
(17)		PrecMin	762	148	105	68	0	1	0	1	0	1	5	27	58	(17)
(18)		PrecStd	278	118	113	121	75	36	10	6	1	7	47	41	127	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	34.2	34.6	34.5	34.3	33.5	32.7	32.4	33.0	34.8	35.7	36.0	36.0	(19)
(20)			MCWB	25.8	25.9	25.3	22.7	21.6	21.5	19.0	18.2	20.4	20.6	24.1	24.9	(20)
(21)		2%	DB	33.1	33.6	33.3	33.5	32.7	31.5	31.5	31.8	33.6	34.4	35.0	34.9	(21)
(22)			MCWB	26.1	26.1	25.4	23.2	21.0	20.6	18.8	18.2	20.7	22.6	24.9	25.5	(22)
(23)		5%	DB	32.2	32.7	32.5	32.8	32.0	30.5	30.6	31.0	32.5	33.4	34.2	34.1	(23)
(24)			MCWB	26.0	26.1	25.5	23.5	20.9	20.0	18.6	18.4	21.2	23.5	24.9	25.7	(24)
(25)		10%	DB	31.4	31.8	31.7	32.2	31.1	29.6	29.6	30.1	31.6	32.6	33.5	33.3	(25)
(26)			MCWB	25.8	25.9	25.6	23.5	20.9	19.4	18.4	18.4	21.6	23.8	25.0	25.8	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.6	27.8	27.7	27.2	25.7	24.6	23.4	23.9	25.4	26.6	27.2	27.7	(27)
(28)			MCDWB	31.3	31.6	30.5	30.1	28.6	28.3	27.0	27.6	29.5	31.5	32.0	31.8	(28)
(29)		2%	WB	27.1	27.4	27.2	26.6	25.1	23.6	22.5	23.2	24.7	26.1	26.7	27.2	(29)
(30)			MCDWB	30.9	31.1	30.4	30.1	28.0	27.6	26.3	27.1	28.8	30.6	31.2	31.4	(30)
(31)		5%	WB	26.6	26.8	26.7	26.0	24.5	22.7	21.8	22.7	24.4	25.6	26.4	26.9	(31)
(32)			MCDWB	30.3	30.5	30.1	29.8	27.9	27.0	26.0	26.6	28.4	30.0	30.9	31.1	(32)
(33)		10%	WB	26.3	26.4	26.4	25.5	23.7	21.8	21.0	22.1	24.0	25.2	26.1	26.5	(33)
(34)			MCDWB	29.8	29.9	29.7	29.2	27.7	26.6	25.9	26.0	27.9	29.4	30.6	30.8	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	5.4	5.7	6.1	7.7	9.3	9.8	10.9	11.3	9.5	7.8	7.4	6.6	(35)
(36)			MCDBR	6.7	7.1	7.3	8.4	10.0	10.0	11.4	12.0	10.3	8.9	8.0	7.5	(36)
(37)			MCWBR	2.6	3.0	2.8	3.0	4.0	4.0	4.3	4.1	3.6	2.9	2.8	2.6	(37)
(38)		5% WB	MCDWB	5.9	6.5	6.5	6.9	7.5	9.2	9.8	9.2	8.2	7.2	7.3	6.8	(38)
(39)			MCWBR	2.8	3.0	2.8	2.6	2.7	3.3	3.6	2.9	2.6	2.5	2.8	2.7	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.423	0.414	0.393	0.377	0.370	0.345	0.341	0.355	0.412	0.439	0.438	0.417	(40)	
(41)		taud	2.485	2.510	2.572	2.571	2.535	2.566	2.561	2.510	2.393	2.341	2.383	2.486	(41)	
(42)		Ebn at Noon	923	923	924	906	879	887	899	913	892	889	902	926	(42)	
(43)		Edh at Noon	117	113	104	98	96	90	92	103	122	133	129	117	(43)	
(44)	All-Sky Solar Radiation	RadAvg	5.68	5.80	5.87	5.80	5.36	5.12	5.39	6.10	6.74	7.01	6.98	6.18	(44)	
(45)		RadStd	0.68	0.83	0.71	0.48	0.32	0.21	0.17	0.13	0.19	0.28	0.25	0.53	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page