

PORT KEATS AF, Australia

WMO: 951110

Lat: 14.2494S

Lon: 129.5283E

Elev: 95

StdP: 14.65

Time Zone: 9.50 (AUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	56.3	59.0	24.0	18.3	77.4	27.4	21.4	77.2	17.0	75.8	16.3	76.5	3.3	160	0.366

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11	14.4	96.0	73.8	94.7	74.7	93.6	75.2	82.9	88.2	81.6	88.1	80.8	87.7	9.6	80

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
81.8	165.8	85.4	80.0	156.5	84.6	79.1	151.3	84.5	47.1	87.6	45.5	88.1	44.6	87.6	88.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.5	14.4	13.1	51.6	99.9	3.4	1.7	49.2	101.1	47.2	102.1	45.4	103.0	42.9	104.2
			45.1	83.1	2.0	0.8	43.7	83.7	42.6	84.2	41.5	84.6	40.0	85.3
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	81.0	83.4	83.0	83.8	83.1	78.9	75.1	75.1	75.8	80.1	84.0	85.4	84.8	(6)
	DBStd	4.73	2.49	2.47	2.04	2.33	3.67	4.33	3.51	2.92	3.13	2.24	2.13	2.66	(7)
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
	HDD65	1	0	0	0	0	0	1	0	0	0	0	0	0	(9)
	CDD50	11321	1035	924	1048	992	896	753	778	799	903	1054	1061	1078	(10)
	CDD65	5847	570	504	583	542	431	304	313	334	453	589	611	613	(11)
	CDH74	65654	6665	5677	6657	6079	4394	2671	2893	3231	4773	7166	7798	7650	(12)
	CDH80	29061	2758	2254	2927	2899	1993	1005	1108	1293	2075	3335	3810	3604	(13)
(14) Wind	WSAvg	5.9	6.0	5.6	4.6	4.8	6.2	7.0	6.6	6.0	5.5	6.2	6.1	6.0	(14)
(15) Precipitation	PrecAvg	54.2	13.2	12.5	8.8	3.4	1.1	0.4	0.2	0.1	0.2	1.2	2.9	10.2	(15)
	PrecMax	89.3	23.1	25.6	22.0	12.2	6.7	3.0	0.6	0.6	1.0	6.4	4.7	21.1	(16)
	PrecMin	28.9	4.8	4.2	2.2	0.4	0.0	0.0	0.0	0.0	0.0	0.6	0.6	1.6	(17)
	PrecStd	13.3	5.0	5.7	5.8	2.9	1.4	0.6	0.1	0.1	0.2	1.3	0.9	4.9	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	95.9	94.7	96.2	96.6	94.4	91.7	91.6	92.5	95.3	97.5	97.1	96.9	(19)
		MCWB	76.2	78.5	76.0	73.0	69.8	68.9	66.3	63.4	66.3	67.8	73.9	77.5	(20)
	2%	DB	92.9	92.9	94.3	94.9	92.8	89.8	89.6	90.0	92.9	94.8	94.9	94.5	(21)
		MCWB	79.4	78.6	76.7	73.2	69.5	67.9	65.1	64.4	68.6	71.9	76.3	78.4	(22)
	5%	DB	91.2	91.1	92.7	93.5	91.3	88.0	88.0	88.3	90.9	92.9	93.4	93.0	(23)
		MCWB	79.7	79.0	77.3	73.6	69.8	66.9	65.1	64.5	70.5	74.4	77.0	79.0	(24)
	10%	DB	89.6	89.2	91.1	91.9	89.7	86.1	86.2	86.7	89.1	91.3	92.1	91.5	(25)
		MCWB	79.6	79.1	77.8	74.0	69.5	65.8	64.8	64.8	71.1	74.9	77.3	79.1	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	86.3	84.3	82.1	81.6	78.7	75.6	73.9	75.0	77.8	79.9	82.4	83.5	(27)
		MCDB	88.8	86.1	89.5	89.1	86.5	83.6	83.5	84.2	85.9	88.0	87.8	90.0	(28)
	2%	WB	83.4	82.2	81.0	80.1	77.4	73.6	72.3	73.6	76.6	79.0	80.8	81.6	(29)
		MCDB	87.6	87.8	88.6	87.8	84.3	82.1	81.9	82.9	84.6	86.8	88.4	89.0	(30)
	5%	WB	81.6	80.9	80.3	79.0	76.1	71.8	70.5	72.5	76.0	78.3	80.0	80.7	(31)
		MCDB	87.0	87.4	87.8	87.0	83.3	81.6	80.2	81.4	84.0	86.1	87.9	88.5	(32)
	10%	WB	80.5	80.1	79.6	78.1	74.5	69.6	68.6	71.4	75.3	77.8	79.2	80.0	(33)
		MCDB	86.1	86.6	86.9	85.6	82.6	80.6	79.6	79.8	83.3	85.6	87.3	87.7	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	12.0	12.1	15.2	18.8	22.0	22.3	23.4	23.8	19.8	16.3	14.4	13.1	(35)
		MCDBR	14.5	15.3	18.2	21.0	23.4	22.9	24.8	25.7	21.3	18.3	15.8	15.0	(36)
	5% WB	MCWBR	6.1	6.4	6.7	7.1	8.2	9.0	9.4	9.7	7.7	6.4	5.7	5.7	(37)
		MCWBR	13.1	13.3	15.1	16.6	17.3	20.9	21.9	19.7	16.9	15.0	14.0	13.4	(38)
(40) Clear-Sky Solar Irradiance	taub		0.417	0.416	0.395	0.375	0.368	0.346	0.341	0.359	0.424	0.452	0.454	0.426	(40)
		taud	2.511	2.511	2.572	2.589	2.541	2.555	2.564	2.506	2.365	2.313	2.345	2.468	(41)
	Ebn at Noon		294	292	292	288	279	280	285	289	279	279	282	291	(42)
		Edh at Noon	36	36	33	31	30	29	29	33	40	43	43	38	(43)
(44) All-Sky Solar Radiation	RadAvg		1784	1799	1844	1859	1705	1612	1707	1920	2110	2192	2122	1904	(44)
	RadStd		189	262	214	121	84	65	48	49	76	89	94	166	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (4 neighbors)	N/A	-1.55	N/A	+1.22	+0.40	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page