

MIDDLE POINT, Australia

WMO: 951210

Lat: 12.6050S

Lon: 131.2989E

Elev: 15

StdP: 101.14

Time Zone: 9.50 (AUC)

Period: 03-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.2	12.8	0.5	3.9	28.6	3.1	4.7	25.8	8.0	30.6	7.4	30.4	1.5	180	0.354

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11	11.3	36.8	23.1	36.1	23.5	35.3	23.7	27.6	32.3	27.1	31.9	26.8	31.4	4.2	10

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.4	22.0	29.3	26.0	21.4	28.9	25.7	21.0	28.6	87.7	32.4	85.8	32.0	84.3	31.6	30.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
7.5	6.6	6.0	DB	7.9	38.8	1.9	0.9	6.5	39.5	5.4	40.0	4.3	40.5	2.9	41.1
			WB	6.5	28.6	1.7	0.7	5.3	29.1	4.3	29.4	3.3	29.8	2.0	30.3

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	27.2	28.3	28.4	28.5	28.1	26.2	23.8	23.7	24.4	27.3	29.1	29.4	29.1
	DBStd	2.65	1.42	1.31	1.24	1.29	2.02	2.55	2.19	2.03	1.69	1.14	1.06	1.28
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	1	0	0	0	0	0	1	1	0	0	0	0	0
	CDD10.0	6268	568	516	574	543	501	414	423	445	518	591	583	593
	CDD18.3	3227	309	282	316	293	243	164	166	187	268	332	333	334
	CDH23.3	35147	3207	2901	3234	3061	2400	1710	1877	2248	3116	3949	3812	3632
	CDH26.7	16583	1240	1159	1300	1428	1121	765	878	1159	1753	2198	1948	1635
Wind	WSAvg	2.4	2.7	2.5	2.2	2.1	2.3	2.5	2.5	2.5	2.5	2.6	2.4	2.3
Precipitation	PrecAvg	1406	344	272	265	71	12	1	1	2	13	59	131	221
	PrecMax	2186	866	522	553	207	75	29	22	14	68	163	236	484
	PrecMin	875	135	48	44	1	0	0	0	0	0	0	29	19
	PrecStd	273	137	119	126	56	17	5	4	3	18	47	61	118
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	35.6	35.7	35.7	35.3	34.6	33.9	34.0	35.2	37.2	38.1	37.7	36.9
		MCWB	26.3	26.0	25.9	23.8	22.4	21.7	20.7	19.9	20.6	22.1	23.9	25.6
	2%	DB	34.4	34.6	34.5	34.5	33.6	32.8	33.0	34.1	36.0	36.9	36.5	35.7
		MCWB	26.3	26.2	25.9	23.7	22.5	21.2	20.1	19.8	21.1	22.4	24.3	25.9
	5%	DB	33.4	33.7	33.6	33.7	32.9	32.0	32.2	33.1	35.2	36.0	35.5	34.7
		MCWB	26.3	26.2	25.9	23.7	22.5	20.8	19.8	19.3	21.2	22.8	24.5	25.8
	10%	DB	32.3	32.6	32.6	33.0	32.0	31.0	31.2	32.2	34.3	35.1	34.5	33.6
		MCWB	26.2	26.1	25.9	23.8	22.4	20.1	19.4	19.1	21.3	23.0	24.7	25.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	28.1	28.2	27.8	27.1	26.1	24.4	23.9	23.6	25.2	26.2	27.2	27.8
		MCDB	32.9	31.9	32.5	31.4	30.3	29.8	29.9	31.3	31.6	32.3	32.9	33.2
	2%	WB	27.3	27.4	27.2	26.5	25.4	23.4	22.9	22.8	24.5	25.7	26.6	27.1
		MCDB	32.0	31.9	31.7	30.6	29.7	29.4	29.4	30.0	31.0	31.7	32.4	32.5
	5%	WB	26.9	26.9	26.8	26.0	24.9	22.6	22.1	22.2	24.0	25.2	26.1	26.7
		MCDB	31.3	31.6	31.1	30.0	29.2	28.8	28.8	29.0	30.3	31.2	31.9	32.0
	10%	WB	26.5	26.5	26.4	25.6	24.3	21.8	21.2	21.4	23.5	24.8	25.6	26.3
		MCDB	30.6	30.7	30.5	29.4	28.6	28.0	27.8	28.3	29.7	30.7	31.3	31.4
Mean Daily Temperature Range	5% DB	MDBR	7.6	8.1	8.3	10.5	12.7	15.3	16.4	17.3	15.6	13.5	11.3	9.3
		MCDBR	9.8	10.3	10.3	11.6	13.2	14.9	16.3	17.5	16.5	14.7	12.7	11.2
		MCWBR	3.4	3.6	3.3	3.2	4.0	4.9	5.4	5.6	4.9	3.9	3.3	3.4
	5% WB	MCDBR	8.4	8.9	8.8	9.4	10.3	13.3	14.1	15.3	13.6	12.2	11.0	9.8
		MCWBR	3.4	3.5	3.3	2.9	3.3	4.7	5.1	5.3	4.0	3.4	3.6	3.5
Clear-Sky Solar Irradiance	taub	0.422	0.411	0.399	0.377	0.372	0.354	0.347	0.367	0.431	0.454	0.456	0.424	
	taud	2.473	2.499	2.531	2.571	2.534	2.529	2.544	2.476	2.320	2.281	2.312	2.450	
	Ebn at Noon	923	926	919	909	881	882	897	905	876	877	885	919	
	Edh at Noon	118	115	108	99	97	94	95	107	132	141	138	121	
All-Sky Solar Radiation	RadAvg	5.23	5.47	5.59	5.80	5.40	5.19	5.43	6.07	6.57	6.77	6.42	5.72	
	RadStd	0.52	0.79	0.67	0.45	0.27	0.17	0.13	0.17	0.27	0.28	0.23	0.51	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A
Regional (10 neighbors)	+0.32	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page