

NGAYAWILI, Australia

WMO: 951460

Lat: 11.997S

Lon: 135.572E

Elev: 30

StdP: 14.68

Time Zone: 9.50 (AUC)

Period: 99-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	64.1	66.1	52.7	59.1	77.9	55.2	64.9	76.2	18.2	76.8	16.7	77.9	6.3	160	0.412

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	10.0	92.0	78.0	91.2	78.5	90.4	78.5	83.9	87.3	82.8	86.9	82.0	86.6	12.4	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
83.2	173.3	86.1	81.8	165.8	85.7	80.8	160.2	85.4	48.2	87.4	46.9	87.0	46.0	86.6	92.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
28.1	23.5	20.0	DB	58.6	95.2	3.4	1.1	56.2	96.0	54.2	96.7	52.2	97.3	49.8	98.1
			WB	56.6	86.4	2.2	3.6	54.9	89.0	53.6	91.1	52.4	93.2	50.7	95.8

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	80.8	83.6	83.2	82.7	81.6	80.0	76.8	76.3	76.7	79.1	81.5	83.4	84.5
	DBStd	3.60	2.16	2.10	2.01	1.69	2.18	3.08	2.38	2.29	2.30	2.14	1.91	2.23
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	11229	1042	929	1013	947	930	803	814	829	873	977	1002	1070
	CDD65	5754	577	509	548	497	465	353	349	364	423	512	552	605
	CDH74	60880	7174	6155	6242	5150	4266	2454	2304	2767	3946	5725	6871	7826
	CDH80	22824	2913	2358	2272	1737	1269	584	532	797	1407	2327	3049	3579
(14) Wind	WSAvg	9.4	13.5	13.3	9.2	7.0	8.1	9.2	8.7	7.9	7.6	8.3	8.9	10.7
(15) Precipitation	PrecAvg	57.5	14.5	13.1	11.8	5.4	1.1	0.2	0.1	0.0	0.0	0.2	2.5	8.7
	PrecMax	87.2	37.6	32.9	26.9	17.9	6.1	2.7	0.6	0.8	0.5	1.7	22.3	25.5
	PrecMin	25.2	4.0	3.7	2.0	0.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.4
	PrecStd	15.2	6.7	6.0	6.1	4.8	1.3	0.4	0.2	0.1	0.1	0.4	3.7	5.6
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	91.7	91.5	91.5	91.6	89.9	88.0	87.2	88.9	91.5	93.3	93.2	92.7
		MCWB	80.8	80.1	79.7	78.7	77.0	74.8	72.2	71.0	72.8	74.1	77.3	78.9
	2%	DB	90.2	89.9	89.9	90.0	88.6	86.3	85.8	87.2	89.8	91.4	91.5	91.7
		MCWB	80.7	80.0	79.9	77.8	76.7	74.1	71.9	70.9	73.4	75.8	78.7	79.4
	5%	DB	89.1	88.9	88.8	88.8	87.4	85.0	84.6	85.9	88.3	89.9	90.4	90.9
		MCWB	80.6	80.0	79.9	77.6	76.2	73.4	71.6	70.7	73.7	76.6	78.7	79.6
	10%	DB	87.9	87.7	87.6	87.5	86.0	83.6	83.3	84.5	86.8	88.6	89.4	89.9
		MCWB	80.4	80.0	79.9	77.5	75.5	72.7	71.1	70.3	73.6	76.7	78.7	79.5
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	84.6	84.4	86.2	84.5	81.6	80.0	78.1	78.4	79.5	82.8	83.7	83.9
		MCDB	88.1	87.2	86.9	87.3	86.2	83.7	83.1	83.8	86.6	87.3	89.3	89.0
	2%	WB	83.3	82.7	83.4	81.8	79.6	77.1	76.1	75.8	78.0	80.8	81.9	82.6
		MCDB	87.0	86.1	86.1	85.9	85.0	82.3	81.4	82.2	85.4	86.8	87.8	88.2
	5%	WB	82.3	81.8	82.0	80.1	78.2	75.6	74.6	74.1	76.8	79.2	80.9	81.6
		MCDB	86.4	85.8	86.4	85.2	83.8	81.7	80.2	81.2	83.8	86.1	87.4	87.8
	10%	WB	81.6	81.0	80.9	79.1	77.3	74.5	73.3	72.8	75.7	78.2	80.0	80.7
		MCDB	86.2	85.5	86.1	84.2	83.1	80.8	79.6	80.5	82.9	85.5	87.0	87.4
(35) Mean Daily Temperature Range	5% DB	MDBR	7.9	8.0	9.4	12.2	13.1	14.4	15.6	17.5	17.1	15.3	13.1	10.0
		MCDBR	9.5	9.9	11.5	14.6	14.4	14.7	16.1	18.2	18.2	16.7	14.1	11.5
		MCWBR	4.6	4.5	5.2	5.6	5.4	5.3	5.4	5.9	6.0	5.7	5.3	4.7
	5% WB	MCDBR	7.9	7.5	9.9	12.5	12.8	13.4	14.0	16.0	16.0	14.8	11.8	9.3
		MCWBR	5.1	4.8	6.1	6.5	6.2	6.0	6.5	7.4	7.3	7.1	5.9	5.1
(40) Clear-Sky Solar Irradiance	taub	0.417	0.405	0.393	0.385	0.381	0.371	0.360	0.365	0.396	0.414	0.420	0.412	(40)
	taud	2.529	2.563	2.599	2.605	2.584	2.582	2.609	2.568	2.461	2.426	2.451	2.522	(41)
	Ebn at Noon	294	296	293	286	277	275	281	288	288	290	291	295	(42)
	Edh at Noon	36	34	32	30	30	29	28	31	36	39	38	36	(43)
(44) All-Sky Solar Radiation	RadAvg	1647	1680	1647	1647	1578	1504	1600	1865	2092	2211	2161	1885	(44)
	RadStd	216	263	184	215	131	99	71	69	79	99	107	200	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (4 neighbors)	N/A	N/A	N/A	+0.74	+0.32	+0.47	N/A	N/A	N/A	N/A

Nomenclature: See separate page