

WYNDHAM AP, Australia

WMO: 952140

Lat: 15.510S

Lon: 128.150E

Elev: 14

StdP: 14.69

Time Zone: 8.00 (E08)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	53.3	56.0	19.0	14.3	80.7	22.2	16.7	78.1	22.4	76.8	20.7	78.3	3.2	80	0.459

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11	20.5	105.6	73.4	103.8	73.7	102.0	74.0	82.7	90.7	81.5	90.0	80.6	89.6	10.1	350

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
81.2	161.9	85.9	79.7	154.0	84.7	78.6	148.7	84.3	46.7	90.4	45.3	90.2	44.3	89.3	95.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 22.6	19.7	17.5	48.0	109.4	3.0	1.5	45.8	110.5	44.1	111.3	42.4	112.2	40.2	113.2		
(5)			39.6	84.2	2.5	3.7	37.8	86.9	36.4	89.1	35.0	91.2	33.2	93.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	84.1	87.7	87.3	87.4	86.0	80.1	74.5	74.5	76.8	84.7	89.5	91.2	90.0		
	DBStd	7.15	3.86	4.09	3.62	3.46	4.82	5.33	4.67	4.41	4.05	3.15	3.25	4.33		
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0		
	HDD65	3	0	0	0	0	0	2	1	0	0	0	0	0		
	CDD50	12452	1170	1044	1159	1079	932	735	760	831	1041	1224	1237	1240		
	CDD65	6980	705	624	694	629	467	287	296	366	591	759	787	775		
	CDH74	92398	9385	8213	9160	8191	5459	3124	3445	4496	7726	10737	11449	11013		
	CDH80	52366	5110	4404	4943	4648	2853	1377	1600	2319	4573	6628	7219	6692		
(14) Wind	WSAvg	7.8	8.0	7.5	6.6	6.8	7.4	7.5	7.4	7.8	8.5	9.2	8.8	8.4		
(15) Precipitation	PrecAvg	29.9	6.7	7.6	5.7	1.1	0.3	0.1	0.2	0.0	0.1	0.8	2.2	5.4		
	PrecMax	56.3	14.3	14.8	16.9	5.9	3.9	0.9	3.3	0.0	1.9	4.2	6.9	12.3		
	PrecMin	18.2	1.4	1.7	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.6		
	PrecStd	8.5	3.3	3.3	4.2	1.4	0.7	0.2	0.6	0.0	0.4	1.1	1.8	3.5		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	105.2	105.1	104.3	102.6	98.5	95.1	95.0	97.4	103.0	106.4	107.6	108.0		
		MCWB	75.2	75.2	73.9	72.7	71.0	69.6	66.1	68.1	68.6	70.3	72.1	74.8		
	2%	DB	101.8	102.1	101.1	100.3	96.5	92.5	92.9	95.1	100.8	104.2	105.2	105.0		
		MCWB	77.0	75.6	75.8	72.0	68.9	67.8	65.1	66.3	68.6	71.1	73.1	76.0		
	5%	DB	99.0	99.3	98.9	98.6	94.7	90.4	91.1	93.2	98.9	102.2	103.1	102.1		
		MCWB	78.0	76.8	76.3	71.9	69.0	66.0	64.0	65.0	68.8	71.6	73.9	76.8		
	10%	DB	96.3	96.0	96.5	96.8	92.7	88.0	88.8	91.1	97.1	100.2	100.8	99.2		
		MCWB	78.4	78.0	76.7	71.7	68.1	64.4	62.9	63.4	68.5	71.6	74.8	77.6		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	83.1	82.4	84.4	82.0	79.5	74.9	71.1	73.0	76.8	79.2	85.2	89.1		
		MCDB	92.5	89.8	90.8	93.8	86.1	83.7	89.2	90.1	88.2	90.8	95.0	99.2		
	2%	WB	81.6	81.4	82.3	79.0	77.0	72.0	69.2	71.3	75.1	77.8	79.8	82.2		
		MCDB	91.0	89.5	89.4	87.0	85.0	86.2	86.8	88.4	88.7	89.6	90.1	90.1		
	5%	WB	80.7	80.7	81.0	77.7	75.0	69.8	66.9	69.9	73.8	76.8	78.9	80.6		
		MCDB	90.2	89.2	89.1	86.4	86.4	85.7	84.9	86.3	88.8	89.1	89.4	89.4		
	10%	WB	80.0	80.0	80.0	76.6	72.8	67.3	64.8	68.0	72.7	75.9	78.1	79.7		
		MCDB	89.4	88.4	88.2	86.5	86.5	83.2	83.8	84.1	88.6	89.3	89.6	89.2		
(35) Mean Daily Temperature Range	5% DB	MDBR	16.1	16.1	16.6	21.5	24.2	25.5	27.8	29.2	26.1	23.0	20.5	18.1		
		MCDBR	20.2	20.9	20.8	23.6	25.8	26.1	29.3	29.7	26.6	25.2	23.1	21.8		
		MCWBR	6.0	5.9	6.4	6.5	8.2	9.3	10.7	10.4	8.1	7.2	6.4	6.3		
		MCDBR	16.9	16.3	16.8	17.6	18.4	22.1	25.3	24.4	22.8	21.6	20.4	18.7		
	5% WB	MCWBR	6.0	5.7	6.8	6.2	7.3	8.1	9.7	8.9	6.7	6.3	6.5	7.2		
(40) Clear-Sky Solar Irradiance	taub		0.417	0.415	0.399	0.381	0.374	0.345	0.349	0.365	0.425	0.447	0.456	0.426		
	taud		2.466	2.475	2.515	2.503	2.453	2.496	2.462	2.395	2.279	2.255	2.283	2.422		
	Ebn at Noon		294	292	291	285	276	279	281	285	278	280	281	292		
	Edh at Noon		38	37	35	33	33	30	32	36	43	46	45	40		
(44) All-Sky Solar Radiation	RadAvg		1966	1961	1912	1889	1712	1619	1715	1954	2154	2242	2208	2035		
	RadStd		157	245	222	129	112	71	59	56	86	114	95	127		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
(46)	Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(46)
(47)	Regional (4 neighbors)	N/A	N/A	N/A	+1.17	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page