

COOKTOWN, Australia

WMO: 952830

Lat: 15.4461S

Lon: 145.1861E

Elev: 6

StdP: 101.26

Time Zone: 10.00 (E10)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.2	15.1	11.0	8.1	18.5	12.3	8.9	19.2	10.1	23.9	9.3	24.1	1.0	300	0.408

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	6.7	33.8	25.9	32.4	25.6	31.5	25.3	27.4	30.6	26.9	30.2	26.5	29.6	4.8	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.7	22.3	28.5	26.1	21.5	28.3	25.7	20.9	28.0	87.2	30.8	84.7	30.4	83.0	29.9	33.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.6	8.6	8.1	DB	10.8	36.9	2.2	1.5	9.2	38.0	7.9	38.9	6.7	39.8	5.1	40.9	(4)
(5)			WB	10.4	30.0	2.0	1.6	8.9	31.2	7.8	32.1	6.6	33.0	5.2	34.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	25.4	27.8	27.7	26.9	25.9	24.3	22.7	21.9	22.4	24.3	26.0	27.2	28.0	(6)	
	DBStd	2.62	1.25	1.23	1.09	1.26	1.62	1.97	2.08	1.86	1.54	1.25	1.11	1.23	(7)	
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)	
	HDD18.3	4	0	0	0	0	0	1	2	1	0	0	0	0	(9)	
	CDD10.0	5632	552	496	525	478	443	382	368	386	429	496	517	559	(10)	
	CDD18.3	2594	294	263	267	228	185	133	112	128	179	237	267	301	(11)	
	CDH23.3	21453	3071	2652	2518	1939	1102	498	345	502	1031	1891	2616	3288	(12)	
	CDH26.7	5567	1060	872	662	315	77	21	6	24	131	432	784	1183	(13)	
(14) Wind	WSAvg	4.2	3.3	2.9	3.4	4.5	4.4	4.3	4.4	4.5	5.0	5.1	4.8	4.1	(14)	
(15) Precipitation	PrecAvg	1652	324	362	361	167	57	40	28	20	13	24	67	182	(15)	
	PrecMax	2742	676	634	1016	610	248	118	74	70	43	158	493	679	(16)	
	PrecMin	667	83	35	35	11	0	6	1	1	0	0	0	13	(17)	
	PrecStd	514	185	151	236	149	51	28	19	18	12	32	105	150	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	35.7	35.2	33.1	30.2	29.2	28.2	27.4	28.4	30.0	32.2	33.9	35.5	(19)	
		MCWB	26.2	25.8	26.2	25.4	24.2	23.2	21.6	22.0	23.0	24.4	25.3	25.8	(20)	
	2%	DB	33.4	33.1	31.2	29.6	28.1	27.2	26.5	27.3	28.7	30.5	31.7	33.0	(21)	
		MCWB	26.1	26.2	26.0	24.8	23.3	22.4	21.3	21.3	22.4	24.0	24.7	25.8	(22)	
	5%	DB	31.9	31.5	30.3	29.0	27.5	26.5	25.9	26.6	28.0	29.6	30.8	32.0	(23)	
		MCWB	25.8	26.0	25.6	24.4	23.0	21.9	20.8	20.7	21.9	23.3	24.2	25.0	(24)	
	10%	DB	30.9	30.6	29.6	28.4	27.0	25.8	25.2	25.9	27.4	28.9	30.1	31.2	(25)	
		MCWB	25.5	25.8	25.2	24.0	22.6	21.5	20.5	20.2	21.4	22.6	23.7	24.8	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.9	28.2	27.7	26.7	25.6	24.4	23.6	24.1	25.2	26.9	27.7	28.2	(27)	
		MCDB	32.4	31.1	30.3	29.1	27.8	26.5	25.6	26.6	27.8	28.0	29.7	30.5	(28)	
	2%	WB	27.1	27.2	26.8	26.0	24.7	23.5	22.7	22.9	24.1	25.2	26.1	26.9	(29)	
		MCDB	30.8	30.5	29.9	28.3	26.9	25.8	25.0	25.3	26.9	28.4	29.2	30.4	(30)	
	5%	WB	26.6	26.7	26.4	25.5	24.1	22.9	22.1	22.1	23.3	24.6	25.5	26.4	(31)	
		MCDB	30.1	29.9	29.2	27.7	26.3	25.4	24.4	24.8	26.4	27.8	28.8	29.8	(32)	
	10%	WB	26.2	26.3	26.0	25.0	23.5	22.3	21.5	21.4	22.6	23.9	25.0	25.9	(33)	
		MCDB	29.4	29.3	28.4	27.1	25.9	24.9	24.1	24.5	26.0	27.2	28.5	29.3	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	6.7	6.4	5.6	5.1	5.6	6.3	7.0	7.2	6.7	6.4	6.4	6.7	(35)	
		MCDBR	8.5	8.1	6.7	5.5	6.1	6.5	7.2	7.8	7.3	7.4	7.3	8.1	(36)	
	5% WB	MCWBR	3.0	2.9	2.7	2.6	3.0	3.1	3.5	3.5	3.0	2.7	2.5	2.7	(37)	
		MCWBR	7.4	6.9	6.1	5.0	4.9	5.7	5.4	6.2	6.8	6.8	7.0	7.4	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.402	0.400	0.395	0.388	0.377	0.372	0.359	0.361	0.388	0.402	0.406	0.406	(40)	
		taud	2.535	2.546	2.554	2.550	2.546	2.552	2.572	2.551	2.455	2.433	2.453	2.491	(41)	
	Ebn at Noon		943	936	921	892	868	855	878	905	913	923	932	938	(42)	
		Edh at Noon	112	109	105	100	94	91	91	98	114	121	120	116	(43)	
(44) All-Sky Solar Radiation	RadAvg		5.86	5.63	5.27	5.11	4.52	4.07	4.38	5.25	6.24	6.78	6.87	6.46	(44)	
	RadStd		0.52	0.68	0.39	0.47	0.35	0.28	0.30	0.31	0.24	0.38	0.47	0.70	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (6 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page