

BOUGAINVILLE REEF, AustraliaWMO: **952880**Lat: **15.488S**Lon: **147.118E**Elev: **13**StdP: **101.17**Time Zone: **10.00 (E10)**Period: **96-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	21.2	21.9	N/A	N/A	N/A	N/A	N/A	N/A	15.1	23.7	14.4	23.8	9.0	140	0.736

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	1.9	30.2	N/A	29.7	N/A	29.5	N/A	N/A	N/A	N/A	N/A	N/A	N/A	4.7	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 14.8	13.9	13.1	DB	21.0	32.0	0.8	1.6	20.5	33.2	20.0	34.1	19.6	35.0	19.0	36.2	(4)
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A (5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	26.0	27.9	28.2	27.7	26.8	25.7	24.6	23.9	23.7	24.3	25.4	26.6	27.7
	DBStd	1.85	1.13	0.97	1.17	1.02	1.06	0.92	0.87	0.86	0.85	0.94	0.90	0.96
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	5847	556	509	547	504	488	437	432	424	429	476	498	547
	CDD18.3	2806	297	276	289	254	229	187	173	166	179	218	248	289
	CDH23.3	25048	3566	3359	3369	2647	1941	1013	627	447	782	1562	2440	3296
	CDH26.7	4898	1131	1153	972	406	64	2	2	1	2	38	263	866
Wind	WSAvg	8.1	6.5	6.3	7.5	9.5	9.6	9.8	10.0	8.9	8.4	7.7	7.0	6.3
Precipitation	PrecAvg	1738	303	366	348	157	83	59	47	35	29	51	73	187
	PrecMax	2813	671	856	875	576	280	134	114	195	102	198	325	510
	PrecMin	753	29	17	20	2	1	2	1	0	0	0	0	35
	PrecStd	499	164	200	214	124	55	34	29	39	29	52	90	132
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	30.4	30.9	31.3	29.0	28.2	26.9	26.2	26.2	26.8	28.2	29.4	30.4
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	29.7	30.2	29.9	28.6	27.7	26.6	25.7	25.6	26.3	27.6	28.7	29.6
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	29.5	29.8	29.4	28.4	27.4	26.2	25.5	25.2	25.9	27.1	28.2	29.2
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	10%	DB	29.2	29.5	29.1	28.1	27.0	26.0	25.2	24.7	25.5	26.7	27.8	29.0
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	1.9	1.9	1.9	1.5	1.5	1.2	1.2	1.0	0.9	0.9	1.2	1.5
		MCDBR	2.1	2.4	2.1	2.0	2.1	1.4	1.8	1.2	1.1	1.4	1.7	1.9
	5% WB	MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	Clear-Sky Solar Irradiance	taub	0.395	0.391	0.398	0.393	0.384	0.381	0.364	0.368	0.380	0.395	0.394	0.393
		taud	2.595	2.619	2.584	2.578	2.567	2.565	2.597	2.572	2.519	2.491	2.530	2.570
Ebn at Noon		949	945	918	888	862	846	874	898	920	929	943	950	
Edh at Noon		105	102	102	97	92	90	89	96	107	114	111	108	
All-Sky Solar Radiation	RadAvg	6.41	6.17	5.58	5.30	4.65	4.17	4.48	5.38	6.40	7.00	7.21	6.91	
	RadStd	0.60	0.57	0.40	0.44	0.39	0.32	0.32	0.34	0.23	0.35	0.51	0.72	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page