

GREEN ISLAND, Australia

WMO: 952890

Lat: 16.759S

Lon: 145.973E

Elev: 3

StdP: 101.29

Time Zone: 10.00 (E10)

Period: 94-10

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.7	19.4	N/A	N/A	N/A	N/A	N/A	N/A	18.1	20.5	17.0	21.6	6.7	160	0.662

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	5.2	32.8	N/A	31.9	N/A	31.0	N/A	N/A	N/A	N/A	N/A	N/A	N/A	5.6	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.1	15.0	14.0	DB	16.6	33.9	1.8	1.5	15.3	35.0	14.2	35.9	13.2	36.7	11.9	37.8	(4)
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	25.2	27.9	27.5	26.8	25.8	24.0	22.5	21.7	22.1	23.8	25.7	27.2	28.0
	DBStd	2.55	1.39	1.41	1.11	1.09	1.10	1.31	1.08	1.10	1.07	1.17	1.25	1.56
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	5566	555	491	519	473	434	376	362	376	416	488	516	559
	CDD18.3	2524	297	258	261	223	176	126	104	118	166	229	266	301
	CDH23.3	18641	3137	2643	2436	1708	677	158	41	114	568	1553	2441	3165
	CDH26.7	4097	932	680	407	119	5	1	0	1	27	257	636	1034
Wind	WSAvg	8.0	6.4	6.8	8.9	9.4	9.4	10.2	9.4	8.7	7.0	6.9	6.4	6.2
Precipitation	PrecAvg	2237	380	528	398	215	117	83	61	53	35	53	92	229
	PrecMax	3555	932	1376	1049	693	332	238	153	199	105	228	295	508
	PrecMin	826	87	81	62	12	8	16	14	0	0	0	1	32
	PrecStd	695	231	331	281	147	67	50	36	48	41	58	90	143
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	33.8	33.5	31.1	29.3	27.2	26.0	25.1	26.2	28.5	31.0	32.8	34.0
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	32.5	31.7	30.0	28.5	26.5	25.2	24.3	25.3	27.5	29.9	31.7	33.0
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	31.3	30.6	29.2	27.8	26.0	24.7	23.7	24.5	26.6	29.0	30.7	31.9
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	30.2	29.6	28.6	27.3	25.6	24.2	23.2	23.9	25.9	28.1	29.8	30.9
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	4.6	3.8	3.2	2.7	2.4	1.9	2.5	3.1	4.4	5.2	5.4	5.2
		MCDBR	6.3	5.3	4.2	3.3	2.9	2.3	3.3	4.4	5.4	6.4	6.8	6.7
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub	0.394	0.396	0.396	0.384	0.372	0.365	0.346	0.352	0.377	0.394	0.397	0.406	
	taud	2.584	2.584	2.566	2.583	2.583	2.589	2.626	2.597	2.503	2.478	2.508	2.513	
	Ebn at Noon	950	939	918	893	870	859	888	912	921	930	941	939	
	Edh at Noon	106	105	104	96	90	86	85	93	109	116	114	114	
All-Sky Solar Radiation	RadAvg	6.06	5.82	5.34	4.92	4.33	3.84	4.20	5.11	6.17	6.72	6.88	6.62	
	RadStd	0.52	0.65	0.46	0.47	0.38	0.34	0.31	0.37	0.29	0.40	0.54	0.72	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (6 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page