

SOUTH JOHNSTONE, Australia

WMO: 952920

Lat: 17.6053S

Lon: 145.9972E

Elev: 61

StdP: 14.66

Time Zone: 10.00 (E10)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	51.4	54.2	45.5	45.0	64.4	48.5	50.7	61.1	15.0	71.0	14.2	71.4	5.1	260	0.286

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	12.9	91.4	78.1	89.5	77.6	88.0	77.1	80.6	87.6	79.7	86.2	79.0	84.9	8.7	50

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
78.7	149.2	83.6	78.0	145.7	82.8	77.3	142.5	82.0	44.3	88.2	43.4	86.5	42.6	85.2	88.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.4	14.1	12.5	DB	47.9	96.7	2.4	2.8	46.2	98.7	44.8	100.4	43.5	101.9	41.8	104.0	(4)
(5)			WB	47.0	83.5	2.2	2.5	45.4	85.3	44.1	86.7	42.8	88.1	41.2	90.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	74.7	80.4	80.7	78.9	75.8	72.1	68.9	67.6	68.2	71.5	74.8	77.4	79.9	(6)	
	DBStd	5.42	2.18	2.42	2.15	2.25	3.03	3.70	3.67	3.07	2.78	2.49	2.13	2.16	(7)	
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)	
	HDD65	43	0	0	0	0	1	12	20	9	1	0	0	0	(9)	
	CDD50	9000	942	860	895	775	686	568	545	565	646	769	823	926	(10)	
	CDD65	3569	477	440	430	325	222	130	101	109	197	304	373	461	(11)	
	CDH74	25858	4468	4112	3415	1870	770	251	146	353	1077	2083	2982	4331	(12)	
	CDH80	7115	1487	1414	885	286	58	6	1	9	120	461	853	1535	(13)	
(14) Wind	WSAvg	5.6	5.1	4.8	5.7	6.3	5.8	5.6	5.9	5.5	5.4	6.0	5.8	5.3	(14)	
(15) Precipitation	PrecAvg	126.2	20.5	22.5	23.0	14.4	13.2	6.1	4.2	3.1	2.7	3.1	5.3	8.0	(15)	
	PrecMax	209.0	105.3	58.7	46.6	40.3	34.1	14.4	21.2	12.3	13.2	12.3	25.6	38.5	(16)	
	PrecMin	65.7	0.0	0.0	0.0	0.0	0.0	0.3	0.0	0.2	0.0	0.0	0.7	0.0	(17)	
	PrecStd	33.0	20.2	13.7	12.2	9.6	8.2	4.1	4.0	2.9	3.0	3.1	5.1	7.7	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	93.8	95.8	91.5	86.3	83.8	80.9	79.2	81.3	84.8	88.7	90.1	92.6	(19)	
		MCWB	78.0	76.3	77.8	74.0	73.1	72.0	70.0	69.2	70.3	73.4	75.9	77.9	(20)	
	2%	DB	90.3	91.7	88.3	84.7	81.7	78.4	77.3	79.2	82.7	86.0	87.5	90.0	(21)	
		MCWB	78.7	78.4	77.3	74.0	71.7	70.3	68.6	67.8	70.0	73.8	75.4	77.7	(22)	
	5%	DB	88.3	89.4	86.5	83.2	79.9	76.9	75.6	77.8	81.4	84.2	86.0	88.4	(23)	
		MCWB	77.9	78.0	76.5	73.7	71.1	69.3	67.5	67.2	69.6	72.5	74.4	77.0	(24)	
	10%	DB	86.8	87.5	84.8	81.6	78.2	75.2	74.0	76.0	79.8	82.7	84.6	87.0	(25)	
		MCWB	77.3	77.8	76.1	73.5	70.8	68.5	66.9	66.7	69.1	71.7	73.8	76.3	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	81.3	81.7	80.6	78.4	76.2	74.2	72.9	72.8	75.6	77.4	80.5	81.5	(27)	
		MCDB	88.4	89.0	87.1	82.7	80.7	77.6	75.8	76.6	80.6	85.3	87.2	88.4	(28)	
	2%	WB	80.1	80.5	79.2	77.0	74.4	72.6	71.1	71.2	73.9	75.7	77.8	79.9	(29)	
		MCDB	86.9	87.4	84.8	80.4	78.4	75.8	74.1	75.6	78.8	82.6	83.8	86.9	(30)	
	5%	WB	79.4	79.6	78.4	75.9	73.3	71.4	70.1	69.8	72.4	74.6	76.5	78.9	(31)	
		MCDB	85.4	85.9	83.4	79.6	77.3	74.8	73.4	74.3	77.8	80.9	82.5	85.5	(32)	
	10%	WB	78.7	78.8	77.6	75.0	72.3	70.3	69.0	68.5	71.0	73.4	75.5	78.0	(33)	
		MCDB	84.1	84.5	82.1	78.8	76.2	73.5	72.4	73.4	76.7	79.5	81.4	83.9	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	12.7	12.9	11.5	11.4	12.0	12.0	13.2	15.7	16.7	15.8	14.6	14.0	(35)	
		MCDBR	15.8	17.3	15.3	14.8	15.0	13.9	14.8	18.2	19.3	18.1	16.9	16.4	(36)	
	5% WB	MCWBR	5.8	6.2	5.6	6.1	6.6	6.6	7.0	8.2	8.1	7.2	6.2	5.9	(37)	
		MCWBR	13.1	14.0	12.0	10.2	10.8	10.3	9.7	13.4	14.5	15.7	13.8	13.9	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.403	0.400	0.395	0.381	0.366	0.355	0.340	0.353	0.380	0.399	0.398	0.412	(40)	
		taud	2.533	2.550	2.550	2.571	2.580	2.593	2.618	2.562	2.471	2.443	2.488	2.475	(41)	
	Ebn at Noon		299	297	291	284	277	274	283	288	291	293	298	296	(42)	
		Edh at Noon	36	35	33	31	29	27	27	30	36	38	37	37	(43)	
(44) All-Sky Solar Radiation	RadAvg		1905	1837	1665	1494	1308	1167	1292	1580	1924	2102	2146	2083	(44)	
	RadStd		149	209	159	149	124	120	104	135	117	143	189	225	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (6 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page