

SOUTH JOHNSTONE, Australia

WMO: 952920

Lat: 17.6053S

Lon: 145.9972E

Elev: 19

StdP: 101.10

Time Zone: 10.00 (E10)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.8	12.3	7.5	6.4	18.0	9.2	7.2	16.2	6.7	21.6	6.4	21.9	2.3	260	0.286

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	7.2	33.0	25.6	31.9	25.4	31.1	25.0	27.0	30.9	26.5	30.1	26.1	29.4	3.9	50

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
25.9	21.3	28.7	25.5	20.8	28.2	25.2	20.4	27.8	85.1	31.2	83.1	30.3	81.3	29.6	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7.3	6.3	5.6	8.9	35.9	1.3	1.6	7.9	37.1	7.1	38.0	6.4	38.9	5.4	40.0
			8.4	28.6	1.2	1.4	7.5	29.6	6.7	30.4	6.0	31.2	5.1	32.2
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	23.7	26.9	27.1	26.0	24.4	22.3	20.5	19.8	20.1	22.0	23.8	25.2	26.6
	DBStd	3.01	1.21	1.34	1.19	1.25	1.68	2.05	2.04	1.71	1.55	1.38	1.18	1.20
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	24	0	0	0	0	1	7	11	5	1	0	0	0
	CDD10.0	5000	523	478	497	431	381	316	303	314	359	427	457	514
	CDD18.3	1983	265	244	239	181	123	72	56	61	109	169	207	256
	CDH23.3	14366	2482	2284	1897	1039	428	139	81	196	598	1157	1657	2406
CDH26.7	3953	826	786	492	159	32	3	1	5	67	256	474	853	
Wind	WSAvg	2.5	2.3	2.1	2.5	2.8	2.6	2.5	2.6	2.5	2.4	2.7	2.6	2.4
Precipitation	PrecAvg	3205	521	571	584	365	336	154	107	79	69	80	134	203
	PrecMax	5308	2674	1492	1183	1024	866	366	538	312	335	313	650	978
	PrecMin	1670	0	0	0	0	0	8	1	6	0	0	18	0
	PrecStd	837	513	349	311	244	208	105	102	73	77	78	130	195
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	34.3	35.4	33.1	30.2	28.8	27.2	26.2	27.4	29.3	31.5	32.3	33.7
		MCWB	25.5	24.6	25.4	23.3	22.8	22.2	21.1	20.7	21.3	23.0	24.4	25.5
	2%	DB	32.4	33.2	31.3	29.3	27.6	25.8	25.1	26.2	28.2	30.0	30.8	32.2
		MCWB	25.9	25.8	25.2	23.3	22.1	21.3	20.3	19.9	21.1	23.2	24.1	25.4
	5%	DB	31.3	31.9	30.3	28.4	26.6	24.9	24.2	25.4	27.4	29.0	30.0	31.3
		MCWB	25.5	25.6	24.7	23.2	21.7	20.7	19.7	19.5	20.9	22.5	23.6	25.0
	10%	DB	30.4	30.8	29.4	27.5	25.7	24.0	23.3	24.4	26.6	28.2	29.2	30.5
		MCWB	25.2	25.5	24.5	23.0	21.6	20.3	19.4	19.3	20.6	22.0	23.2	24.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.4	27.6	27.0	25.8	24.6	23.4	22.7	22.7	24.2	25.2	27.0	27.5
		MCDB	31.4	31.6	30.6	28.1	27.0	25.3	24.3	24.8	27.0	29.6	30.6	31.3
	2%	WB	26.7	26.9	26.2	25.0	23.6	22.5	21.7	21.8	23.3	24.3	25.5	26.6
		MCDB	30.5	30.8	29.3	26.9	25.8	24.4	23.4	24.2	26.0	28.1	28.8	30.5
	5%	WB	26.3	26.5	25.8	24.4	22.9	21.9	21.2	21.0	22.5	23.6	24.7	26.1
		MCDB	29.7	30.0	28.6	26.4	25.1	23.8	23.0	23.5	25.4	27.2	28.0	29.7
	10%	WB	25.9	26.0	25.4	23.9	22.4	21.3	20.6	20.3	21.7	23.0	24.2	25.5
		MCDB	28.9	29.2	27.8	26.0	24.5	23.1	22.4	23.0	24.9	26.4	27.5	28.9
Mean Daily Temperature Range	5% DB	MDBR	7.0	7.2	6.4	6.3	6.7	6.7	7.3	8.7	9.3	8.8	8.1	7.8
		MCDBR	8.8	9.6	8.5	8.2	8.3	7.7	8.2	10.1	10.7	10.1	9.4	9.1
		MCWBR	3.2	3.4	3.1	3.4	3.7	3.7	3.9	4.5	4.5	4.0	3.4	3.3
	5% WB	MCDBR	7.3	7.8	6.7	5.7	6.0	5.7	5.4	7.4	8.0	8.7	7.7	7.7
		MCWBR	3.1	3.2	2.8	2.6	3.0	3.0	2.9	3.6	3.7	3.9	3.4	3.2
Clear-Sky Solar Irradiance	taub	0.403	0.400	0.395	0.381	0.366	0.355	0.340	0.353	0.380	0.399	0.398	0.412	
	taud	2.533	2.550	2.550	2.571	2.580	2.593	2.618	2.562	2.471	2.443	2.488	2.475	
	Ebn at Noon	942	935	918	895	873	865	891	908	917	924	941	934	
	Edh at Noon	112	109	105	97	90	85	85	96	112	120	116	118	
All-Sky Solar Radiation	RadAvg	6.01	5.79	5.25	4.71	4.12	3.68	4.07	4.98	6.06	6.63	6.76	6.57	
	RadStd	0.47	0.66	0.50	0.47	0.39	0.38	0.33	0.43	0.37	0.45	0.60	0.71	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (6 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page