

RABBIT FLAT, Australia

WMO: 953220

Lat: 20.1825S

Lon: 130.0147E

Elev: 342

StdP: 97.29

Time Zone: 9.50 (AUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	3.5	5.1	-16.0	1.0	24.8	-13.4	1.2	24.4	7.5	22.3	7.2	22.1	1.2	180	0.442

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	12.7	42.0	19.6	40.9	19.5	39.8	19.6	25.6	30.8	25.0	30.0	24.5	29.7	4.4	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
24.5	20.4	27.2	23.9	19.6	26.7	23.4	18.9	26.7	81.2	30.8	78.5	29.8	76.5	29.6	34.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9.0	7.7	6.9	0.5	43.8	1.4	1.2	-0.5	44.6	-1.3	45.3	-2.0	46.0	-3.0	46.9
			-1.3	29.1	1.2	2.8	-2.2	31.1	-2.9	32.7	-3.6	34.3	-4.4	36.4

DB
WB

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	25.2	31.2	30.4	29.3	26.1	20.7	16.9	16.7	18.7	24.1	27.6	30.0	31.1
	DBStd	6.14	2.49	2.36	2.32	2.83	3.06	3.30	3.10	3.54	3.62	3.08	2.54	2.62
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	190	0	0	0	0	13	67	69	38	3	0	0	0
	CDD10.0	5548	657	571	599	482	332	207	208	271	422	547	599	654
	CDD18.3	2697	398	338	341	232	86	24	19	51	174	289	349	396
	CDH23.3	39493	5817	4773	4657	3092	1156	397	499	1078	2714	4355	5139	5814
	CDH26.7	23514	3649	2914	2773	1763	463	106	127	435	1541	2759	3283	3700
(14) Wind	WSAvg	3.1	3.4	3.1	3.2	3.0	2.8	2.7	2.5	2.8	3.1	3.4	3.4	3.5
(15) Precipitation	PrecAvg	447	100	110	36	21	14	11	4	3	10	17	33	60
	PrecMax	847	324	408	264	139	89	86	63	34	112	80	101	208
	PrecMin	157	2	1	0	0	0	0	0	0	0	0	0	5
	PrecStd	183	86	102	55	36	22	24	12	8	22	22	29	53
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	42.8	42.1	41.1	38.4	34.4	32.1	31.4	34.9	38.2	41.1	41.8	43.9
		MCWB	21.5	19.3	19.7	20.0	17.8	17.1	15.3	16.5	17.0	17.8	18.7	19.0
	2%	DB	41.5	40.7	39.5	37.1	32.6	29.4	29.5	32.8	36.8	39.7	40.7	42.3
		MCWB	20.7	19.9	19.9	19.2	16.6	16.3	14.6	15.3	16.7	17.6	18.8	19.1
	5%	DB	40.0	39.4	38.1	36.0	31.1	27.5	28.1	31.1	35.6	38.7	39.7	40.7
		MCWB	20.9	20.0	20.0	18.6	16.0	15.0	13.9	15.2	16.6	17.5	18.7	19.6
	10%	DB	38.6	38.0	36.8	34.7	29.5	25.6	26.5	29.2	34.2	37.4	38.4	38.8
		MCWB	20.9	20.5	19.9	18.1	15.6	13.7	13.2	13.8	15.9	17.3	18.9	20.4
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.7	25.8	26.2	25.6	22.4	20.1	20.0	19.3	20.6	22.7	24.5	25.6
		MCDB	37.0	29.5	32.0	35.2	26.5	24.0	24.9	29.0	31.2	32.1	30.4	30.6
	2%	WB	25.7	25.1	25.0	23.0	20.9	17.9	17.1	17.6	19.2	21.6	23.3	24.7
		MCDB	30.9	29.3	30.0	29.0	26.1	26.5	26.4	28.3	31.5	29.4	30.4	30.2
	5%	WB	25.1	24.6	24.3	21.8	19.3	16.5	15.2	16.2	18.2	20.8	22.6	24.2
		MCDB	30.1	29.2	29.7	28.8	25.8	25.1	25.6	28.8	31.4	29.5	30.5	29.8
	10%	WB	24.5	24.2	23.6	20.4	17.7	15.0	13.8	14.7	17.1	20.0	22.0	23.7
		MCDB	29.6	29.2	29.4	29.9	25.1	23.7	24.7	28.1	31.0	29.6	30.6	29.9
(35) Mean Daily Temperature Range	5% DB	MDBR	12.7	13.0	13.7	16.1	16.0	16.6	18.2	19.2	18.5	17.6	15.2	13.4
		MCDBR	15.6	16.2	16.3	17.2	18.4	17.9	20.2	20.5	19.3	19.8	18.1	17.3
		MCWBR	4.4	4.5	4.6	5.6	6.8	7.5	9.0	8.6	7.0	6.6	5.4	4.8
	5% WB	MCDBR	10.8	10.0	11.3	13.5	11.7	14.9	16.2	16.8	15.0	13.4	12.8	11.3
		MCWBR	3.6	3.0	4.1	5.9	4.7	6.7	7.4	7.5	6.0	4.8	3.8	3.3
(40) Clear-Sky Solar Irradiance	taub		0.374	0.377	0.364	0.340	0.330	0.311	0.318	0.329	0.384	0.383	0.392	0.386
	taud		2.530	2.524	2.552	2.537	2.510	2.540	2.494	2.433	2.322	2.356	2.400	2.472
	Ebn at Noon		970	956	944	928	899	900	903	925	909	938	947	959
	Edh at Noon		112	111	104	98	93	87	93	107	129	130	127	119
(44) All-Sky Solar Radiation	RadAvg		7.17	7.03	6.44	5.95	4.98	4.62	4.90	5.89	6.72	7.24	7.33	7.11
	RadStd		0.46	0.48	0.54	0.31	0.44	0.27	0.34	0.19	0.32	0.46	0.45	0.42

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page