

LEINSTER, Australia

WMO: 954480

Lat: 27.8386S

Lon: 120.7031E

Elev: 1634

StdP: 13.85

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	38.1	40.4	11.2	10.3	77.6	14.9	12.4	76.4	21.5	62.4	19.7	62.8	4.2	70	0.494

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	23.0	106.4	64.7	103.8	64.7	100.9	64.2	73.9	84.0	72.3	84.7	70.6	85.1	11.2	330

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
71.8	125.1	76.8	69.1	113.7	76.6	66.5	103.8	75.7	38.8	83.4	37.2	83.9	35.6	84.7	97.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
21.2	18.9	17.4	DB	33.0	110.2	1.3	2.7	32.0	112.1	31.2	113.7	30.5	115.2	29.5	117.1	
			WB	29.9	75.8	1.7	2.4	28.7	77.5	27.8	78.9	26.8	80.2	25.6	82.0	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	70.3	85.8	83.2	77.7	71.3	61.9	55.6	54.4	58.2	64.1	71.9	77.4	82.7	(6)
(7)		DBStd	12.61	7.33	7.31	7.20	6.29	6.02	5.12	5.19	6.17	6.71	7.00	7.06	6.69	(7)
(8)		HDD50	26	0	0	0	0	0	7	15	4	0	0	0	0	(8)
(9)		HDD65	1118	1	0	3	16	136	284	331	226	98	20	2	1	(9)
(10)		CDD50	7434	1111	930	858	640	368	176	152	258	424	679	823	1015	(10)
(11)		CDD65	3053	647	511	396	205	39	3	3	16	72	234	376	551	(11)
(12)		CDH74	40178	9479	7033	4708	2018	354	23	32	232	998	2862	4771	7668	(12)
(13)		CDH80	22435	6013	4236	2443	819	77	1	2	37	345	1338	2565	4559	(13)
(14)	Wind	WSAvg	9.5	11.1	10.6	10.0	8.5	7.8	8.0	8.7	9.5	10.5	10.7	10.8	(14)	
(15)	Precipitation	PrecAvg	10.0	1.5	1.3	1.2	1.1	0.9	0.7	0.7	0.4	0.2	0.4	0.4	0.8	(15)
(16)		PrecMax	17.7	5.5	4.3	6.3	6.4	3.9	2.6	2.8	1.7	1.7	2.8	2.6	3.8	(16)
(17)		PrecMin	4.6	0.0	0.0	0.0	0.0	0.1	0.1	0.0	0.0	0.0	0.0	0.0	0.0	(17)
(18)		PrecStd	3.7	1.7	1.3	1.5	1.4	0.9	0.6	0.7	0.5	0.4	0.7	0.6	0.9	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	110.4	110.0	103.3	96.7	87.2	77.2	78.2	84.3	91.9	99.4	104.3	107.6	(19)
(20)		0.4%	MCWB	65.4	64.3	64.4	63.1	59.4	56.2	55.7	55.2	57.7	60.7	62.8	64.7	(20)
(21)		2%	DB	106.7	105.8	99.1	91.9	81.6	72.8	73.2	80.1	87.8	95.3	100.0	104.3	(21)
(22)		2%	MCWB	65.3	64.8	64.1	61.2	57.5	54.3	52.6	54.6	56.7	60.5	61.7	63.8	(22)
(23)		5%	DB	104.1	102.1	96.0	88.6	77.8	69.9	69.7	76.2	84.3	91.7	96.8	101.0	(23)
(24)		5%	MCWB	65.7	64.5	64.3	61.3	57.2	52.9	51.7	53.2	56.0	59.1	61.3	63.5	(24)
(25)		10%	DB	100.9	98.3	92.3	84.8	74.4	66.9	66.3	72.2	80.2	87.8	93.1	97.7	(25)
(26)		10%	MCWB	65.3	65.3	64.2	60.4	56.3	52.1	50.9	52.2	54.9	58.2	60.8	63.1	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	75.4	83.0	73.1	69.0	66.2	61.2	60.1	60.2	61.5	68.0	68.9	73.3	(27)
(28)		0.4%	MCDWB	83.5	83.1	79.8	82.7	71.7	66.4	69.1	70.5	76.8	82.4	81.7	86.0	(28)
(29)		2%	WB	73.6	74.4	70.8	66.5	62.5	58.7	56.8	57.6	59.4	63.9	66.4	70.7	(29)
(30)		2%	MCDWB	85.3	83.4	81.3	78.2	72.3	65.4	63.6	71.1	78.3	80.0	82.6	85.4	(30)
(31)		5%	WB	72.0	72.7	69.1	65.1	60.4	56.9	55.0	55.8	57.8	61.8	64.7	68.9	(31)
(32)		5%	MCDWB	87.1	83.7	82.4	76.9	71.3	65.1	63.3	70.3	77.9	81.0	84.4	85.5	(32)
(33)		10%	WB	70.1	70.9	67.5	63.7	58.5	54.7	53.2	54.0	56.3	60.0	63.3	66.7	(33)
(34)		10%	MCDWB	88.8	83.8	82.7	76.3	70.2	63.0	63.2	69.0	76.6	82.7	85.4	87.7	(34)
(35)	Mean Daily Temperature Range		MDBR	23.0	22.0	21.2	21.6	21.6	20.5	21.3	23.5	25.3	24.8	24.2	23.8	(35)
(36)		5% DB	MCDBR	26.7	27.1	25.8	26.5	24.7	23.9	26.0	27.9	30.8	29.9	27.9	27.1	(36)
(37)			MCWBR	7.4	7.7	7.8	8.7	9.6	11.1	12.0	12.2	12.0	10.9	9.3	8.4	(37)
(38)		5% WB	MCDWB	22.0	19.1	19.6	19.4	18.3	17.6	19.5	22.6	25.6	24.9	24.8	23.8	(38)
(39)			MCWBR	7.4	6.4	7.4	7.4	8.0	9.6	10.5	11.4	10.5	9.5	8.5	8.1	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.340	0.342	0.324	0.308	0.288	0.277	0.275	0.279	0.298	0.318	0.326	0.328	(40)	
(41)		taud	2.575	2.586	2.612	2.628	2.634	2.653	2.642	2.612	2.540	2.502	2.517	2.558	(41)	
(42)		Ebn at Noon	318	312	308	298	292	289	294	305	312	316	320	322	(42)	
(43)		Edh at Noon	34	33	30	27	24	23	23	27	32	35	36	35	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2474	2227	1929	1583	1294	1107	1210	1563	1990	2280	2507	2600	(44)	
(45)		RadStd	198	157	138	75	85	68	81	79	71	145	109	151	151	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page