

COOBER PEDY, Australia

WMO: 954580

Lat: 29.0347S

Lon: 134.7222E

Elev: 741

StdP: 14.31

Time Zone: 9.50 (AUA)

Period: 97-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	39.4	41.4	-4.9	4.3	87.2	3.7	6.8	84.1	29.0	62.2	26.4	63.1	9.0	30	0.600

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	24.3	107.5	66.0	104.4	65.0	101.5	64.5	73.8	85.9	71.5	88.3	69.7	87.9	13.2	10

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
70.9	117.0	77.4	67.3	103.0	77.0	64.2	92.2	76.4	38.0	84.2	35.7	87.7	34.2	87.5	81.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
28.6	25.4	23.0	35.2	111.6	1.1	2.4	34.3	113.3	33.7	114.7	33.0	116.1	32.2	117.8		
			31.4	75.6	1.9	2.8	30.0	77.6	28.9	79.2	27.8	80.8	26.4	82.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	69.6	85.3	83.1	77.1	69.8	61.2	54.5	54.5	57.7	64.9	70.7	76.7	80.9	(6)
(7)		DBStd	12.62	7.72	7.73	7.24	6.34	5.75	4.23	4.88	5.68	7.48	7.84	7.95	7.82	(7)
(8)		HDD50	16	0	0	0	0	0	6	8	2	0	0	0	0	(8)
(9)		HDD65	1189	0	0	3	24	151	315	327	240	95	30	4	0	(9)
(10)		CDD50	7180	1096	926	841	593	347	142	149	240	446	643	800	957	(10)
(11)		CDD65	2878	631	506	379	167	33	1	3	13	91	208	354	492	(11)
(12)		CDH74	38938	9518	7252	4657	1647	261	12	45	193	1176	2661	4653	6863	(12)
(13)		CDH80	22202	6124	4429	2433	630	56	0	5	47	499	1335	2568	4076	(13)
(14)	Wind	WSAvg	12.6	14.2	13.5	12.5	11.3	10.8	10.5	11.2	12.4	13.3	14.1	13.8	13.8	(14)
(15)	Precipitation	PrecAvg	6.8	0.7	0.8	0.3	0.3	0.6	0.7	0.4	0.4	0.5	0.7	0.5	0.8	(15)
(16)		PrecMax	16.8	6.0	4.7	1.9	1.7	3.4	3.6	2.0	2.0	1.7	4.1	3.3	3.1	(16)
(17)		PrecMin	1.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	(17)
(18)		PrecStd	3.8	1.3	1.2	0.4	0.5	0.8	0.9	0.5	0.5	0.6	0.9	0.6	0.9	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	111.9	109.6	104.1	95.5	85.5	75.6	79.5	85.8	96.3	101.5	107.3	110.0	(19)
(20)		MCWB	66.3	66.3	63.9	62.1	58.4	55.7	54.2	55.5	59.5	61.5	63.1	65.7	(20)	
(21)		2%	DB	107.9	105.7	99.6	90.8	80.7	70.5	73.6	79.2	90.8	97.4	101.7	105.1	(21)
(22)		MCWB	66.4	65.9	63.5	60.5	57.7	53.8	52.9	53.7	57.9	60.4	62.0	63.7	(22)	
(23)		5%	DB	104.8	102.4	96.0	87.0	76.4	66.9	69.2	74.5	85.9	92.9	97.6	101.3	(23)
(24)		MCWB	65.8	65.8	62.7	59.2	56.1	52.5	51.7	52.6	56.6	58.9	61.4	63.7	(24)	
(25)		10%	DB	101.5	99.0	92.2	83.2	72.5	63.9	65.2	70.4	80.9	87.8	93.3	97.5	(25)
(26)		MCWB	65.3	65.2	62.2	58.3	54.7	51.3	50.2	51.2	54.9	57.9	60.9	62.7	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	76.2	77.4	73.9	68.9	62.7	60.7	58.8	59.1	64.0	66.6	70.5	74.6	(27)
(28)		MCDWB	88.2	84.6	80.8	74.8	71.9	68.1	68.8	72.3	79.8	83.2	82.4	83.2	(28)	
(29)		2%	WB	72.5	74.9	71.3	66.0	60.7	57.6	55.1	56.5	61.0	64.1	67.8	71.1	(29)
(30)		MCDWB	90.2	85.2	83.4	74.2	71.3	63.6	66.7	72.8	80.7	83.3	82.8	84.5	(30)	
(31)		5%	WB	70.4	71.8	68.9	63.1	59.0	54.9	53.2	54.5	58.7	62.2	66.0	69.0	(31)
(32)		MCDWB	92.1	91.0	83.4	78.9	71.2	62.8	66.0	69.9	80.6	82.4	84.0	86.1	(32)	
(33)		10%	WB	68.6	69.5	65.9	61.1	56.9	53.0	51.5	52.7	56.6	60.1	63.9	66.7	(33)
(34)		MCDWB	92.7	89.2	86.4	78.3	69.2	61.6	62.8	67.6	76.7	81.8	84.8	88.2	(34)	
(35)	Mean Daily Temperature Range		MDBR	24.3	23.3	22.6	21.6	20.1	19.2	20.6	22.7	24.7	25.0	24.4	24.5	(35)
(36)		5% DB	MCDBR	26.7	25.9	26.3	26.0	23.7	22.8	26.1	28.1	31.4	31.9	28.9	28.3	(36)
(37)		MCWBR	8.8	8.5	9.2	10.0	10.3	11.6	12.5	12.8	12.7	12.2	10.0	10.2	(37)	
(38)		5% WB	MCDBR	22.3	19.8	19.2	19.2	18.9	17.8	21.8	23.8	26.4	24.6	23.5	23.4	(38)
(39)		MCWBR	8.5	7.7	8.4	9.2	9.6	10.2	11.5	11.8	11.9	10.9	10.0	9.7	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.362	0.356	0.335	0.322	0.300	0.285	0.289	0.302	0.337	0.347	0.359	0.348	(40)	
(41)		taud	2.424	2.471	2.501	2.522	2.550	2.579	2.553	2.494	2.398	2.385	2.396	2.452	(41)	
(42)		Ebn at Noon	311	307	304	292	285	283	286	294	298	306	309	316	(42)	
(43)		Edh at Noon	39	36	33	30	26	24	25	30	36	39	40	38	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2555	2342	2029	1577	1236	1064	1159	1489	1897	2205	2410	2534	(44)	
(45)		RadStd	113	142	118	80	83	58	56	62	87	144	108	97	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	+0.92	N/A	N/A	N/A	N/A	N/A	N/A	-97	+351	+243	(46)
(47)	Regional (2 neighbors)	+0.76	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+297	+200	(47)

Nomenclature: See separate page