

COOBER PEDY, Australia

WMO: 954580

Lat: 29.0347S

Lon: 134.7222E

Elev: 226

StdP: 98.64

Time Zone: 9.50 (AUA)

Period: 97-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	4.1	5.2	-20.5	0.6	30.6	-15.7	1.0	28.9	13.0	16.8	11.8	17.3	4.0	30	0.600

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	13.5	41.9	18.9	40.2	18.3	38.6	18.0	23.2	30.0	21.9	31.3	21.0	31.1	5.9	10

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
21.6	16.7	25.2	19.6	14.7	25.0	17.9	13.2	24.7	70.4	29.0	65.2	30.9	61.7	30.8	27.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.8	11.4	10.3	DB	1.8	44.2	0.6	1.3	1.3	45.2	0.9	46.0	0.6	46.7	0.1	47.7	(4)
(5)			WB	-0.3	24.2	1.1	1.6	-1.1	25.3	-1.7	26.2	-2.3	27.1	-3.1	28.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	20.9	29.6	28.4	25.1	21.0	16.2	12.5	12.5	14.3	18.3	21.5	24.8	27.1	(6)
(7)		DBStd	7.01	4.29	4.30	4.02	3.52	3.19	2.35	2.71	3.16	4.15	4.36	4.42	4.34	(7)
(8)		HDD10.0	9	0	0	0	0	0	3	4	1	0	0	0	0	(8)
(9)		HDD18.3	661	0	0	2	13	84	175	182	133	53	17	2	0	(9)
(10)		CDD10.0	3989	609	514	467	329	193	79	83	133	248	357	444	532	(10)
(11)		CDD18.3	1599	351	281	211	93	18	1	2	7	51	116	197	273	(11)
(12)		CDH23.3	21632	5288	4029	2587	915	145	7	25	107	653	1478	2585	3813	(12)
(13)	CDH26.7	12334	3402	2461	1352	350	31	0	3	26	277	742	1427	2264	(13)	
(14)	Wind	WSAvg	5.6	6.4	6.1	5.6	5.0	4.8	4.7	5.0	5.5	5.9	6.3	6.1	6.2	(14)
(15)	Precipitation	PrecAvg	173	19	21	7	8	14	17	10	10	12	17	13	20	(15)
(16)		PrecMax	427	153	120	47	42	87	91	51	50	44	104	84	79	(16)
(17)		PrecMin	38	0	0	0	0	0	0	0	0	0	0	0	0	(17)
(18)		PrecStd	96	34	30	11	12	20	22	13	13	14	23	16	22	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	44.4	43.1	40.1	35.3	29.7	24.2	26.4	29.9	35.7	38.6	41.8	43.3	(19)
(20)			MCWB	19.0	19.1	17.7	16.7	14.7	13.1	12.3	13.0	15.3	16.4	17.3	18.7	(20)
(21)		2%	DB	42.2	40.9	37.5	32.7	27.1	21.4	23.1	26.2	32.7	36.3	38.7	40.6	(21)
(22)			MCWB	19.1	18.8	17.5	15.8	14.3	12.1	11.6	12.0	14.4	15.8	16.7	17.6	(22)
(23)		5%	DB	40.4	39.1	35.6	30.6	24.6	19.4	20.7	23.6	29.9	33.8	36.4	38.5	(23)
(24)			MCWB	18.8	18.8	17.1	15.1	13.4	11.4	10.9	11.5	13.7	15.0	16.3	17.6	(24)
(25)		10%	DB	38.6	37.2	33.4	28.5	22.5	17.7	18.4	21.3	27.2	31.0	34.0	36.4	(25)
(26)			MCWB	18.5	18.4	16.8	14.6	12.6	10.7	10.1	10.6	12.7	14.4	16.1	17.1	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	24.5	25.2	23.3	20.5	17.0	16.0	14.9	15.1	17.8	19.2	21.4	23.7	(27)
(28)			MCDWB	31.2	29.2	27.1	23.8	22.2	20.0	20.5	22.4	26.5	28.5	28.0	28.5	(28)
(29)		2%	WB	22.5	23.8	21.8	18.9	16.0	14.2	12.8	13.6	16.1	17.8	19.9	21.7	(29)
(30)			MCDWB	32.3	29.6	28.6	23.5	21.8	17.6	19.3	22.6	27.1	28.5	28.2	29.2	(30)
(31)		5%	WB	21.3	22.1	20.5	17.3	15.0	12.7	11.8	12.5	14.8	16.8	18.9	20.6	(31)
(32)			MCDWB	33.4	32.8	28.5	26.1	21.8	17.1	18.9	21.1	27.0	28.0	28.9	30.0	(32)
(33)		10%	WB	20.3	20.8	18.9	16.2	13.8	11.6	10.9	11.5	13.7	15.6	17.7	19.3	(33)
(34)			MCDWB	33.7	31.8	30.2	25.7	20.6	16.4	17.1	19.8	24.8	27.7	29.3	31.2	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	13.5	12.9	12.5	12.0	11.1	10.6	11.5	12.6	13.7	13.9	13.5	13.6	(35)
(36)			MCDBR	14.9	14.4	14.6	14.4	13.2	12.7	14.5	15.6	17.4	17.7	16.1	15.7	(36)
(37)			MCWBR	4.9	4.7	5.1	5.6	5.7	6.5	6.9	7.1	7.0	6.8	5.6	5.7	(37)
(38)		5% WB	MCDWB	12.4	11.0	10.6	10.7	10.5	9.9	12.1	13.2	14.7	13.6	13.1	13.0	(38)
(39)			MCWBR	4.7	4.3	4.6	5.1	5.3	5.7	6.4	6.5	6.6	6.1	5.6	5.4	(39)
(40)	Clear-Sky Solar Irradiance	taub		0.362	0.356	0.335	0.322	0.300	0.285	0.289	0.302	0.337	0.347	0.359	0.348	(40)
(41)		taud		2.424	2.471	2.501	2.522	2.550	2.579	2.553	2.494	2.398	2.385	2.396	2.452	(41)
(42)		Ebn at Noon		979	968	957	920	897	891	901	928	938	965	975	995	(42)
(43)		Edh at Noon		124	115	105	93	81	75	80	94	115	124	127	121	(43)
(44)	All-Sky Solar Radiation	RadAvg		8.05	7.38	6.39	4.97	3.90	3.35	3.65	4.69	5.98	6.95	7.60	7.99	(44)
(45)		RadStd		0.36	0.45	0.37	0.25	0.26	0.18	0.18	0.20	0.27	0.46	0.34	0.30	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.51	N/A	N/A	N/A	N/A	N/A	N/A	-54	+195	+135
(47)	Regional (2 neighbors)	+0.42	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+165	+111

Nomenclature: See separate page