

MOOMBA, Australia

WMO: 954810

Lat: 28.0997S

Lon: 140.1956E

Elev: 126

StdP: 14.63

Time Zone: 9.50 (AUA)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	39.4	41.6	10.1	9.3	75.8	13.9	11.2	74.6	24.7	67.9	21.7	65.1	6.1	190	0.533

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	23.6	109.3	69.0	106.7	68.1	104.1	67.5	76.7	89.0	74.6	89.7	72.8	91.0	11.2	350

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
73.8	126.4	81.6	70.6	113.2	81.1	67.6	101.8	80.9	40.3	89.4	38.3	88.7	36.6	90.5	92.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 25.0	21.8	19.6	DB	35.2	112.7	2.0	2.5	33.8	114.5	32.6	116.0	31.5	117.4	30.0	119.2	(4)
(5)			WB	31.2	83.3	2.2	6.6	29.7	88.1	28.4	92.0	27.2	95.7	25.6	100.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	72.4	89.1	86.7	80.9	72.3	63.1	56.7	55.6	58.7	66.7	74.0	79.9	85.5	(6)	
	DBStd	13.25	6.33	6.69	6.52	6.28	5.71	5.23	4.80	5.62	7.08	7.39	7.34	6.75	(7)	
	HDD50	8	0	0	0	0	0	3	4	1	0	0	0	0	(8)	
	HDD65	958	0	0	0	12	108	257	295	212	63	10	1	0	(9)	
	CDD50	8170	1213	1027	957	670	406	204	178	272	500	744	898	1101	(10)	
	CDD65	3643	748	607	492	232	48	8	4	18	112	289	449	636	(11)	
	CDH74	52496	11910	9189	6491	2521	467	70	73	282	1532	3881	6304	9776	(12)	
	CDH80	31494	7989	5882	3669	1072	99	7	9	70	669	2053	3698	6277	(13)	
(14) Wind	WSAvg	10.5	11.9	11.8	11.4	10.2	9.3	9.0	8.7	9.5	10.3	11.1	11.3	11.5	(14)	
(15) Precipitation	PrecAvg	6.9	1.1	1.0	0.2	0.5	0.6	0.4	0.7	0.4	0.4	0.7	0.5	0.4	(15)	
	PrecMax	13.6	7.1	6.4	1.3	4.3	3.4	1.7	3.5	1.7	4.4	3.1	1.5	3.9	(16)	
	PrecMin	1.8	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	(17)	
	PrecStd	3.5	1.6	1.5	0.3	0.9	0.9	0.5	0.9	0.4	0.8	0.8	0.4	0.7	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	113.5	110.6	106.0	96.4	86.2	80.5	80.7	87.1	97.6	103.0	109.5	111.0	(19)	
		MCWB	69.6	70.5	68.4	66.1	61.1	60.1	58.1	59.3	61.6	64.9	66.8	67.6	(20)	
	2%	DB	110.3	107.3	101.5	93.3	82.8	75.5	75.4	80.9	92.4	99.1	104.8	107.5	(21)	
		MCWB	69.7	69.3	67.2	64.1	59.8	57.8	55.4	56.4	59.9	63.2	65.4	66.7	(22)	
	5%	DB	106.9	104.5	98.7	89.9	79.4	71.3	71.2	76.5	87.8	95.5	100.6	104.5	(23)	
		MCWB	68.9	68.6	66.8	62.6	59.0	55.8	53.5	54.4	58.0	62.2	64.4	66.5	(24)	
	10%	DB	104.0	101.3	95.5	86.5	75.6	67.7	67.3	72.2	82.9	91.2	96.5	101.2	(25)	
		MCWB	68.3	68.0	65.4	61.7	57.3	53.8	52.2	52.7	56.8	60.9	63.6	65.7	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	80.3	78.8	76.7	71.8	67.7	63.8	63.8	62.8	66.9	70.8	73.7	78.7	(27)	
		MCDB	87.5	90.5	82.6	81.3	73.6	71.4	71.1	74.9	75.4	87.4	89.7	89.5	(28)	
	2%	WB	76.4	76.4	73.7	68.7	63.5	61.1	58.2	58.9	63.9	67.3	71.0	73.6	(29)	
		MCDB	91.8	89.0	86.7	82.3	74.2	70.0	68.5	76.4	79.3	85.4	87.4	90.8	(30)	
	5%	WB	74.2	74.5	71.5	66.2	61.1	58.4	55.6	56.2	61.4	65.1	69.2	71.6	(31)	
		MCDB	91.5	90.2	87.7	83.2	74.1	67.1	67.5	72.7	82.0	86.2	86.5	90.5	(32)	
	10%	WB	72.4	72.5	69.2	63.7	59.0	55.9	53.5	53.9	58.9	62.9	67.1	69.7	(33)	
		MCDB	93.5	92.0	88.4	83.0	73.6	66.0	65.3	70.0	79.3	86.0	87.2	91.7	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	23.6	22.6	22.8	23.3	22.1	21.0	22.9	24.8	25.9	25.9	24.8	24.4	(35)	
		MCDBR	27.2	26.2	26.7	26.8	26.1	24.8	28.3	30.2	32.6	31.7	30.5	28.5	(36)	
	5% WB	MCWBR	9.6	9.6	10.6	11.6	12.2	12.6	14.5	14.6	14.2	13.7	12.0	11.2	(37)	
		MCWBR	21.3	19.5	20.6	21.8	21.2	19.5	23.4	25.4	25.1	25.1	23.4	21.7	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.372	0.366	0.344	0.327	0.308	0.297	0.300	0.316	0.365	0.362	0.373	0.370	(40)	
		taud	2.359	2.398	2.433	2.450	2.465	2.486	2.461	2.396	2.264	2.296	2.317	2.344	(41)	
	Ebn at Noon		307	304	301	291	282	278	282	290	289	302	305	309	(42)	
		Edh at Noon	42	39	36	32	28	26	28	33	42	43	43	43	(43)	
(44) All-Sky Solar Radiation	RadAvg		2564	2376	2074	1676	1308	1126	1225	1538	1924	2282	2435	2542	(44)	
	RadStd		100	155	123	77	61	64	53	71	107	122	134	132	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(46)
		N/A	N/A	N/A	+1.80	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (1 neighbor)	N/A	N/A	N/A	+1.80	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page