

BIRDSVILLE, Australia

WMO: 954820

Lat: 25.8975S

Lon: 139.3472E

Elev: 47

StdP: 100.76

Time Zone: 10.00 (E10)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	4.8	6.0	-13.8	1.1	24.8	-11.1	1.5	22.8	11.6	21.2	9.8	20.5	2.5	180	0.498

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	12.9	43.4	21.0	42.2	20.7	40.9	20.4	26.1	33.1	24.9	32.6	24.0	32.5	5.0	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
24.5	19.6	28.8	23.0	17.8	28.6	21.5	16.2	28.6	81.4	33.0	76.3	32.5	72.3	32.4	37.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.9	10.2	9.1	2.4	46.0	1.1	1.3	1.6	46.9	1.0	47.7	0.4	48.4	-0.4	49.3		
(5)			-0.1	29.8	1.1	4.6	-0.9	33.1	-1.5	35.8	-2.1	38.3	-2.9	41.7	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	23.9	33.1	31.4	28.7	24.2	18.6	15.0	14.5	16.5	21.1	25.0	28.3	31.3	(6)	(7)
	DBStd	7.36	3.35	3.22	3.56	3.54	3.37	3.18	2.95	3.65	4.13	4.16	3.93	3.63	(7)	(8)
	HDD10.0	1	0	0	0	0	0	1	1	0	0	0	0	0	(8)	(9)
	HDD18.3	377	0	0	0	2	39	111	124	81	17	2	0	0	(9)	(10)
	CDD10.0	5085	715	598	581	425	265	150	142	202	334	465	549	659	(10)	(11)
	CDD18.3	2419	457	365	322	177	46	11	6	25	101	209	299	401	(11)	(12)
	CDH23.3	36056	7561	5663	4524	2096	483	108	109	394	1396	2917	4409	6397	(12)	(13)
	CDH26.7	22322	5258	3693	2687	1028	136	22	17	135	685	1651	2726	4284	(13)	(14)
(14) Wind	WSAvg	4.5	5.1	4.9	4.8	4.1	3.8	3.7	3.7	4.1	4.5	5.0	5.1	5.3	(14)	(15)
(15) Precipitation	PrecAvg	172	31	28	12	11	14	9	13	9	4	13	12	17	(15)	(16)
	PrecMax	496	263	126	133	87	99	49	108	57	24	66	48	102	(16)	(17)
	PrecMin	33	0	0	0	0	0	0	0	0	0	0	0	0	(17)	(18)
	PrecStd	88	52	37	25	20	20	12	21	13	5	16	13	23	(18)	(19)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	45.3	43.8	42.2	37.4	31.9	29.4	28.8	33.8	38.8	41.1	43.8	44.9	(19)	(20)
		MCWB	21.6	21.6	20.8	18.8	16.8	17.2	14.3	16.8	17.1	18.7	20.3	20.4	(20)	(21)
	2%	DB	43.7	42.0	39.8	35.5	29.9	26.8	26.2	30.2	35.8	38.8	41.5	43.0	(21)	(22)
		MCWB	21.7	21.1	20.6	18.4	16.3	15.7	13.8	15.2	16.8	18.3	19.3	20.1	(22)	(23)
	5%	DB	42.2	40.5	38.1	34.0	28.1	24.1	24.0	27.7	33.3	36.9	39.4	41.3	(23)	(24)
		MCWB	21.5	20.9	20.2	17.7	15.7	14.3	13.1	13.9	15.9	17.5	18.9	20.1	(24)	(25)
	10%	DB	40.7	38.9	36.6	32.2	26.2	21.8	21.8	25.1	30.9	34.8	37.3	39.8	(25)	(26)
		MCWB	20.9	20.9	19.7	17.3	14.9	13.0	12.2	12.8	14.9	16.9	18.4	19.9	(26)	(27)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.1	27.4	25.8	23.7	20.4	18.5	18.2	18.4	21.2	23.0	25.7	31.3	(27)	(28)
		MCDB	33.1	32.4	33.2	28.9	25.6	26.3	22.6	29.4	29.2	30.4	33.8	35.6	(28)	(29)
	2%	WB	25.6	25.7	24.5	21.9	18.5	17.0	15.9	16.6	19.0	20.7	22.8	25.2	(29)	(30)
		MCDB	33.3	33.1	30.7	27.9	25.4	23.6	22.0	26.2	28.2	31.2	30.8	32.2	(30)	(31)
	5%	WB	24.4	24.7	23.5	20.2	17.3	15.7	14.3	15.0	17.6	19.2	21.5	23.3	(31)	(32)
		MCDB	33.5	32.7	31.2	29.3	25.0	21.7	21.9	25.2	29.2	31.7	31.6	32.7	(32)	(33)
	10%	WB	23.5	23.8	22.2	18.9	16.1	14.3	12.9	13.6	16.2	18.1	20.6	22.2	(33)	(34)
		MCDB	34.1	33.1	31.5	29.1	23.8	20.3	20.5	23.8	28.4	31.8	31.7	33.4	(34)	(35)
(35) Mean Daily Temperature Range	5% DB	MDBR	12.9	12.5	12.8	13.6	13.0	12.5	13.6	14.9	15.4	15.1	14.3	13.8	(35)	(36)
		MCDBR	13.9	14.5	14.5	15.1	14.7	14.8	16.4	17.8	18.7	17.6	16.9	15.8	(36)	(37)
	5% WB	MCWBR	5.2	5.7	5.8	6.3	6.7	7.3	8.3	8.5	8.4	7.8	6.9	6.3	(37)	(38)
		MCWBR	11.3	10.5	10.9	11.8	12.3	11.8	13.6	15.0	14.8	14.1	13.1	12.4	(38)	(39)
(39) Clear-Sky Solar Irradiance	taub		0.387	0.381	0.359	0.337	0.319	0.306	0.306	0.325	0.374	0.378	0.388	0.390	(39)	(40)
		taud	2.348	2.375	2.406	2.430	2.442	2.465	2.445	2.372	2.249	2.258	2.288	2.311	(40)	(41)
	Ebn at Noon		956	947	938	912	886	878	891	912	908	938	949	955	(41)	(42)
		Edh at Noon	134	128	118	105	94	87	92	109	135	142	142	140	(42)	(43)
(43) All-Sky Solar Radiation	RadAvg		7.93	7.50	6.63	5.55	4.38	3.82	4.17	5.18	6.24	7.30	7.71	7.88	(43)	(44)
	RadStd		0.39	0.44	0.39	0.31	0.25	0.23	0.21	0.23	0.37	0.38	0.39	0.43	(44)	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		N/A	N/A	N/A	+1.23	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page