

THARGOMINDAH, Australia

WMO: 954920

Lat: 27.9867S

Lon: 143.8150E

Elev: 431

StdP: 14.47

Time Zone: 10.00 (E10)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	38.7	41.0	9.0	8.8	81.5	13.4	11.0	77.5	20.1	69.1	18.1	65.9	4.1	170	0.473

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	21.3	107.8	67.0	105.2	66.9	102.7	66.5	75.6	87.1	74.0	86.5	72.6	86.6	10.6	330

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
73.2	125.1	79.7	70.8	115.5	79.4	68.3	105.5	79.2	39.5	85.5	37.9	86.2	36.6	86.1	95.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
22.0	18.9	16.7	DB	34.4	112.0	2.2	2.9	32.8	114.1	31.6	115.8	30.3	117.4	28.8	119.6	
			WB	31.1	83.1	1.9	7.2	29.8	88.3	28.7	92.5	27.7	96.5	26.3	101.8	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	73.1	89.1	86.4	82.0	73.9	63.6	57.0	56.0	59.5	67.5	75.2	81.4	86.2	(6)
	DBStd	13.19	5.69	6.62	6.15	5.97	5.95	5.43	5.12	6.16	6.89	7.14	6.99	6.55	(7)
	HDD50	9	0	0	0	0	0	4	4	1	0	0	0	0	(8)
	HDD65	891	0	0	0	6	101	249	283	194	51	7	0	0	(9)
	CDD50	8435	1211	1020	993	716	421	213	191	296	526	782	943	1123	(10)
	CDD65	3842	746	600	528	273	56	7	5	25	127	324	493	658	(11)
	CDH74	53572	11642	8740	6900	2890	497	49	66	397	1681	4190	6676	9844	(12)
	CDH80	31282	7628	5436	3822	1189	84	2	4	111	720	2166	3885	6235	(13)
(14) Wind	WSAvg	8.8	10.2	9.4	9.0	8.0	7.4	7.2	7.2	8.0	8.7	9.9	10.2	10.3	(14)
(15) Precipitation	PrecAvg	12.4	2.1	1.4	1.3	0.9	1.0	0.7	0.7	0.6	0.5	0.7	1.3	1.0	(15)
	PrecMax	29.2	15.6	7.6	6.5	6.1	3.6	4.5	4.3	2.3	3.0	2.1	7.4	5.9	(16)
	PrecMin	2.7	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	(17)
	PrecStd	5.9	3.0	1.8	1.5	1.3	1.1	0.9	1.0	0.6	0.7	0.6	1.6	1.3	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	111.0	110.4	105.3	96.3	86.1	79.0	79.8	89.5	97.1	101.6	108.7	109.9	(19)
		MCWB	68.1	70.9	67.3	65.4	61.0	59.1	56.1	58.8	61.2	63.9	66.1	67.0	(20)
	2%	DB	107.6	106.2	101.3	92.5	82.3	74.9	75.4	82.6	92.0	97.9	103.9	106.4	(21)
		MCWB	67.1	69.2	66.5	63.2	59.7	57.5	55.4	56.1	59.0	62.4	64.7	65.8	(22)
	5%	DB	104.9	103.1	98.1	89.8	79.6	71.6	72.0	78.2	87.9	94.9	100.1	103.2	(23)
		MCWB	67.2	68.0	65.4	62.6	58.7	56.4	54.0	54.3	57.5	61.8	64.0	65.4	(24)
	10%	DB	102.0	100.1	95.2	87.0	76.5	68.2	68.5	74.1	83.9	91.6	96.5	100.4	(25)
		MCWB	67.7	67.4	65.1	61.6	57.6	54.2	52.8	53.0	56.7	61.2	62.9	64.9	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	80.3	82.2	74.8	71.7	67.2	63.6	66.0	62.2	66.5	70.6	72.4	75.5	(27)
		MCDB	90.0	84.8	81.9	82.3	73.7	71.1	71.1	74.4	76.1	82.4	83.9	87.0	(28)
	2%	WB	75.8	75.5	73.0	68.6	63.9	61.2	60.2	59.0	63.0	67.4	70.0	72.9	(29)
		MCDB	87.3	88.1	81.6	82.3	74.9	69.0	67.1	75.3	78.8	83.1	84.5	86.5	(30)
	5%	WB	74.2	73.9	71.3	65.9	61.1	58.8	57.2	56.2	60.9	65.2	68.6	70.9	(31)
		MCDB	87.2	87.7	85.2	82.3	75.0	66.8	66.8	75.4	81.0	85.5	84.7	86.4	(32)
	10%	WB	72.4	72.4	69.5	63.9	59.1	56.6	54.1	54.1	58.7	63.0	67.2	69.2	(33)
		MCDB	88.1	87.7	87.0	81.2	73.8	65.9	66.4	71.5	79.4	85.6	85.2	87.9	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	21.3	20.4	20.9	22.2	22.2	20.6	23.1	25.4	25.3	25.2	23.0	22.3	(35)
		MCDBR	24.4	23.5	24.2	24.5	24.3	23.3	27.8	30.4	32.0	29.4	27.5	25.3	(36)
		MCWBR	8.9	7.6	8.6	8.9	10.2	11.0	13.4	13.7	13.1	11.8	10.1	10.1	(37)
	5% WB	MCDBR	18.5	17.7	18.3	19.9	20.5	17.6	19.3	24.9	23.9	23.1	20.7	19.7	(38)
(40) Clear-Sky Solar Irradiance	taub	taub	0.358	0.354	0.336	0.318	0.301	0.290	0.291	0.306	0.352	0.348	0.363	0.354	(40)
		taud	2.486	2.513	2.546	2.554	2.552	2.582	2.553	2.489	2.365	2.399	2.414	2.461	(41)
		Ebn at Noon	312	308	304	295	286	282	287	294	294	306	308	314	(42)
	Edh at Noon		37	35	32	29	26	24	26	30	38	39	40	38	(43)
(44) All-Sky Solar Radiation	RadAvg		2470	2285	2002	1667	1295	1093	1210	1531	1912	2258	2382	2494	(44)
	RadStd		110	159	122	87	60	64	74	71	111	127	172	137	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page