

THARGOMINDAH, Australia

WMO: 954920

Lat: 27.9867S

Lon: 143.8150E

Elev: 131

StdP: 99.76

Time Zone: 10.00 (E10)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	3.7	5.0	-12.8	1.3	27.5	-10.4	1.6	25.3	9.0	20.6	8.1	18.8	1.8	170	0.473

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	11.8	42.1	19.4	40.7	19.4	39.3	19.2	24.2	30.6	23.3	30.3	22.6	30.3	4.7	330

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
22.9	17.9	26.5	21.6	16.5	26.3	20.1	15.1	26.2	74.0	29.7	70.3	30.1	67.2	30.0	35.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.8	8.5	7.5	1.3	44.5	1.2	1.6	0.5	45.6	-0.2	46.6	-0.9	47.5	-1.8	48.6		
(5)			-0.5	28.4	1.0	4.0	-1.2	31.3	-1.8	33.6	-2.4	35.9	-3.2	38.8	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	22.8	31.7	30.2	27.8	23.3	17.5	13.9	13.3	15.3	19.7	24.0	27.5	30.1	(6)	(7)
	DBStd	7.33	3.16	3.68	3.42	3.32	3.31	3.02	2.84	3.42	3.83	3.97	3.88	3.64	(7)	(8)
	HDD10.0	5	0	0	0	0	0	2	2	1	0	0	0	0	(8)	(9)
	HDD18.3	495	0	0	0	3	56	138	157	108	28	4	0	0	(9)	(10)
	CDD10.0	4686	673	567	552	398	234	118	106	164	292	434	524	624	(10)	(11)
	CDD18.3	2134	414	333	293	152	31	4	3	14	71	180	274	366	(11)	(12)
	CDH23.3	29762	6468	4856	3833	1606	276	27	37	221	934	2328	3709	5469	(12)	(13)
	CDH26.7	17379	4238	3020	2123	661	47	1	2	62	400	1203	2158	3464	(13)	(14)
(14) Wind	WSAvg	3.9	4.6	4.2	4.0	3.6	3.3	3.2	3.2	3.6	3.9	4.4	4.5	4.6	(14)	(15)
(15) Precipitation	PrecAvg	316	53	35	32	22	26	17	19	16	13	17	33	26	(15)	(16)
	PrecMax	741	396	194	164	155	92	115	110	58	76	53	189	151	(16)	(17)
	PrecMin	68	0	0	0	0	0	0	0	0	0	0	0	0	(17)	(18)
	PrecStd	151	75	46	39	33	28	23	26	14	17	15	41	34	(18)	(19)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	43.9	43.5	40.7	35.7	30.0	26.1	26.6	31.9	36.1	38.7	42.6	43.3	(19)	(20)
		MCWB	20.1	21.6	19.6	18.5	16.1	15.0	13.4	14.9	16.2	17.7	19.0	19.4	(20)	(21)
	2%	DB	42.0	41.2	38.5	33.6	27.9	23.8	24.1	28.1	33.4	36.6	39.9	41.3	(21)	(22)
		MCWB	19.5	20.7	19.2	17.3	15.4	14.2	13.0	13.4	15.0	16.9	18.2	18.8	(22)	(23)
	5%	DB	40.5	39.5	36.7	32.1	26.4	22.0	22.2	25.7	31.0	34.9	37.9	39.5	(23)	(24)
		MCWB	19.6	20.0	18.6	17.0	14.8	13.6	12.2	12.4	14.2	16.6	17.8	18.6	(24)	(25)
	10%	DB	38.9	37.8	35.1	30.6	24.7	20.1	20.3	23.4	28.9	33.1	35.8	38.0	(25)	(26)
		MCWB	19.8	19.7	18.4	16.4	14.2	12.3	11.5	11.6	13.7	16.2	17.2	18.3	(26)	(27)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.9	27.9	23.8	22.0	19.5	17.6	18.9	16.8	19.2	21.4	22.5	24.1	(27)	(28)
		MCDB	32.2	29.3	27.7	27.9	23.2	21.7	21.7	23.6	24.5	28.0	28.9	30.5	(28)	(29)
	2%	WB	24.4	24.2	22.8	20.3	17.7	16.2	15.6	15.0	17.2	19.7	21.1	22.7	(29)	(30)
		MCDB	30.7	31.2	27.6	27.9	23.8	20.5	19.5	24.1	26.0	28.4	29.2	30.3	(30)	(31)
	5%	WB	23.4	23.3	21.8	18.8	16.2	14.9	14.0	13.5	16.1	18.4	20.3	21.6	(31)	(32)
		MCDB	30.7	31.0	29.6	28.0	23.9	19.3	19.3	24.1	27.2	29.7	29.3	30.2	(32)	(33)
	10%	WB	22.4	22.5	20.8	17.7	15.1	13.7	12.3	12.3	14.8	17.2	19.6	20.7	(33)	(34)
		MCDB	31.2	30.9	30.6	27.3	23.2	18.9	19.1	22.0	26.3	29.8	29.6	31.0	(34)	(35)
(35) Mean Daily Temperature Range	5% DB	MDBR	11.8	11.3	11.6	12.4	12.4	11.4	12.8	14.1	14.0	14.0	12.8	12.4	(35)	(36)
		MCDBR	13.5	13.0	13.5	13.6	13.5	12.9	15.4	16.9	17.8	16.3	15.3	14.1	(36)	(37)
	5% WB	MCWBR	4.9	4.2	4.8	4.9	5.7	6.1	7.5	7.6	7.3	6.6	5.6	5.6	(37)	(38)
		MCWBR	10.3	9.8	10.2	11.0	11.4	9.8	10.7	13.8	13.3	12.8	11.5	10.9	(38)	(39)
(39) Clear-Sky Solar Irradiance	taub		0.358	0.354	0.336	0.318	0.301	0.290	0.291	0.306	0.352	0.348	0.363	0.354	(39)	(40)
		taud	2.486	2.513	2.546	2.554	2.552	2.582	2.553	2.489	2.365	2.399	2.414	2.461	(40)	(41)
	Ebn at Noon		983	970	958	929	901	890	904	928	926	965	972	989	(41)	(42)
		Edh at Noon	117	111	101	91	82	76	81	95	119	123	125	120	(42)	(43)
(43) All-Sky Solar Radiation	RadAvg		7.79	7.20	6.31	5.25	4.08	3.44	3.82	4.83	6.03	7.12	7.51	7.86	(43)	(44)
	RadStd		0.35	0.50	0.38	0.27	0.19	0.20	0.23	0.23	0.35	0.40	0.54	0.43	(44)	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page