

MOREE, Australia

WMO: 955270

Lat: 29.4897S

Lon: 149.8472E

Elev: 717

StdP: 14.32

Time Zone: 10.00 (AUS)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	33.5	35.9	16.0	12.7	68.6	20.3	15.6	65.7	23.8	58.7	21.1	58.6	4.9	90	0.478

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	22.9	100.7	67.4	97.4	67.1	94.4	66.6	73.7	86.2	72.5	85.0	71.3	83.9	11.6	350

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
70.9	117.0	76.5	69.2	110.4	76.1	67.8	104.8	75.9	37.8	85.9	36.6	84.7	35.6	83.8	96.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 22.4	20.1	18.2	29.2	106.0	2.0	4.2	27.7	109.0	26.6	111.5	25.5	113.8	24.1	116.9		
(5)			28.2	77.5	2.4	4.8	26.4	80.9	25.0	83.8	23.7	86.5	21.9	90.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	67.0	80.6	79.0	75.1	67.9	59.6	54.1	52.3	54.7	61.5	68.4	73.8	78.0
	DBStd	11.41	5.40	5.37	4.79	5.13	5.38	5.07	4.91	5.56	6.25	6.47	6.66	5.96
	HDD50	67	0	0	0	0	2	18	31	15	1	0	0	0
	HDD65	1445	0	0	1	30	180	326	396	323	141	40	7	1
	CDD50	6281	949	812	779	536	299	142	101	162	346	571	715	869
	CDD65	2185	484	392	316	116	12	0	1	5	36	146	272	405
	CDH74	24622	5757	4358	3094	1123	132	3	6	68	554	1691	3079	4757
	CDH80	11512	3067	2166	1286	270	7	0	0	13	155	641	1459	2448
Wind	WSAvg	9.2	10.4	9.9	9.3	8.4	8.0	8.0	8.2	8.5	9.3	9.8	10.6	10.7
Precipitation	PrecAvg	23.1	3.0	2.7	1.8	1.5	1.8	1.1	1.8	1.5	1.3	1.8	2.2	2.6
	PrecMax	33.4	9.0	9.8	8.9	9.5	7.0	2.9	7.4	6.3	4.5	4.4	8.7	9.5
	PrecMin	12.6	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.2	0.1	0.2
	PrecStd	5.3	2.3	2.3	1.9	2.0	1.8	0.8	1.6	1.4	1.0	1.2	1.7	2.2
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	104.2	103.5	97.8	89.4	80.8	73.7	74.3	80.9	89.9	94.8	103.2	103.5
		MCWB	69.4	69.3	67.0	63.7	60.2	58.5	56.3	58.1	59.2	62.3	65.2	67.5
	2%	DB	100.1	98.2	92.9	85.6	77.4	70.9	70.1	75.0	84.7	90.3	96.9	98.7
		MCWB	68.8	68.9	66.1	63.3	59.1	56.9	54.7	55.9	58.9	61.5	64.6	65.7
	5%	DB	96.7	94.4	89.8	83.0	75.0	68.6	67.2	71.6	80.3	86.8	92.5	95.1
		MCWB	67.9	68.5	65.9	62.0	58.0	55.5	53.6	53.9	57.7	61.2	64.0	65.7
	10%	DB	93.3	91.1	87.0	80.6	72.4	66.0	64.5	68.4	76.4	83.3	88.2	91.8
		MCWB	67.6	67.9	65.7	61.1	57.0	54.3	52.3	53.1	56.7	60.3	63.1	65.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	75.4	75.5	73.1	68.9	65.5	62.1	63.2	62.1	65.7	68.9	71.3	73.7
		MCDB	87.4	88.3	83.2	80.0	72.9	68.0	67.6	75.6	77.1	81.3	84.7	86.2
	2%	WB	73.6	74.0	71.6	66.9	62.9	60.0	58.8	59.1	63.2	66.4	69.3	71.9
		MCDB	87.0	86.0	81.2	77.4	71.5	65.9	64.6	68.0	73.2	79.8	81.4	84.9
	5%	WB	72.3	72.6	70.1	65.0	61.0	58.1	56.0	57.0	61.3	64.6	68.0	70.6
		MCDB	85.9	84.6	80.6	76.8	69.7	64.4	63.0	66.8	73.0	78.0	80.5	83.7
	10%	WB	71.1	71.1	68.7	63.3	59.0	56.3	54.1	54.9	59.4	63.1	66.7	69.2
		MCDB	84.7	83.6	80.2	76.2	69.0	63.3	61.8	65.5	71.6	76.6	80.2	82.7
Mean Daily Temperature Range	5% DB	MDBR	22.9	22.1	22.8	24.6	24.3	22.3	23.8	26.3	27.0	25.9	24.3	24.0
		MCDBR	26.8	26.1	25.4	26.2	25.8	24.8	26.8	30.0	31.5	29.6	28.9	28.1
		MCWBR	8.5	8.3	8.8	10.4	11.7	12.8	14.3	14.6	13.5	11.4	10.0	9.7
	5% WB	MCDBR	21.0	20.2	19.5	21.9	20.1	18.6	20.2	23.5	23.6	23.8	21.5	22.3
	MCWBR	7.6	7.7	8.3	10.0	10.1	10.9	12.4	12.9	12.2	10.9	8.6	9.2	
Clear-Sky Solar Irradiance	taub	0.361	0.360	0.334	0.318	0.298	0.291	0.286	0.298	0.333	0.353	0.374	0.365	
	taud	2.528	2.540	2.608	2.610	2.612	2.644	2.633	2.570	2.463	2.441	2.432	2.494	
	Ebn at Noon	311	305	304	293	285	280	287	296	299	304	305	311	
	Edh at Noon	36	34	30	27	24	22	23	28	34	37	39	37	
All-Sky Solar Radiation	RadAvg	2369	2160	1858	1543	1210	987	1110	1418	1793	2080	2241	2369	
	RadStd	149	155	113	75	63	82	77	83	125	158	217	180	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		+1.04	N/A	N/A	+2.34	N/A	N/A	N/A	+515	+392
(47) Regional (6 neighbors)		+1.10	N/A	N/A	+2.34	N/A	N/A	N/A	+486	+374

Nomenclature: See separate page