

MILES, Australia

WMO: 955290

Lat: 26.6569S

Lon: 150.1819E

Elev: 305

StdP: 97.71

Time Zone: 10.00 (E10)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	-0.2	1.2	-7.7	2.0	21.4	-5.4	2.5	20.3	6.1	16.7	5.5	16.6	0.2	0	0.368

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	11.9	37.2	20.3	35.7	20.1	34.3	19.9	24.0	30.2	23.2	29.0	22.6	28.5	3.6	10

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.6	17.9	25.7	21.7	17.0	25.3	20.9	16.2	24.9	73.9	30.2	70.7	29.0	68.1	28.2	36.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.0	5.9	5.3	-2.7	39.9	1.1	1.4	-3.5	40.9	-4.2	41.7	-4.8	42.5	-5.6	43.5		
(5)			-1.3	26.6	1.2	3.6	-2.2	29.2	-2.9	31.3	-3.5	33.3	-4.4	36.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	20.1	27.0	26.0	24.1	20.4	15.5	13.0	12.1	13.6	17.8	21.4	24.4	26.0	(6)
(7)		DBStd	6.05	2.26	2.58	2.42	2.43	2.97	3.00	2.98	3.33	3.63	3.33	2.91	2.81	(7)
(8)		HDD10.0	22	0	0	0	0	1	7	11	4	0	0	0	0	(8)
(9)		HDD18.3	678	0	0	1	9	95	163	193	151	54	11	1	1	(9)
(10)		CDD10.0	3699	527	449	437	311	172	95	77	117	233	353	433	496	(10)
(11)		CDD18.3	1313	268	216	179	70	8	1	1	6	37	105	183	237	(11)
(12)		CDH23.3	14224	3038	2381	1744	660	117	8	12	102	511	1184	1899	2567	(12)
(13)		CDH26.7	6401	1557	1161	705	147	13	1	0	21	158	471	882	1286	(13)
(14)	Wind	WSAvg	2.3	2.9	2.8	2.5	1.9	1.5	1.6	1.5	1.8	2.2	2.7	2.9	2.9	(14)
(15)	Precipitation	PrecAvg	646	96	68	53	39	42	35	33	28	51	69	98		(15)
(16)		PrecMax	1009	280	215	174	211	240	192	168	171	115	117	175	442	(16)
(17)		PrecMin	386	12	0	0	0	0	0	0	0	0	5	0	21	(17)
(18)		PrecStd	156	67	53	42	48	46	38	37	31	26	28	45	72	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	38.7	38.9	36.4	31.5	28.2	24.2	24.8	29.2	33.4	35.6	37.2	39.2	(19)
(20)			MCWB	21.5	21.2	19.9	18.4	16.7	16.0	14.4	15.0	16.9	17.9	19.8	19.3	(20)
(21)		2%	DB	36.6	36.4	33.7	29.7	26.1	22.6	22.8	25.8	30.5	33.1	35.1	36.8	(21)
(22)			MCWB	20.6	20.8	20.3	17.8	15.7	14.9	14.1	14.2	16.0	17.2	18.8	20.2	(22)
(23)		5%	DB	35.1	34.4	32.0	28.3	24.5	21.3	21.3	23.9	28.4	31.2	33.4	34.7	(23)
(24)			MCWB	20.7	20.8	19.7	17.5	15.1	14.2	13.3	13.2	15.6	16.9	18.5	19.9	(24)
(25)		10%	DB	33.6	32.7	30.5	27.1	23.0	19.8	19.7	22.0	26.4	29.4	31.6	32.9	(25)
(26)			MCWB	20.3	20.5	19.3	17.2	14.6	13.6	12.6	12.5	15.0	16.6	18.0	19.8	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	25.6	24.8	23.7	21.7	19.0	18.2	18.1	17.6	19.7	21.7	22.5	25.1	(27)
(28)			MCDWB	30.3	30.4	27.8	26.3	23.1	21.7	21.8	22.5	27.0	29.1	29.0	29.5	(28)
(29)		2%	WB	24.1	23.7	22.7	20.3	17.7	16.8	16.4	16.2	18.2	20.3	21.4	23.1	(29)
(30)			MCDWB	30.2	30.3	27.7	25.3	22.7	19.9	19.9	22.5	25.0	26.9	28.4	28.6	(30)
(31)		5%	WB	23.2	23.0	21.9	19.3	16.7	15.8	14.9	15.1	17.3	19.3	20.7	22.3	(31)
(32)			MCDWB	29.2	29.0	27.2	24.7	22.0	19.0	18.7	21.1	24.6	25.7	28.0	28.3	(32)
(33)		10%	WB	22.5	22.3	21.2	18.5	15.8	14.7	13.7	14.0	16.4	18.4	20.0	21.6	(33)
(34)			MCDWB	28.6	28.4	26.8	24.2	20.8	18.3	18.0	20.0	23.8	25.1	27.5	28.1	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	11.9	11.9	12.2	13.7	15.1	13.3	15.2	16.6	16.0	14.6	12.9	12.2	(35)
(36)			MCDBR	14.6	14.7	14.2	15.2	16.5	15.0	17.0	18.8	18.2	17.1	15.4	15.2	(36)
(37)			MCWBR	3.8	3.9	3.7	5.2	7.1	7.6	8.2	8.1	7.0	5.6	4.3	4.5	(37)
(38)		5% WB	MCDWB	11.3	11.3	11.0	11.7	12.7	10.6	12.2	13.9	14.3	12.8	12.1	11.1	(38)
(39)			MCWBR	4.4	3.9	3.9	4.5	6.0	6.0	6.8	6.9	6.3	5.1	4.3	4.4	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.367	0.356	0.336	0.319	0.299	0.292	0.285	0.298	0.332	0.356	0.369	0.372	(40)	
(41)		taud	2.530	2.571	2.624	2.632	2.629	2.655	2.658	2.598	2.492	2.460	2.470	2.497	(41)	
(42)		Ebn at Noon	975	970	962	933	911	897	920	943	949	959	967	972	(42)	
(43)		Edh at Noon	112	105	94	85	78	72	74	87	106	116	118	116	(43)	
(44)	All-Sky Solar Radiation	RadAvg	7.13	6.58	5.81	4.96	4.04	3.39	3.83	4.81	5.86	6.61	7.08	7.17	(44)	
(45)		RadStd	0.51	0.58	0.37	0.30	0.17	0.26	0.28	0.31	0.44	0.55	0.69	0.70	(45)	

Historical Trends

		DBAvg		Heating		Cooling			Degree-Days			
				99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (6 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page