

BEERBURRUM FOREST, AustraliaWMO: **955660**Lat: **26.9586S**Lon: **152.9619E**Elev: **157**StdP: **14.61**Time Zone: **10.00 (E10)**Period: **01-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	43.7	45.6	27.9	22.0	62.7	31.7	26.2	61.3	12.2	63.7	10.0	64.6	0.6	230	0.277

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	16.2	91.8	72.6	88.8	72.6	86.5	71.8	77.3	85.4	75.8	83.8	74.5	82.3	7.4	30

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
75.2	133.0	80.3	73.6	125.6	79.6	72.2	119.7	78.7	40.9	85.3	39.3	83.8	38.2	82.3	83.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.9	10.1	8.9	39.5	100.1	1.9	4.5	38.1	103.4	37.0	106.0	35.9	108.6	34.5	111.9		
(5)			37.3	79.1	1.7	1.5	36.1	80.3	35.1	81.2	34.2	82.0	32.9	83.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	68.3	76.4	76.0	73.7	69.2	64.1	60.5	59.3	60.7	65.2	68.7	72.0	74.9
	DBStd	7.10	3.61	3.36	3.02	2.88	3.22	3.48	3.45	3.91	4.43	4.67	4.14	4.13
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	587	0	0	0	3	55	139	180	146	50	13	1	0
	CDD50	6688	817	727	733	575	436	315	289	331	457	578	659	771
	CDD65	1800	352	307	268	128	26	4	4	12	57	126	210	306
	CDH74	12518	2689	2173	1520	595	138	17	25	150	512	982	1435	2282
	CDH80	3523	859	662	335	68	8	0	0	24	125	285	391	766
Wind	WSAvg	3.2	3.7	3.5	3.1	2.7	2.5	2.7	2.6	3.1	3.4	3.7	3.7	3.7
Precipitation	PrecAvg	57.7	8.3	8.6	7.2	4.6	5.0	2.8	2.6	1.9	1.6	3.8	5.2	6.5
	PrecMax	110.3	49.2	25.7	21.2	27.5	17.0	20.1	24.6	5.4	7.8	12.3	14.0	35.5
	PrecMin	33.5	0.6	1.8	0.3	0.9	0.6	0.0	0.2	0.0	0.0	0.4	1.0	1.6
	PrecStd	15.6	8.3	6.4	5.0	4.2	4.3	4.0	3.9	1.5	1.7	2.8	3.1	5.6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	95.3	93.6	90.6	84.8	80.5	76.4	76.9	82.8	89.2	93.2	92.2	96.0
		MCWB	75.8	76.5	73.9	69.5	64.4	63.9	60.4	61.9	65.2	68.5	69.6	73.4
	2%	DB	90.2	89.0	86.2	81.8	77.5	73.4	73.6	77.9	83.6	86.6	87.2	90.5
		MCWB	75.0	75.0	72.6	68.0	63.8	61.7	59.0	60.7	64.4	67.1	69.8	72.6
	5%	DB	87.1	86.4	83.5	79.5	75.1	70.9	71.1	74.5	79.4	82.5	84.2	87.2
		MCWB	73.6	73.8	71.4	67.5	63.0	60.6	58.8	59.5	63.1	66.0	69.2	72.1
	10%	DB	84.6	84.2	81.3	77.6	72.9	68.8	68.8	71.4	76.3	79.2	81.6	84.1
		MCWB	72.8	72.4	70.5	66.9	62.3	59.8	58.0	57.8	61.8	65.7	68.6	70.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	79.0	80.5	76.4	72.8	69.1	67.4	66.5	66.9	69.7	72.9	74.3	77.6
		MCDB	85.5	90.3	85.2	80.2	75.7	71.8	71.6	77.2	80.3	83.7	84.9	88.0
	2%	WB	77.3	77.4	74.5	70.9	66.9	65.0	63.9	64.2	67.5	70.6	72.6	75.7
		MCDB	84.8	85.2	82.1	77.6	73.4	69.6	69.1	72.5	77.2	80.6	82.2	84.6
	5%	WB	75.8	75.6	73.3	69.6	65.5	63.5	61.7	62.3	65.8	68.8	71.2	74.2
		MCDB	83.6	82.9	80.5	76.1	72.0	68.0	67.3	70.2	75.3	77.8	80.1	82.8
	10%	WB	74.4	74.1	72.2	68.4	64.1	61.9	60.0	60.5	64.2	67.2	70.1	72.8
		MCDB	82.0	81.0	79.0	74.8	70.2	66.6	66.0	67.9	72.8	75.7	78.4	80.9
Mean Daily Temperature Range	5% DB	MDBR	16.2	15.4	15.8	17.5	19.0	17.5	20.5	23.1	22.5	20.4	18.9	17.5
		MCDBR	20.5	19.2	19.3	20.6	21.9	20.2	23.4	27.1	27.3	26.1	22.8	22.6
		MCWBR	7.7	7.5	7.9	9.4	10.6	10.7	11.6	12.7	11.6	10.8	9.1	8.9
		MCDBR	17.1	17.1	15.8	17.0	17.4	15.5	18.4	21.9	22.3	21.3	18.8	18.9
	5% WB	MCWBR	7.1	7.7	7.2	8.7	9.8	9.6	11.0	12.1	10.9	10.0	8.1	8.3
Clear-Sky Solar Irradiance	taub		0.395	0.383	0.360	0.343	0.320	0.313	0.304	0.318	0.357	0.378	0.383	0.399
	taud		2.485	2.528	2.594	2.617	2.633	2.648	2.657	2.593	2.481	2.456	2.479	2.458
	Ebn at Noon		301	299	297	288	281	277	285	292	293	298	303	300
	Edh at Noon		37	35	31	28	25	23	24	28	34	37	37	38
All-Sky Solar Radiation	RadAvg		2069	1900	1640	1417	1179	985	1142	1423	1748	1938	2114	2096
	RadStd		175	162	108	80	64	73	94	111	138	171	185	228