

BEERBURRUM FOREST, AustraliaWMO: **955660**Lat: **26.9586S**Lon: **152.9619E**Elev: **48**StdP: **100.75**Time Zone: **10.00 (E10)**Period: **01-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.5	7.6	-2.3	3.1	17.1	-0.2	3.7	16.3	5.4	17.6	4.5	18.1	0.3	230	0.277

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	9.0	33.2	22.5	31.6	22.5	30.3	22.1	25.2	29.7	24.3	28.8	23.6	27.9	3.3	30

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
24.0	19.0	26.8	23.1	17.9	26.4	22.3	17.1	25.9	77.1	29.6	73.6	28.8	70.9	27.9	28.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 5.8	4.5	4.0	4.2	37.8	1.1	2.5	3.4	39.6	2.8	41.1	2.2	42.5	1.4	44.4		
(5)			3.0	26.2	0.9	0.9	2.3	26.8	1.7	27.3	1.2	27.8	0.5	28.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	20.2	24.6	24.4	23.1	20.7	17.8	15.8	15.2	15.9	18.5	20.4	22.2	23.8
	DBStd	3.94	2.01	1.87	1.68	1.60	1.79	1.93	1.91	2.17	2.46	2.59	2.30	2.29
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	326	0	0	0	2	31	77	100	81	28	7	1	0
	CDD10.0	3716	454	404	407	319	242	175	161	184	254	321	366	428
	CDD18.3	1000	196	171	149	71	14	2	2	7	32	70	117	170
	CDH23.3	6954	1494	1207	844	331	77	9	14	83	284	546	797	1268
	CDH26.7	1957	477	368	186	38	4	0	0	13	69	158	217	426
Wind	WSAvg	1.4	1.6	1.5	1.4	1.2	1.1	1.2	1.2	1.4	1.5	1.7	1.7	1.7
Precipitation	PrecAvg	1465	210	219	182	116	127	70	67	49	40	97	132	164
	PrecMax	2802	1250	654	539	698	432	510	626	136	197	312	356	902
	PrecMin	851	14	46	7	23	15	1	4	1	0	10	26	41
	PrecStd	396	211	162	128	106	110	101	99	38	44	70	78	143
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	35.2	34.2	32.5	29.3	26.9	24.7	25.0	28.2	31.8	34.0	33.4	35.5
		MCWB	24.3	24.7	23.3	20.9	18.0	17.7	15.8	16.6	18.5	20.3	20.9	23.0
	2%	DB	32.3	31.7	30.1	27.7	25.3	23.0	23.1	25.5	28.6	30.3	30.7	32.5
		MCWB	23.9	23.9	22.6	20.0	17.7	16.5	15.0	15.9	18.0	19.5	21.0	22.6
	5%	DB	30.6	30.2	28.6	26.4	23.9	21.6	21.7	23.6	26.3	28.1	29.0	30.7
		MCWB	23.1	23.2	21.9	19.7	17.2	15.9	14.9	15.3	17.3	18.9	20.7	22.3
	10%	DB	29.2	29.0	27.4	25.3	22.7	20.5	20.4	21.9	24.6	26.2	27.5	29.0
		MCWB	22.7	22.5	21.4	19.4	16.8	15.5	14.4	14.3	16.6	18.7	20.3	21.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.1	27.0	24.7	22.7	20.6	19.7	19.1	19.4	20.9	22.7	23.5	25.3
		MCDB	29.7	32.4	29.6	26.8	24.3	22.1	22.0	25.1	26.8	28.7	29.4	31.1
	2%	WB	25.2	25.2	23.6	21.6	19.4	18.3	17.7	17.9	19.7	21.4	22.5	24.3
		MCDB	29.4	29.6	27.8	25.3	23.0	20.9	20.6	22.5	25.1	27.0	27.9	29.2
	5%	WB	24.3	24.2	22.9	20.9	18.6	17.5	16.5	16.8	18.8	20.5	21.8	23.5
		MCDB	28.7	28.3	27.0	24.5	22.2	20.0	19.6	21.2	24.0	25.5	26.7	28.2
	10%	WB	23.6	23.4	22.3	20.2	17.8	16.6	15.5	15.8	17.9	19.6	21.2	22.6
		MCDB	27.8	27.2	26.1	23.8	21.2	19.2	18.9	20.0	22.6	24.3	25.8	27.2
Mean Daily Temperature Range	5% DB	MDBR	9.0	8.6	8.8	9.7	10.5	9.7	11.4	12.9	12.5	11.4	10.5	9.7
		MCDBR	11.4	10.7	10.7	11.5	12.2	11.2	13.0	15.1	15.2	14.5	12.7	12.6
		MCWBR	4.3	4.2	4.4	5.2	5.9	5.9	6.5	7.1	6.4	6.0	5.0	4.9
	5% WB	MCDBR	9.5	9.5	8.8	9.4	9.7	8.6	10.2	12.2	12.4	11.8	10.5	10.5
		MCWBR	3.9	4.3	4.0	4.8	5.4	5.4	6.1	6.7	6.1	5.5	4.5	4.6
Clear-Sky Solar Irradiance	taub	0.395	0.383	0.360	0.343	0.320	0.313	0.304	0.318	0.357	0.378	0.383	0.399	
	taud	2.485	2.528	2.594	2.617	2.633	2.648	2.657	2.593	2.481	2.456	2.479	2.458	
	Ebn at Noon	948	944	937	908	887	873	897	920	924	938	954	946	
	Edh at Noon	117	109	97	87	78	73	75	87	107	116	117	121	
All-Sky Solar Radiation	RadAvg	6.52	5.99	5.17	4.47	3.72	3.10	3.60	4.49	5.51	6.11	6.67	6.61	
	RadStd	0.55	0.51	0.34	0.25	0.20	0.23	0.29	0.35	0.43	0.54	0.58	0.72	