

NAMBOUR, Australia

WMO: 955720

Lat: 26.6442S

Lon: 152.9383E

Elev: 54

StdP: 100.68

Time Zone: 10.00 (E10)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	5.2	6.8	-2.4	3.1	17.6	-0.2	3.7	16.2	5.3	16.7	4.6	17.5	0.0	290	0.261

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	7.7	32.7	22.8	31.1	22.5	29.7	22.1	24.9	29.6	24.2	28.5	23.6	27.5	3.3	350

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
23.6	18.6	27.1	23.0	17.9	26.4	22.4	17.2	25.8	76.3	29.8	73.5	28.6	71.0	27.5	28.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 5.2	4.5	4.2	DB	3.5	37.2	1.7	2.3	38.9	1.3	40.2	0.3	41.5	-0.9	43.2		
(5)			WB	2.4	26.2	1.3	0.8	26.8	0.7	27.3	-0.1	27.7	-1.0	28.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	20.2	24.6	24.3	23.2	20.8	18.1	16.0	15.3	16.0	18.6	20.4	22.1	23.7		
	DBStd	3.92	1.95	1.78	1.61	1.60	1.97	2.24	2.12	2.36	2.45	2.51	2.53	2.40		
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0		
	HDD18.3	314	0	0	0	2	28	74	98	80	26	6	1	0		
	CDD10.0	3737	452	400	411	324	251	179	163	187	257	324	363	426		
	CDD18.3	1008	194	167	152	76	20	4	2	8	32	71	114	168		
	CDH23.3	6307	1382	1085	814	284	68	11	12	66	231	461	713	1179		
	CDH26.7	1544	372	273	151	23	2	1	1	9	46	123	191	354		
(14) Wind	WSAvg	1.3	1.6	1.4	1.3	1.1	0.9	1.0	1.1	1.2	1.5	1.5	1.7	1.6		
(15) Precipitation	PrecAvg	1679	237	244	207	144	142	87	66	54	45	103	144	182		
	PrecMax	3040	1218	860	658	641	422	543	233	151	242	317	398	612		
	PrecMin	974	15	54	19	37	3	3	1	0	0	4	22	25		
	PrecStd	483	214	210	145	112	104	115	55	41	45	69	88	127		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	34.2	33.5	31.8	28.7	26.5	24.7	24.9	27.6	30.6	33.1	34.4	35.0		
		MCWB	24.3	24.3	23.6	21.5	18.1	17.6	16.1	17.0	17.9	19.8	20.8	22.8		
	2%	DB	31.6	31.1	29.7	27.1	25.1	23.0	23.1	25.0	27.7	29.7	30.7	32.2		
		MCWB	23.9	23.7	22.8	20.3	17.7	16.8	15.4	16.0	18.0	19.7	20.9	23.0		
	5%	DB	29.9	29.5	28.2	26.1	23.9	21.7	21.6	23.2	25.9	27.6	28.7	30.2		
		MCWB	23.1	23.1	22.1	20.0	17.5	16.2	15.1	15.2	17.4	19.4	20.8	22.4		
	10%	DB	28.6	28.2	27.1	25.0	22.7	20.6	20.3	21.6	24.2	25.8	27.0	28.4		
		MCWB	22.4	22.4	21.6	19.4	17.2	15.8	14.7	14.6	16.8	19.0	20.4	21.8		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	25.9	25.9	25.0	23.2	21.2	19.8	19.2	19.1	20.8	22.6	23.5	25.2		
		MCDB	31.4	31.6	29.3	26.3	23.8	22.1	22.4	24.5	26.1	28.1	29.2	31.6		
	2%	WB	24.9	24.8	24.0	21.8	20.0	18.6	17.7	17.9	19.7	21.5	22.6	24.3		
		MCDB	29.1	29.2	27.9	25.0	22.8	21.0	20.6	22.3	24.6	26.8	27.7	29.7		
	5%	WB	24.2	24.0	23.2	21.0	19.1	17.7	16.7	17.0	18.9	20.6	21.9	23.5		
		MCDB	28.0	27.7	26.5	24.4	22.1	20.3	19.9	21.1	23.7	25.4	26.5	28.1		
	10%	WB	23.5	23.3	22.6	20.4	18.3	16.9	15.7	16.1	18.1	19.8	21.2	22.7		
		MCDB	27.1	26.7	25.7	23.7	21.2	19.5	18.8	19.8	22.6	24.2	25.5	26.8		
(35) Mean Daily Temperature Range	MDBR		7.7	7.4	7.6	8.4	9.6	9.5	10.9	12.0	11.5	10.1	9.3	8.7		
	5% DB	MCDBR	9.8	9.7	9.8	10.5	11.7	11.0	12.9	14.3	14.0	13.3	11.7	11.6		
		MCWBR	3.5	3.7	4.1	4.8	5.6	5.8	6.5	6.5	5.9	5.4	4.3	4.3		
	5% WB	MCDBR	8.4	8.4	8.2	8.4	8.4	8.4	9.7	10.9	11.4	11.0	9.9	10.1		
		MCWBR	3.4	3.6	3.8	4.3	4.6	5.1	5.7	5.7	5.4	4.9	4.0	4.1		
(40) Clear-Sky Solar Irradiance	taub		0.395	0.383	0.361	0.344	0.320	0.314	0.304	0.318	0.356	0.377	0.382	0.399		
	taud		2.486	2.530	2.590	2.615	2.635	2.647	2.657	2.595	2.485	2.459	2.483	2.460		
	Ebn at Noon		948	944	936	908	889	873	898	921	925	939	955	947		
	Edh at Noon		117	109	98	87	78	73	75	87	107	116	117	120		
(44) All-Sky Solar Radiation	RadAvg		6.53	5.99	5.17	4.48	3.73	3.13	3.63	4.51	5.54	6.13	6.69	6.64		
	RadStd		0.56	0.51	0.36	0.27	0.21	0.23	0.31	0.36	0.44	0.54	0.59	0.74		

Historical Trends

		DBAvg		Heating		Cooling		Degree-Days			
				99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.76	+2.35	-1.79	N/A	N/A	-0.45	N/A	-138	+319	+158
(47) Regional (25 neighbors)		+0.35	N/A	N/A	N/A	N/A	N/A	N/A	-66	+179	+109

Nomenclature: See separate page