

BEAUDESERT, Australia

WMO: 955750

Lat: 27.971S

Lon: 152.990E

Elev: 48

StdP: 100.75

Time Zone: 10.00 (E10)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	2.5	3.9	-2.7	3.0	14.2	-0.8	3.6	12.4	7.3	17.8	6.6	17.7	0.4	100	0.311

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	10.5	34.2	22.7	32.6	22.6	31.2	22.1	24.9	30.8	24.1	29.4	23.5	28.5	3.2	30

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
23.4	18.3	26.7	22.7	17.5	26.2	22.1	16.9	25.8	76.0	30.7	73.0	29.5	70.5	28.5	27.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 6.5	5.7	5.1	-1.1	38.9	1.3	2.5	-2.1	40.7	-2.8	42.2	-3.6	43.6	-4.5	45.4		
(5)			-1.6	26.4	1.4	0.6	-2.6	26.9	-3.4	27.2	-4.1	27.6	-5.1	28.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	19.8	25.1	24.5	23.3	20.4	16.6	14.6	13.8	14.6	17.8	20.1	23.0	24.1	(6)
(7)		DBStd	4.63	2.11	2.06	1.81	1.75	2.21	2.31	2.42	2.42	2.42	2.47	2.59	2.40	(7)
(8)		HDD10.0	2	0	0	0	0	0	1	1	1	0	0	0	0	(8)
(9)		HDD18.3	487	0	0	0	3	61	113	142	120	37	11	0	0	(9)
(10)		CDD10.0	3577	468	406	413	311	206	138	119	142	235	312	390	437	(10)
(11)		CDD18.3	1020	209	173	155	64	8	1	2	3	22	64	141	178	(11)
(12)		CDH23.3	8098	1781	1379	1015	379	81	6	13	71	279	562	1104	1428	(12)
(13)	CDH26.7	2629	683	471	271	54	3	0	1	12	67	154	392	522	(13)	
(14)	Wind	WSAvg	1.7	1.9	2.0	1.7	1.6	1.3	1.4	1.4	1.5	1.6	1.8	1.9	1.8	(14)
(15)	Precipitation	PrecAvg	900	114	110	87	65	69	43	42	36	34	69	92	133	(15)
(16)		PrecMax	1327	600	298	264	452	337	347	212	134	128	325	287	339	(16)
(17)		PrecMin	454	15	12	0	6	6	2	1	0	0	13	8	41	(17)
(18)		PrecStd	230	98	75	65	86	79	61	42	31	32	53	63	76	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	36.3	35.3	33.9	29.9	26.9	24.1	24.9	28.1	31.7	33.1	35.3	35.7	(19)
(20)			MCWB	23.7	24.2	23.4	21.0	18.3	16.7	16.5	16.7	17.9	19.7	21.3	22.9	(20)
(21)		2%	DB	33.6	32.8	31.0	28.2	25.5	22.5	22.8	25.2	28.4	30.2	32.6	33.0	(21)
(22)			MCWB	23.1	24.0	22.7	20.3	17.7	15.8	15.4	15.7	17.8	19.5	21.4	22.3	(22)
(23)		5%	DB	32.0	31.1	29.5	26.8	24.1	21.3	21.4	23.2	26.2	28.2	30.6	31.2	(23)
(24)			MCWB	23.0	23.1	21.9	19.6	16.9	15.3	14.6	14.7	17.0	18.7	21.1	22.2	(24)
(25)		10%	DB	30.3	29.6	28.1	25.6	22.8	20.1	20.1	21.7	24.6	26.5	28.8	29.6	(25)
(26)			MCWB	22.5	22.3	21.3	19.3	16.3	14.9	14.3	14.1	16.2	18.2	20.4	21.7	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	25.7	25.9	24.6	22.7	20.5	18.7	19.4	18.9	20.6	22.3	24.1	25.0	(27)
(28)			MCDWB	31.3	32.3	29.6	26.0	24.2	20.6	22.0	25.4	27.6	29.2	30.4	31.8	(28)
(29)		2%	WB	24.9	24.9	23.9	21.6	19.1	17.6	17.9	17.5	19.6	21.0	23.0	24.0	(29)
(30)			MCDWB	30.9	30.6	28.2	25.8	23.3	20.3	20.7	22.0	24.8	26.6	29.4	30.3	(30)
(31)		5%	WB	24.0	24.0	23.2	20.8	18.1	16.7	16.3	16.3	18.7	20.1	22.2	23.3	(31)
(32)			MCDWB	29.0	28.9	27.4	25.0	22.2	19.7	19.5	20.8	23.4	25.4	27.6	28.6	(32)
(33)		10%	WB	23.3	23.2	22.5	20.1	17.3	15.8	15.1	15.3	17.7	19.3	21.5	22.7	(33)
(34)			MCDWB	28.1	27.7	26.5	24.5	21.3	18.8	18.6	19.9	22.4	24.4	26.5	27.2	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	10.5	10.1	9.8	11.2	13.1	12.2	14.0	15.8	14.6	13.0	11.7	10.8	(35)
(36)			MCDBR	13.5	12.7	12.3	13.2	14.8	13.6	15.7	17.7	17.3	16.4	14.4	13.6	(36)
(37)			MCWBR	4.6	4.5	4.6	6.0	7.4	7.6	8.4	8.7	7.4	6.3	5.1	4.7	(37)
(38)		5% WB	MCDWB	10.8	11.3	10.1	11.6	11.7	10.2	11.4	14.7	13.7	12.6	12.1	11.2	(38)
(39)			MCWBR	4.1	4.4	4.3	5.6	6.3	6.2	7.0	7.9	6.2	5.3	4.7	4.3	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.387	0.374	0.355	0.337	0.313	0.308	0.298	0.311	0.356	0.378	0.382	0.394	(40)	
(41)		taud	2.484	2.532	2.581	2.608	2.629	2.636	2.651	2.591	2.459	2.429	2.459	2.450	(41)	
(42)		Ebn at Noon	955	951	939	910	890	873	899	924	922	936	953	951	(42)	
(43)		Edh at Noon	117	109	98	87	77	73	74	87	109	119	119	122	(43)	
(44)	All-Sky Solar Radiation	RadAvg	6.47	5.90	5.07	4.36	3.63	3.00	3.49	4.38	5.39	6.00	6.51	6.49	(44)	
(45)		RadStd	0.54	0.51	0.30	0.21	0.21	0.21	0.27	0.34	0.44	0.56	0.57	0.68	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (28 neighbors)	+0.40	N/A	N/A	N/A	N/A	N/A	N/A	-64	+182	+110

Nomenclature: See separate page