

BRISBANE REDCLIFFE, Australia

WMO: 955910

Lat: 27.2169S

Lon: 153.0922E

Elev: 43

StdP: 14.67

Time Zone: 10.00 (E10)

Period: 04-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	48.0	49.9	27.2	21.1	61.8	31.0	25.2	61.7	23.1	63.2	21.4	62.9	6.4	240	0.500

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	9.4	86.4	73.3	84.8	72.9	83.4	72.2	76.3	83.7	75.2	82.3	74.2	81.2	15.5	40

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
73.8	126.3	81.3	72.8	121.7	80.5	71.8	117.6	79.6	39.8	84.0	38.8	82.5	37.8	81.3	79.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
28.9	25.7	23.3	DB	43.4	92.6	1.7	3.0	42.2	94.7	41.2	96.5	40.2	98.1	38.9	100.3
			WB	38.8	78.0	1.8	0.8	37.5	78.6	36.4	79.1	35.4	79.6	34.1	80.2

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	69.5	77.7	77.1	75.1	70.8	65.5	61.6	60.3	61.7	65.9	69.5	73.2	75.8	(6)
	DBStd	6.89	2.75	2.76	2.61	2.67	3.07	3.33	3.24	3.50	3.76	3.58	3.27	3.22	(7)
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
	HDD65	441	0	0	0	1	31	108	151	113	32	5	0	0	(9)
	CDD50	7106	859	758	779	623	479	348	318	364	476	605	697	800	(10)
	CDD65	2074	394	338	314	174	45	6	4	12	58	146	248	335	(11)
	CDH74	11857	3088	2530	1835	554	75	3	10	44	165	434	1038	2081	(12)
	CDH80	1651	548	418	186	24	0	0	1	4	20	42	87	321	(13)
(14) Wind	WSAvg	12.1	14.6	14.9	14.0	12.2	9.7	9.1	8.7	9.3	11.5	13.4	14.0	14.2	(14)
(15) Precipitation	PrecAvg	51.7	7.8	6.2	5.7	4.3	4.5	2.7	2.8	2.1	1.5	4.8	4.9	6.1	(15)
	PrecMax	91.1	40.5	18.3	15.7	17.8	17.0	19.9	19.6	5.1	4.1	13.4	15.4	23.7	(16)
	PrecMin	29.8	1.2	0.6	0.2	0.7	0.4	0.0	0.0	0.0	0.0	0.2	1.0	1.7	(17)
	PrecStd	13.5	7.6	4.3	4.2	4.2	4.2	4.1	3.8	1.4	1.2	3.3	3.6	4.1	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	88.7	87.8	86.3	82.5	78.2	73.9	74.6	78.8	82.6	84.1	85.3	89.2	(19)
		MCWB	75.5	76.2	73.6	69.5	64.0	62.4	59.9	60.3	64.6	65.7	70.8	71.2	(20)
	2%	DB	85.9	85.6	83.6	80.2	76.1	71.5	71.4	74.2	77.9	80.4	82.3	85.5	(21)
		MCWB	74.4	74.0	72.4	68.5	64.1	61.6	59.9	60.3	63.6	68.1	70.6	72.3	(22)
	5%	DB	84.4	84.1	82.0	78.4	74.3	69.9	69.3	71.8	75.4	78.1	80.5	83.2	(23)
		MCWB	73.4	73.0	71.6	67.5	63.4	60.6	59.2	59.7	63.5	67.4	70.1	72.0	(24)
	10%	DB	83.0	82.6	80.7	77.1	72.7	68.3	67.4	69.7	73.5	76.3	78.9	81.4	(25)
		MCWB	72.4	72.0	71.0	67.2	62.8	59.8	58.4	59.1	63.0	66.5	69.1	71.2	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	77.4	77.3	76.4	72.9	69.1	65.7	65.8	66.7	69.2	72.3	74.1	76.8	(27)
		MCDB	84.8	85.0	83.1	77.9	74.7	70.2	70.6	73.6	76.8	79.6	82.3	86.1	(28)
	2%	WB	76.3	76.2	74.8	70.9	66.9	64.4	63.7	64.7	67.4	70.8	72.7	75.1	(29)
		MCDB	83.6	83.2	81.1	77.0	73.3	68.9	68.4	70.8	74.2	77.4	79.9	82.8	(30)
	5%	WB	75.1	74.9	73.7	69.7	65.7	63.0	61.7	62.9	66.2	69.4	71.6	73.8	(31)
		MCDB	82.3	81.7	79.9	76.2	72.0	67.7	67.0	69.1	73.0	75.8	78.4	81.0	(32)
	10%	WB	74.1	73.7	72.6	68.6	64.5	61.8	60.2	61.3	65.0	68.0	70.5	72.7	(33)
		MCDB	81.0	80.7	78.9	75.2	70.6	66.6	65.6	67.5	71.7	74.8	77.4	79.6	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	9.4	9.9	10.5	12.6	14.3	13.3	15.0	16.6	14.9	12.1	10.1	9.9	(35)
		MCDBR	11.2	11.5	11.9	14.2	16.2	14.7	17.0	18.8	17.4	14.8	11.6	12.5	(36)
	5% WB	MCWBR	4.9	4.7	5.1	6.4	7.9	8.0	9.2	9.9	8.7	7.6	5.5	6.3	(37)
		MCWBR	10.4	10.8	10.5	12.1	12.9	11.5	14.0	15.3	14.1	12.5	10.7	11.5	(38)
(40) Clear-Sky Solar Irradiance	taub		0.393	0.383	0.359	0.341	0.323	0.314	0.304	0.318	0.359	0.379	0.384	0.397	(40)
		taud	2.498	2.533	2.603	2.630	2.626	2.650	2.660	2.599	2.480	2.459	2.482	2.470	(41)
	Ebn at Noon		301	299	297	288	280	276	284	292	292	297	302	301	(42)
		Edh at Noon	37	35	30	27	25	23	23	28	34	37	37	38	(43)
(44) All-Sky Solar Radiation	RadAvg		2073	1905	1643	1411	1172	973	1131	1413	1739	1931	2112	2091	(44)
	RadStd		171	159	103	75	62	70	90	107	134	168	177	222	(45)

Historical Trends

		Heating		Cooling			Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (28 neighbors)	+0.70	N/A	N/A	N/A	N/A	N/A	N/A	-121	+335	+202	(47)

Nomenclature: See separate page