

BRISBANE REDCLIFFE, Australia

WMO: 955910

Lat: 27.2169S

Lon: 153.0922E

Elev: 13

StdP: 101.17

Time Zone: 10.00 (E10)

Period: 04-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 7	(b) 8.9	(c) 10.0	(d) -2.7	(e) 3.0	(f) 16.6	(g) -0.6	(h) 3.6	(i) 16.5	(j) 10.3	(k) 17.3	(l) 9.6	(m) 17.2	(n) 2.9	(o) 240	(p) 0.500

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 1	(b) 5.2	(c) 30.2	(d) 23.0	(e) 29.3	(f) 22.7	(g) 28.6	(h) 22.3	(i) 24.6	(j) 28.7	(k) 24.0	(l) 28.0	(m) 23.5	(n) 27.3	(o) 6.9	(p) 40

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
23.2	18.0	27.4	22.6	17.4	27.0	22.1	16.8	26.5	74.8	28.9	72.4	28.1	70.1	27.4	26.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
12.9	11.5	10.4	DB	6.4	33.7	1.0	1.6	5.7	34.9	5.1	35.8	4.5	36.7	3.8	37.9	
			WB	3.8	25.6	1.0	0.5	3.0	25.9	2.5	26.2	1.9	26.4	1.2	26.8	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	20.8	25.4	25.0	24.0	21.5	18.6	16.4	15.7	16.5	18.8	20.9	22.9	24.3
	DBStd	3.83	1.53	1.54	1.45	1.48	1.71	1.85	1.80	1.94	2.09	1.99	1.82	1.79
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	245	0	0	0	1	17	60	84	63	18	3	0	0
	CDD10.0	3948	477	421	433	346	266	193	177	202	264	336	387	444
	CDD18.3	1152	219	188	174	97	25	3	2	7	32	81	138	186
	CDH23.3	6587	1716	1406	1019	308	42	2	6	24	92	241	577	1156
	CDH26.7	917	304	232	103	13	0	0	1	2	11	23	48	178
Wind	WSAvg	5.4	6.5	6.6	6.2	5.4	4.3	4.1	3.9	4.1	5.1	6.0	6.3	6.4
Precipitation	PrecAvg	1314	199	158	144	109	114	69	72	54	39	121	124	154
	PrecMax	2314	1028	465	398	453	432	505	498	129	103	341	391	603
	PrecMin	758	30	14	5	17	9	1	0	1	0	5	25	42
	PrecStd	342	194	110	106	107	107	105	96	36	31	85	91	105
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	31.5	31.0	30.2	28.0	25.7	23.3	23.7	26.0	28.1	29.0	29.6	31.8
		MCWB	24.1	24.5	23.1	20.8	17.8	16.9	15.5	15.7	18.1	18.7	21.5	21.8
	2%	DB	29.9	29.8	28.6	26.8	24.5	21.9	21.9	23.5	25.5	26.9	28.0	29.7
		MCWB	23.5	23.3	22.4	20.3	17.8	16.4	15.5	15.7	17.6	20.0	21.5	22.4
	5%	DB	29.1	28.9	27.8	25.8	23.5	21.1	20.7	22.1	24.1	25.6	27.0	28.5
		MCWB	23.0	22.8	22.0	19.7	17.5	15.9	15.1	15.4	17.5	19.7	21.2	22.2
	10%	DB	28.3	28.1	27.0	25.1	22.6	20.2	19.7	20.9	23.0	24.6	26.1	27.4
		MCWB	22.5	22.2	21.6	19.6	17.1	15.5	14.6	15.1	17.2	19.2	20.6	21.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	25.2	25.2	24.6	22.7	20.6	18.7	18.8	19.3	20.7	22.4	23.4	24.9
		MCDB	29.3	29.4	28.4	25.5	23.7	21.2	21.4	23.1	24.9	26.4	27.9	30.1
	2%	WB	24.6	24.5	23.8	21.6	19.4	18.0	17.6	18.2	19.7	21.5	22.6	23.9
		MCDB	28.7	28.4	27.3	25.0	22.9	20.5	20.2	21.6	23.5	25.2	26.6	28.2
	5%	WB	24.0	23.8	23.1	21.0	18.7	17.2	16.5	17.2	19.0	20.8	22.0	23.2
		MCDB	27.9	27.6	26.6	24.6	22.2	19.9	19.4	20.6	22.8	24.4	25.8	27.2
	10%	WB	23.4	23.1	22.6	20.3	18.1	16.5	15.6	16.3	18.3	20.0	21.4	22.6
		MCDB	27.2	27.0	26.1	24.0	21.4	19.2	18.7	19.7	22.1	23.8	25.2	26.4
Mean Daily Temperature Range	5% DB	MDBR	5.2	5.5	5.8	7.0	7.9	7.4	8.3	9.2	8.3	6.7	5.6	5.5
		MCDBR	6.2	6.4	6.6	7.9	9.0	8.2	9.4	10.4	9.6	8.2	6.4	6.9
	5% WB	MCWBR	2.7	2.6	2.8	3.6	4.4	4.5	5.1	5.5	4.8	4.2	3.1	3.5
		MCWBR	5.8	6.0	5.8	6.7	7.2	6.4	7.8	8.5	7.8	6.9	5.9	6.4
Clear-Sky Solar Irradiance	taub		0.393	0.383	0.359	0.341	0.323	0.314	0.304	0.318	0.359	0.379	0.384	0.397
	taud		2.498	2.533	2.603	2.630	2.626	2.650	2.660	2.599	2.480	2.459	2.482	2.470
	Ebn at Noon		950	944	937	909	882	870	895	919	921	936	953	948
	Edh at Noon		116	109	96	86	78	73	74	87	107	116	117	119
All-Sky Solar Radiation	RadAvg		6.54	6.00	5.18	4.45	3.69	3.07	3.56	4.46	5.48	6.09	6.66	6.59
	RadStd		0.54	0.50	0.33	0.24	0.20	0.22	0.28	0.34	0.42	0.53	0.56	0.70

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (28 neighbors)	+0.39	N/A	N/A	N/A	N/A	N/A	N/A	-67	+186	+112

Nomenclature: See separate page