

BUSSELTON JETTY, AustraliaWMO: **956020**Lat: **33.631S**Lon: **115.339E**Elev: **3**StdP: **101.29**Time Zone: **8.00 (E08)**Period: **01-11**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	4.5	5.6	2.8	4.6	9.3	3.6	4.9	9.9	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	12.1	32.0	19.8	30.3	19.3	28.8	18.9	21.5	27.8	20.7	27.1	20.0	26.4	N/A	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.7	14.5	23.6	18.7	13.5	23.0	17.8	12.8	22.5	62.4	27.3	59.8	27.5	57.3	26.4	25.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
N/A	N/A	N/A	DB	2.4	35.3	0.8	0.7	1.8	35.8	1.3	36.2	0.8	36.6	0.2	37.1
			WB	2.1	23.1	1.0	1.2	1.4	24.0	0.8	24.7	0.2	25.3	-0.6	26.2

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	16.4	21.3	21.8	20.0	16.9	15.3	13.1	12.4	12.5	13.0	14.7	17.5	19.2
	DBStd	4.13	2.50	2.91	2.96	2.29	2.13	1.97	2.00	2.01	1.88	2.32	2.73	3.17
	HDD10.0	7	0	0	0	0	0	1	3	2	1	0	0	0
	HDD18.3	1050	4	3	17	54	98	157	186	181	159	115	48	27
	CDD10.0	2358	350	331	312	208	163	94	76	79	91	147	224	285
	CDD18.3	361	96	101	70	12	3	0	0	0	0	3	22	53
	CDH23.3	3084	845	901	567	69	4	0	0	0	2	24	183	489
CDH26.7	917	263	303	139	7	0	0	0	0	0	2	43	159	
Wind	WSAvg	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Precipitation	PrecAvg	791	8	10	20	42	112	166	164	116	76	44	26	12
	PrecMax	1148	70	64	100	163	245	309	330	231	148	123	81	71
	PrecMin	532	0	0	0	0	34	64	64	35	31	1	1	0
	PrecStd	133	14	16	25	34	54	62	59	44	30	26	19	16
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	33.4	34.6	32.6	27.5	23.6	20.2	18.8	19.2	21.7	26.3	30.4	33.7
		MCWB	19.3	21.2	19.6	18.5	16.9	15.5	15.2	16.0	15.2	17.5	18.1	19.2
	2%	DB	31.3	31.9	30.0	25.2	22.0	19.1	17.8	18.2	19.5	23.3	27.8	30.5
		MCWB	19.3	20.5	18.8	17.6	16.7	15.4	14.5	14.9	14.5	16.2	17.4	19.2
	5%	DB	29.5	30.0	28.0	23.6	20.9	18.5	17.2	17.5	18.4	21.3	25.2	28.2
		MCWB	19.4	19.8	18.8	17.3	16.4	14.9	14.1	14.2	14.1	15.5	17.0	18.5
	10%	DB	27.9	28.5	26.5	22.2	20.1	17.6	16.6	16.7	17.4	19.9	23.4	26.0
		MCWB	18.9	19.2	18.5	17.0	16.0	14.2	13.6	13.6	13.6	14.9	16.6	17.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	22.3	23.8	21.8	20.8	19.1	17.5	16.3	17.2	16.8	18.8	19.8	21.5
		MCDB	27.7	29.9	27.0	23.1	21.2	18.9	17.7	18.3	19.5	22.2	24.5	28.1
	2%	WB	21.0	21.9	20.8	19.6	18.2	16.5	15.6	16.0	15.6	17.6	18.9	20.2
		MCDB	28.1	28.9	26.0	22.3	20.6	18.2	17.2	17.5	18.2	21.2	23.4	27.9
	5%	WB	20.1	20.9	20.1	18.7	17.4	15.6	14.7	15.0	14.8	16.4	18.1	19.1
		MCDB	27.4	28.3	26.0	22.1	20.0	17.7	16.6	16.8	17.5	20.4	23.5	26.8
	10%	WB	19.2	20.0	19.1	17.5	16.5	14.8	14.1	14.1	14.1	15.4	17.2	18.1
		MCDB	26.7	26.8	24.9	21.7	19.4	17.1	16.2	16.4	16.8	19.3	23.0	25.1
Mean Daily Temperature Range	5% DB	MDBR	13.1	12.1	11.6	10.4	9.4	8.5	7.9	8.2	8.8	9.9	10.7	11.8
		MCDBR	15.2	13.9	13.1	12.2	10.5	9.0	7.8	8.2	10.1	12.4	13.5	14.9
		MCWBR	6.2	5.4	5.6	6.4	6.4	5.9	5.5	5.5	6.2	6.7	6.1	6.2
	5% WB	MCDBR	13.3	11.7	11.0	9.7	8.8	7.5	6.7	7.4	8.8	10.0	10.8	13.4
		MCWBR	6.4	5.4	6.2	6.3	6.7	6.1	5.5	5.7	6.3	6.0	5.9	6.1
Clear-Sky Solar Irradiance	taub	0.334	0.334	0.323	0.317	0.312	0.308	0.305	0.314	0.329	0.327	0.333	0.327	
	taud	2.592	2.603	2.633	2.643	2.625	2.615	2.627	2.587	2.525	2.546	2.552	2.592	
	Ebn at Noon	1003	983	960	912	862	838	862	900	937	979	998	1014	
	Edh at Noon	104	99	90	80	72	68	70	82	98	104	108	105	
All-Sky Solar Radiation	RadAvg	7.86	7.00	5.61	3.99	2.89	2.32	2.48	3.31	4.45	5.91	7.13	7.86	
	RadStd	0.40	0.29	0.29	0.24	0.20	0.15	0.13	0.20	0.25	0.30	0.41	0.39	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (22 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page