

SHANNON, Australia

WMO: 956170

Lat: 34.5683S

Lon: 116.3367E

Elev: 689

StdP: 14.33

Time Zone: 8.00 (E08)

Period: 98-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	38.5	40.3	36.3	32.2	44.4	38.0	34.4	46.2	19.1	54.3	18.0	55.3	3.0	0	0.491

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	20.8	88.9	66.5	84.8	65.7	81.0	64.8	69.3	82.0	67.7	79.3	66.3	76.9	9.6	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
65.8	97.8	70.8	64.4	92.9	69.8	63.0	88.4	68.8	33.8	82.1	32.4	79.4	31.3	77.0	81.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
17.5	15.8	14.3	DB	34.3	98.6	1.8	2.6	33.0	100.5	32.0	102.0	31.0	103.5	29.7	105.4
			WB	34.2	73.2	2.2	2.3	32.6	74.9	31.4	76.2	30.1	77.5	28.6	79.1

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	58.2	65.6	66.6	64.5	60.2	56.0	52.6	50.9	51.4	52.4	55.5	60.1	62.8	(6)
	DBStd	7.42	5.47	5.88	6.16	5.29	4.24	3.36	3.31	3.65	4.00	4.78	5.93	5.95	(7)
	HDD50	94	0	0	0	1	2	12	29	25	19	5	1	0	(8)
	HDD65	2831	59	47	86	163	280	372	438	421	379	298	174	114	(9)
	CDD50	3075	483	466	448	307	189	90	56	69	91	175	303	398	(10)
	CDD65	335	77	92	69	20	2	0	0	0	3	25	47		(11)
	CDH74	2989	715	770	555	117	9	0	0	0	3	39	280	501	(12)
	CDH80	1024	252	273	200	19	0	0	0	0	4	91	185		(13)
(14) Wind	WSAvg	7.3	8.3	8.1	7.8	6.4	6.1	6.8	7.0	7.1	7.3	7.3	7.7	7.9	(14)
(15) Precipitation	PrecAvg	41.8	0.7	0.8	1.5	2.7	4.9	6.3	7.4	5.9	4.6	2.9	2.0	1.1	(15)
	PrecMax	50.0	3.0	2.2	4.2	5.9	8.2	10.2	10.7	8.8	7.1	4.7	5.4	2.8	(16)
	PrecMin	32.5	0.2	0.0	0.2	0.3	2.8	3.0	3.1	2.0	1.5	1.5	0.4	0.2	(17)
	PrecStd	5.2	0.7	0.6	1.0	1.6	1.6	2.1	2.0	1.5	1.6	1.1	1.2	0.8	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	92.9	92.4	92.9	82.8	74.8	65.7	64.2	67.5	72.3	78.9	88.7	92.8	(19)
		MCWB	67.8	68.1	67.1	63.7	60.0	57.5	57.0	56.2	57.9	63.0	64.0	65.1	(20)
	2%	DB	86.4	87.2	85.6	77.3	69.5	63.2	61.1	63.5	66.5	72.7	81.9	84.9	(21)
		MCWB	66.6	67.2	66.3	62.7	59.4	56.5	55.3	56.2	57.2	60.9	63.8	65.4	(22)
	5%	DB	81.9	83.0	79.9	73.0	66.3	61.1	59.1	60.6	63.1	68.2	76.1	79.2	(23)
		MCWB	65.1	65.7	65.0	61.4	58.8	55.9	54.5	54.9	55.8	59.1	62.2	63.9	(24)
	10%	DB	77.1	78.4	75.2	69.2	63.7	59.3	57.3	58.3	60.2	64.4	71.0	74.3	(25)
		MCWB	63.8	65.1	63.2	60.4	57.9	55.0	53.4	53.7	54.7	57.2	60.8	62.3	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	70.8	73.0	71.5	66.4	64.4	60.8	59.3	60.0	61.1	65.5	67.9	69.4	(27)
		MCDB	83.9	83.1	83.1	74.9	69.1	63.5	61.5	63.2	66.6	74.6	81.7	84.2	(28)
	2%	WB	68.4	69.3	68.4	64.6	62.0	58.7	57.1	57.4	58.5	62.7	65.5	66.8	(29)
		MCDB	81.7	81.7	79.0	72.0	66.4	60.9	59.6	61.3	63.3	70.5	76.1	80.1	(30)
	5%	WB	66.5	67.5	66.5	63.0	60.4	57.2	55.5	55.7	56.7	60.3	63.5	64.9	(31)
		MCDB	78.7	78.3	75.6	69.6	64.4	59.9	57.8	59.2	61.3	66.1	73.2	76.9	(32)
	10%	WB	64.9	65.9	64.9	61.7	59.0	55.6	54.0	54.4	55.1	58.1	61.7	63.0	(33)
		MCDB	75.1	75.9	72.2	67.9	62.8	58.4	56.6	57.6	59.3	63.4	70.5	73.4	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	21.4	20.8	18.9	16.8	14.9	12.9	12.5	13.3	14.8	16.5	19.1	20.3	(35)
		MCDBR	30.2	28.9	26.8	22.6	18.8	16.1	15.5	17.0	20.2	24.0	28.3	29.7	(36)
		MCWBR	12.0	10.4	10.0	9.9	10.1	10.6	10.1	10.0	11.2	12.9	12.3	11.7	(37)
	5% WB	MCDBR	25.8	24.9	21.9	18.6	14.9	12.6	12.1	14.1	17.1	21.6	24.1	26.0	(38)
		MCWBR	11.4	10.5	9.4	9.5	9.6	9.8	9.1	9.5	10.9	12.3	11.8	11.3	(39)
(40) Clear-Sky Solar Irradiance	taub		0.328	0.327	0.317	0.310	0.305	0.300	0.298	0.305	0.329	0.322	0.327	0.322	(40)
	taud		2.594	2.608	2.632	2.647	2.627	2.620	2.624	2.596	2.501	2.545	2.557	2.595	(41)
	Ebn at Noon		320	314	305	291	274	267	274	287	296	312	318	323	(42)
	Edh at Noon		33	31	28	25	22	21	22	26	32	33	34	33	(43)
(44) All-Sky Solar Radiation	RadAvg		2371	2078	1645	1179	865	704	763	1007	1349	1749	2108	2344	(44)
	RadStd		155	103	114	71	62	45	33	52	64	115	131	134	(45)

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (13 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	-142	N/A	N/A	

Nomenclature: See separate page