

DALWALLINU, Australia

WMO: 956290

Lat: 30.276S

Lon: 116.671E

Elev: 1068

StdP: 14.14

Time Zone: 8.00 (E08)

Period: 98-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	37.9	39.9	20.5	16.0	76.6	23.9	18.8	75.2	24.2	59.8	21.1	59.2	6.0	160	0.549

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	27.4	102.2	65.5	99.3	65.3	96.3	64.7	72.0	85.8	70.1	85.9	68.3	85.5	11.5	340

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
68.6	109.4	76.4	65.7	98.8	74.0	63.4	90.8	72.9	36.5	85.7	34.7	84.5	33.2	85.2	78.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 24.2	21.8	19.9	DB	34.2	108.9	1.7	2.6	33.0	110.7	32.0	112.3	31.1	113.7	29.8	115.6	(4)
(5)			WB	32.2	74.5	1.9	2.6	30.9	76.4	29.8	77.9	28.7	79.4	27.4	81.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	65.7	79.3	78.9	74.6	67.9	60.2	54.9	52.7	53.7	57.0	63.9	71.0	75.7	(6)
(7)		DBStd	11.15	6.25	6.01	6.38	5.80	4.93	3.95	3.82	4.23	5.23	6.14	6.85	7.12	(7)
(8)		HDD50	38	0	0	0	0	0	6	18	10	4	0	0	0	(8)
(9)		HDD65	1610	1	1	5	33	165	305	381	351	248	95	21	4	(9)
(10)		CDD50	5780	908	808	763	538	315	151	103	124	213	432	629	796	(10)
(11)		CDD65	1875	443	389	303	121	15	0	0	0	7	62	200	335	(11)
(12)		CDH74	22957	5666	4748	3345	1127	158	5	0	16	167	946	2511	4268	(12)
(13)		CDH80	11937	3288	2632	1633	381	25	0	0	2	39	341	1236	2360	(13)
(14)	Wind	WSAvg	10.6	13.4	12.9	12.3	10.1	8.7	8.7	8.4	8.4	9.4	10.7	11.8	12.7	(14)
(15)	Precipitation	PrecAvg	14.0	0.6	0.6	0.8	0.9	2.0	2.4	2.3	1.8	1.0	0.7	0.5	0.5	(15)
(16)		PrecMax	26.5	5.3	3.1	7.9	5.0	5.8	7.3	4.6	4.8	2.6	2.9	2.0	2.4	(16)
(17)		PrecMin	7.8	0.0	0.0	0.0	0.0	0.0	0.2	0.7	0.4	0.1	0.0	0.0	0.0	(17)
(18)		PrecStd	3.8	1.0	0.7	1.5	0.9	1.4	1.4	1.1	0.9	0.6	0.6	0.5	0.6	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	106.8	104.9	101.0	93.0	83.4	73.7	70.7	75.8	84.6	93.6	100.6	105.1	(19)
(20)			MCWB	66.1	66.9	64.2	61.8	59.2	55.3	54.6	56.1	58.2	61.0	63.1	65.2	(20)
(21)		2%	DB	102.5	100.4	97.0	88.4	78.3	69.8	66.4	70.6	78.7	88.1	95.7	100.6	(21)
(22)			MCWB	66.1	66.1	64.4	61.3	57.2	53.8	54.1	54.7	56.6	59.4	61.6	64.6	(22)
(23)		5%	DB	98.9	97.2	93.2	84.3	74.5	66.7	63.5	66.7	73.7	83.4	91.8	96.8	(23)
(24)			MCWB	66.0	66.0	64.9	61.0	56.5	54.0	53.9	54.6	56.2	58.7	60.7	64.1	(24)
(25)		10%	DB	95.2	93.9	89.1	80.6	70.9	63.9	61.0	63.4	69.1	79.1	87.7	92.5	(25)
(26)			MCWB	65.3	65.5	63.9	60.3	56.0	53.7	53.6	53.9	55.1	57.4	59.9	62.9	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	74.7	73.9	71.7	67.5	64.2	61.3	60.9	61.5	61.8	64.1	66.6	70.2	(27)
(28)			MCD B	85.5	85.0	80.9	79.2	69.9	65.6	62.9	64.9	73.5	80.8	85.7	88.6	(28)
(29)		2%	WB	72.4	71.9	69.2	65.6	62.0	59.2	58.2	58.9	59.8	62.2	65.0	67.7	(29)
(30)			MCD B	86.7	85.8	82.1	77.2	68.2	63.4	61.4	65.2	71.0	78.8	84.9	88.8	(30)
(31)		5%	WB	70.4	70.0	67.6	64.2	60.3	57.6	56.3	57.1	58.1	60.8	63.5	66.1	(31)
(32)			MCD B	86.6	86.5	82.3	75.8	67.7	62.1	60.0	62.7	68.5	76.8	83.3	88.4	(32)
(33)		10%	WB	68.3	68.2	66.2	62.8	58.8	55.8	54.7	55.4	56.5	59.3	62.0	64.6	(33)
(34)			MCD B	86.5	86.1	82.5	75.0	66.1	60.8	58.7	61.3	66.0	74.4	81.2	87.8	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	27.4	26.2	24.3	22.7	20.5	18.5	17.1	19.4	23.3	27.1	27.4	27.8	(35)
(36)			MCDBR	32.2	30.4	29.1	27.3	26.1	23.2	21.2	25.6	31.5	33.8	32.9	32.2	(36)
(37)			MCWBR	9.4	8.7	9.0	9.6	10.7	11.5	11.8	13.0	12.7	11.3	10.0	10.0	(37)
(38)		5% WB	MCDBR	24.3	24.4	23.0	21.7	17.8	16.4	15.4	19.7	24.4	27.9	28.5	28.7	(38)
(39)			MCWBR	8.5	8.6	8.5	8.5	9.2	10.3	10.5	11.9	11.5	10.0	9.0	9.2	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.329	0.335	0.317	0.305	0.290	0.280	0.279	0.285	0.304	0.312	0.316	0.319	(40)	
(41)		taud	2.535	2.533	2.567	2.581	2.591	2.612	2.618	2.592	2.515	2.510	2.520	2.528	(41)	
(42)		Ebn at Noon	321	313	309	297	287	283	288	300	308	317	323	325	(42)	
(43)		Edh at Noon	35	34	31	28	24	23	23	27	32	35	36	36	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2587	2341	1980	1514	1170	985	1037	1318	1734	2180	2510	2682	(44)	
(45)		RadStd	151	118	122	77	78	66	59	51	79	112	106	129	(45)	

Historical Trends

		Heating		Cooling		Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (11 neighbors)	N/A	N/A	N/A	+1.17	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page