

DALWALLINU, Australia

WMO: 956290

Lat: 30.276S

Lon: 116.671E

Elev: 326

StdP: 97.48

Time Zone: 8.00 (E08)

Period: 98-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 7	(b) 3.3	(c) 4.4	(d) -6.4	(e) 2.3	(f) 24.8	(g) -4.5	(h) 2.7	(i) 24.0	(j) 10.8	(k) 15.5	(l) 9.4	(m) 15.1	(n) 2.7	(o) 160	(p) 0.549

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 1	(b) 15.2	(c) 39.0	(d) 18.6	(e) 37.4	(f) 18.5	(g) 35.7	(h) 18.2	(i) 22.2	(j) 29.9	(k) 21.2	(l) 29.9	(m) 20.2	(n) 29.7	(o) 5.2	(p) 340

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.3	15.6	24.6	18.7	14.1	23.4	17.4	13.0	22.7	66.9	29.9	62.9	29.2	59.3	29.5	26.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10.8	9.7	8.9	1.2	42.7	0.9	1.4	0.6	43.7	0.0	44.6	-0.5	45.4	-1.2	46.4
			0.1	23.6	1.0	1.4	-0.6	24.7	-1.2	25.5	-1.8	26.3	-2.6	27.4
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	18.7	26.3	26.0	23.7	20.0	15.6	12.7	11.5	12.0	13.9	17.7	21.6	24.3
	DBStd	6.19	3.47	3.34	3.55	3.22	2.74	2.19	2.12	2.35	2.91	3.41	3.81	3.96
	HDD10.0	21	0	0	0	0	0	3	10	6	2	0	0	0
	HDD18.3	894	1	1	3	18	92	169	212	195	138	53	12	2
	CDD10.0	3211	504	449	424	299	175	84	57	69	118	240	349	442
	CDD18.3	1042	246	216	168	67	8	0	0	0	4	34	111	186
	CDH23.3	12754	3148	2638	1858	626	88	3	0	9	93	526	1395	2371
	CDH26.7	6632	1827	1462	907	212	14	0	0	1	22	189	687	1311
(14) Wind	WSAvg	4.7	6.0	5.8	5.5	4.5	3.9	3.9	3.7	3.8	4.2	4.8	5.3	5.7
(15) Precipitation	PrecAvg	356	15	15	21	23	51	62	59	45	25	17	13	12
	PrecMax	672	135	79	200	126	147	185	116	123	67	74	52	60
	PrecMin	199	0	0	0	0	1	6	19	10	3	0	0	0
	PrecStd	97	25	19	39	24	35	35	27	24	14	15	13	15
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	41.5	40.5	38.4	33.9	28.6	23.2	21.5	24.4	29.2	34.2	38.1	40.6
		MCWB	19.0	19.4	17.9	16.5	15.1	12.9	12.6	13.4	14.6	16.1	17.3	18.5
	2%	DB	39.2	38.0	36.1	31.3	25.7	21.0	19.1	21.5	26.0	31.2	35.4	38.1
		MCWB	19.0	19.0	18.0	16.3	14.0	12.1	12.3	12.6	13.6	15.2	16.4	18.1
	5%	DB	37.2	36.2	34.0	29.1	23.6	19.3	17.5	19.3	23.1	28.5	33.2	36.0
		MCWB	18.9	18.9	18.3	16.1	13.6	12.2	12.2	12.6	13.5	14.8	15.9	17.9
	10%	DB	35.1	34.4	31.7	27.0	21.6	17.7	16.1	17.4	20.6	26.2	30.9	33.6
		MCWB	18.5	18.6	17.7	15.7	13.3	12.0	12.0	12.2	12.8	14.1	15.5	17.2
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	23.7	23.3	22.0	19.7	17.9	16.3	16.1	16.4	16.5	17.9	19.2	21.2
		MCDB	29.7	29.4	27.2	26.2	21.1	18.7	17.2	18.3	23.1	27.1	29.8	31.4
	2%	WB	22.4	22.2	20.7	18.7	16.7	15.1	14.6	15.0	15.4	16.8	18.3	19.8
		MCDB	30.4	29.9	27.9	25.1	20.1	17.4	16.4	18.4	21.6	26.0	29.4	31.5
	5%	WB	21.4	21.1	19.8	17.9	15.7	14.2	13.5	14.0	14.5	16.0	17.5	18.9
		MCDB	30.3	30.3	27.9	24.3	19.8	16.7	15.6	17.1	20.3	24.9	28.5	31.3
	10%	WB	20.2	20.1	19.0	17.1	14.9	13.2	12.6	13.0	13.6	15.2	16.6	18.1
		MCDB	30.3	30.1	28.0	23.9	19.0	16.0	14.9	16.3	18.9	23.6	27.3	31.0
(35) Mean Daily Temperature Range	5% DB	MDBR	15.2	14.6	13.5	12.6	11.4	10.3	9.5	10.8	12.9	15.0	15.2	15.5
		MCDBR	17.9	16.9	16.2	15.1	14.5	12.9	11.8	14.2	17.5	18.8	18.3	17.9
		MCWBR	5.2	4.8	5.0	5.3	5.9	6.4	6.5	7.2	7.0	6.3	5.6	5.6
	5% WB	MCDBR	13.5	13.6	12.8	12.0	9.9	9.1	8.5	10.9	13.6	15.5	15.8	15.9
		MCWBR	4.7	4.8	4.7	4.7	5.1	5.7	5.8	6.6	6.4	5.5	5.0	5.1
(40) Clear-Sky Solar Irradiance	taub		0.329	0.335	0.317	0.305	0.290	0.280	0.279	0.285	0.304	0.312	0.316	0.319
	taud		2.535	2.533	2.567	2.581	2.591	2.612	2.618	2.592	2.515	2.510	2.520	2.528
	Ebn at Noon		1011	987	973	936	904	891	909	945	971	999	1018	1024
	Edh at Noon		111	108	98	87	77	71	74	84	101	109	112	112
(44) All-Sky Solar Radiation	RadAvg		8.15	7.38	6.24	4.77	3.69	3.10	3.27	4.15	5.47	6.87	7.91	8.46
	RadStd		0.47	0.37	0.39	0.24	0.25	0.21	0.18	0.16	0.25	0.35	0.33	0.41

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (11 neighbors)	N/A	N/A	N/A	+0.65	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page