

BRIDGETOWN, Australia

WMO: 956320

Lat: 33.949S

Lon: 116.131E

Elev: 587

StdP: 14.39

Time Zone: 8.00 (E08)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	32.5	34.6	30.7	25.4	43.3	33.0	28.1	43.1	17.2	60.7	15.2	60.0	0.0	150	0.435

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	26.8	94.6	66.3	91.0	65.7	87.3	64.9	71.0	84.1	68.9	82.5	67.3	80.9	6.7	330

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
67.4	102.8	75.0	65.1	94.8	72.2	63.1	88.4	70.4	35.3	84.8	33.4	82.1	32.1	81.2	88.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.3	13.7	11.8	DB	29.2	101.3	1.1	2.5	28.4	103.1	27.8	104.6	27.1	106.0	26.3	107.9	(4)
(5)			WB	28.7	75.8	1.9	3.4	27.3	78.3	26.1	80.2	25.0	82.1	23.6	84.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	59.3	70.0	70.4	66.8	60.6	55.0	51.4	50.0	51.0	52.4	56.4	62.2	65.8	(6)	
	DBStd	8.95	5.99	6.14	6.34	5.29	4.19	3.97	3.90	3.87	4.32	5.06	6.00	6.33	(7)	
	HDD50	147	0	0	0	0	7	28	48	35	24	5	0	0	(8)	
	HDD65	2709	21	21	55	153	310	409	464	435	378	271	124	68	(9)	
	CDD50	3532	621	571	522	318	162	69	49	64	96	203	366	491	(10)	
	CDD65	621	177	172	112	21	1	0	0	0	0	4	40	94	(11)	
	CDH74	7562	2098	1875	1219	271	19	0	0	0	12	102	602	1364	(12)	
	CDH80	3174	953	831	478	64	1	0	0	0	1	18	210	618	(13)	
(14) Wind	WSAvg	4.4	6.1	5.9	5.0	3.4	2.9	3.1	3.3	3.5	4.0	4.4	5.3	5.5	(14)	
(15) Precipitation	PrecAvg	30.7	0.6	0.6	1.0	1.9	4.1	5.4	5.6	4.4	3.2	2.0	1.4	0.7	(15)	
	PrecMax	42.7	4.3	3.3	4.8	6.9	8.9	11.7	11.5	7.9	6.5	5.2	5.4	3.1	(16)	
	PrecMin	21.5	0.0	0.0	0.0	0.0	1.3	1.9	2.4	1.5	1.0	0.1	0.2	0.0	(17)	
	PrecStd	5.4	0.9	0.8	1.1	1.5	1.8	2.0	2.1	1.6	1.3	1.0	1.0	0.7	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	98.8	98.0	96.2	86.2	76.9	68.1	65.7	69.2	75.1	82.4	92.7	98.3	(19)	
		MCWB	67.3	68.9	65.5	63.0	58.7	55.4	56.8	57.5	60.1	62.9	64.3	65.7	(20)	
	2%	DB	93.6	93.2	90.0	81.1	71.8	65.1	62.9	65.1	69.2	76.6	86.2	92.5	(21)	
		MCWB	65.9	67.0	66.1	62.1	58.8	56.8	56.2	56.9	58.2	62.7	63.2	65.4	(22)	
	5%	DB	89.5	89.2	85.1	76.5	68.1	62.7	60.8	62.3	65.2	72.1	80.9	86.8	(23)	
		MCWB	65.9	65.8	64.8	61.4	58.9	56.3	55.4	55.8	56.9	60.3	62.4	64.0	(24)	
	10%	DB	85.5	85.1	80.7	72.4	65.3	60.5	58.8	60.0	62.2	68.0	76.2	81.7	(25)	
		MCWB	64.8	65.0	63.3	60.8	58.1	55.4	54.7	54.8	56.0	58.4	60.8	62.4	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	74.7	74.6	72.0	67.9	65.6	62.0	60.6	61.8	62.3	66.6	68.4	70.2	(27)	
		MCDB	88.9	89.5	85.2	76.5	69.4	63.5	62.6	64.1	68.3	76.9	82.5	86.6	(28)	
	2%	WB	70.9	70.9	68.7	65.7	62.6	59.6	58.3	59.1	60.2	63.4	65.7	67.6	(29)	
		MCDB	83.3	84.2	80.9	72.5	66.3	62.1	60.6	61.9	65.6	73.2	79.2	84.9	(30)	
	5%	WB	68.5	68.7	66.9	63.9	60.7	57.9	56.7	57.2	58.2	61.2	64.0	65.4	(31)	
		MCDB	82.8	82.8	78.2	71.3	65.2	60.7	59.6	60.6	63.6	69.6	76.0	81.8	(32)	
	10%	WB	66.3	66.7	65.1	62.4	59.1	56.2	54.9	55.5	56.4	59.3	62.4	63.4	(33)	
		MCDB	80.7	80.5	75.5	69.5	63.4	59.0	58.0	59.2	61.0	66.1	73.8	78.0	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	27.9	26.8	25.7	23.4	21.8	19.3	18.1	18.8	19.9	22.3	25.1	27.3	(35)	
		MCDBR	34.6	33.2	32.0	30.4	27.4	22.5	20.5	22.9	25.4	29.6	33.5	36.5	(36)	
	5% WB	MCWBR	12.6	11.7	12.3	14.1	16.4	15.4	14.6	15.2	15.4	16.2	14.5	13.3	(37)	
		MCWBR	28.7	28.1	26.2	23.2	20.7	18.3	17.3	18.9	21.4	25.3	27.9	31.6	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.328	0.327	0.316	0.308	0.302	0.301	0.296	0.306	0.326	0.324	0.326	0.323	(40)	
		taud	2.581	2.593	2.622	2.636	2.624	2.605	2.618	2.572	2.491	2.518	2.545	2.575	(41)	
	Ebn at Noon		320	314	306	292	277	268	276	288	298	311	319	323	(42)	
		Edh at Noon	33	32	29	25	23	22	22	26	32	34	34	34	(43)	
(44) All-Sky Solar Radiation	RadAvg		2462	2179	1739	1237	903	735	790	1038	1393	1816	2204	2452	(44)	
	RadStd		146	95	105	78	65	46	38	56	72	107	138	137	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (17 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	-142	N/A	N/A

Nomenclature: See separate page