

SOUTHERN CROSS AP, Australia

WMO: 956340

Lat: 31.2353S

Lon: 119.3564E

Elev: 348

StdP: 97.21

Time Zone: 8.00 (E08)

Period: 98-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	-0.3	0.9	-8.0	2.0	25.1	-5.8	2.4	23.1	11.7	15.4	10.6	14.8	0.8	200	0.554

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	15.5	39.4	18.3	37.6	18.1	35.8	17.8	22.0	29.8	20.9	29.7	19.9	29.6	5.8	350

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
20.2	15.5	24.2	18.3	13.8	23.4	17.0	12.6	22.5	66.4	29.7	62.1	29.9	58.4	29.6	25.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.9	9.7	8.8	-2.5	42.9	0.9	1.3	-3.2	43.9	-3.7	44.7	-4.2	45.4	-4.8	46.4		
(5)			-3.1	23.2	0.9	1.3	-3.7	24.1	-4.3	24.9	-4.8	25.6	-5.4	26.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	17.9	25.9	25.3	22.7	18.8	14.2	11.1	10.0	11.0	13.3	17.7	21.4	24.0	(6)
(7)		DBStd	6.58	3.77	3.54	3.78	3.37	3.03	2.53	2.44	2.75	3.30	3.81	4.00	3.96	(7)
(8)		HDD10.0	76	0	0	0	0	3	16	31	21	6	0	0	0	(8)
(9)		HDD18.3	1108	1	1	7	34	133	217	258	229	154	58	14	3	(9)
(10)		CDD10.0	2961	492	429	392	263	133	49	31	50	105	239	343	433	(10)
(11)		CDD18.3	951	234	196	141	48	4	0	0	1	4	38	107	178	(11)
(12)		CDH23.3	12505	3128	2406	1617	539	67	3	0	21	136	657	1470	2462	(12)
(13)	CDH26.7	6499	1829	1322	777	180	10	0	0	3	37	254	723	1364	(13)	
(14)	Wind	WSAvg	4.5	5.6	5.3	5.0	4.0	3.5	3.5	3.6	3.7	4.3	4.7	5.2	5.4	(14)
(15)	Precipitation	PrecAvg	323	22	25	24	31	39	50	41	34	20	16	20	14	(15)
(16)		PrecMax	577	124	135	169	107	111	183	98	137	51	59	69	63	(16)
(17)		PrecMin	183	0	0	0	0	2	14	6	9	2	0	0	0	(17)
(18)		PrecStd	77	29	30	34	25	30	30	23	23	12	15	17	15	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	42.0	41.1	38.1	33.8	27.7	22.9	21.4	26.1	30.8	35.3	38.4	41.0	(19)
MCWB			18.6	18.9	17.5	16.1	14.8	12.4	11.9	12.7	14.2	15.6	17.1	18.0	(20)	
2%		DB	39.6	38.2	36.0	30.9	25.1	20.7	19.5	22.6	26.9	32.3	35.8	38.5	(21)	
		MCWB	18.8	18.9	17.8	16.2	13.9	11.9	11.3	12.3	13.0	15.1	16.5	17.7	(22)	
5%		DB	37.5	36.2	33.5	28.6	23.0	18.9	17.7	20.2	24.2	29.5	33.6	36.1	(23)	
		MCWB	18.4	18.6	17.7	15.9	13.5	11.5	11.0	11.5	12.7	14.6	16.0	17.5	(24)	
10%		DB	35.3	34.0	31.1	26.4	21.2	17.2	16.1	18.1	21.8	27.1	30.9	33.8	(25)	
		MCWB	18.1	18.5	17.4	15.5	13.2	11.3	10.8	11.2	12.1	14.1	15.2	16.9	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	23.3	23.9	21.1	19.2	17.4	15.5	14.6	15.2	16.0	18.1	19.6	21.2	(27)
MCD B			29.7	29.8	27.7	26.0	21.8	18.1	17.1	19.8	25.0	27.7	29.7	31.0	(28)	
2%		WB	22.0	22.4	20.0	18.1	16.2	14.2	13.2	13.9	14.7	16.7	18.3	19.9	(29)	
		MCD B	30.1	29.4	28.2	25.3	20.5	17.2	16.0	18.6	23.2	26.8	29.1	30.9	(30)	
5%		WB	21.0	21.1	19.2	17.2	15.3	13.2	12.3	12.9	13.8	15.7	17.5	18.8	(31)	
		MCD B	30.4	29.3	27.9	24.6	20.0	16.3	15.5	17.7	21.4	26.3	28.9	31.0	(32)	
10%		WB	19.9	19.9	18.4	16.4	14.3	12.2	11.4	11.8	12.8	14.8	16.6	18.0	(33)	
		MCD B	30.5	29.2	27.3	23.8	19.0	15.7	14.8	16.8	20.1	24.9	28.0	30.5	(34)	
(35)	Mean Daily Temperature Range	5% DB	MDBR	15.5	14.6	13.8	13.7	13.1	12.4	12.0	13.7	15.4	15.8	15.6	16.0	(35)
MCDBR			18.6	17.6	16.8	16.5	16.1	15.4	15.1	18.0	19.8	19.4	18.6	18.6	(36)	
MCWBR			5.5	5.4	5.4	6.4	7.6	8.4	8.6	9.5	8.9	7.2	6.0	5.7	(37)	
5% WB		MCD BR	14.6	13.8	13.6	13.0	11.4	11.2	11.0	13.8	16.5	16.0	15.9	16.2	(38)	
		MCWBR	5.3	5.3	5.1	5.7	6.0	7.1	7.2	8.1	7.9	6.3	5.4	5.5	(39)	
(40)	Clear-Sky Solar Irradiance	taub		0.332	0.333	0.315	0.302	0.286	0.279	0.276	0.284	0.300	0.314	0.318	0.319	(40)
taud		2.570	2.588	2.619	2.634	2.653	2.649	2.659	2.621	2.559	2.534	2.547	2.570	(41)		
Ebn at Noon		1008	988	974	937	907	890	910	944	974	996	1015	1024	(42)		
Edh at Noon		107	102	92	82	72	68	70	81	96	106	109	107	(43)		
(44)	All-Sky Solar Radiation	RadAvg		7.96	7.08	6.08	4.63	3.52	2.92	3.10	4.08	5.44	6.79	7.74	8.32	(44)
(45)		RadStd		0.48	0.47	0.36	0.24	0.23	0.17	0.17	0.21	0.27	0.39	0.38	0.42	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page