

SALMON GUMS, Australia

WMO: 956390

Lat: 32.9869S

Lon: 121.6239E

Elev: 817

StdP: 14.27

Time Zone: 8.00 (E08)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	31.8	34.4	24.6	19.2	63.1	27.2	21.8	60.7	22.2	61.2	20.2	60.3	2.4	310	0.537

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	27.7	98.8	65.3	94.5	64.0	90.5	63.3	69.5	86.2	67.5	83.7	66.2	81.5	11.2	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.0	95.5	72.8	63.3	89.7	70.1	61.8	85.1	69.1	34.0	86.8	32.4	83.7	31.3	82.0	78.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 25.6	20.9	18.3	26.1	107.3	1.8	2.9	24.8	109.3	23.8	111.0	22.7	112.6	21.4	114.7		
(5)			25.8	73.2	2.5	2.1	24.0	74.7	22.5	75.9	21.1	77.1	19.3	78.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	61.1	71.7	71.3	67.7	62.6	56.1	52.2	50.9	52.0	54.9	60.4	65.0	68.4
	DBStd	9.68	6.49	6.61	7.00	6.37	5.67	4.53	4.53	5.29	6.14	6.96	7.30	7.20
	HDD50	131	0	0	0	0	8	25	44	34	18	2	0	0
	HDD65	2328	12	16	51	121	283	384	438	404	308	179	90	42
	CDD50	4167	673	596	547	379	198	91	71	97	166	326	451	572
	CDD65	889	220	192	133	50	7	0	0	2	7	38	91	149
	CDH74	10922	2629	2079	1455	473	72	2	0	43	166	669	1296	2038
	CDH80	5053	1350	994	641	135	11	0	0	8	46	249	585	1034
Wind	WSAvg	9.1	11.3	10.9	9.3	7.7	7.3	7.6	7.8	8.0	8.5	9.4	10.5	10.6
Precipitation	PrecAvg	14.5	1.5	0.9	1.5	1.0	1.2	1.3	1.5	1.4	1.1	1.1	1.1	0.9
	PrecMax	24.4	6.7	4.1	6.2	3.1	3.0	2.5	2.7	4.7	2.7	3.2	3.1	3.8
	PrecMin	7.7	0.0	0.0	0.2	0.0	0.3	0.4	0.3	0.4	0.1	0.2	0.0	0.1
	PrecStd	3.5	1.9	1.0	1.4	0.8	0.7	0.6	0.6	0.8	0.7	0.8	0.8	0.8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	104.7	102.4	98.8	89.1	81.3	72.0	70.8	79.6	85.8	92.5	98.4	102.9
		MCWB	67.3	67.2	64.2	62.3	59.6	54.9	52.7	55.8	57.6	60.2	63.9	64.6
	2%	DB	97.9	95.4	92.6	84.2	75.1	67.9	66.7	72.6	78.4	87.0	92.2	96.7
		MCWB	65.4	66.1	64.2	62.1	56.9	54.0	52.3	53.7	56.9	59.5	61.4	64.1
	5%	DB	92.6	90.8	86.9	79.3	71.5	64.9	63.7	67.8	73.4	81.7	86.6	91.1
		MCWB	64.2	64.8	63.2	60.5	56.7	53.3	51.9	53.0	55.0	58.5	60.7	63.1
	10%	DB	87.6	86.2	82.0	75.3	68.1	62.1	61.0	63.9	68.9	76.4	81.4	85.4
		MCWB	64.3	64.5	62.5	59.7	55.7	52.0	51.3	51.9	53.8	57.2	59.5	61.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	72.1	73.8	68.5	66.5	64.6	59.4	57.0	58.6	60.3	64.4	66.9	69.6
		MCDB	90.0	88.6	82.7	79.2	71.5	65.1	64.1	68.9	77.4	81.4	85.0	88.7
	2%	WB	69.4	69.9	67.0	64.4	61.7	57.0	55.1	56.4	58.3	61.5	64.7	66.4
		MCDB	87.5	85.3	81.5	74.7	68.3	63.4	61.8	66.0	72.9	78.6	81.3	85.5
	5%	WB	67.3	67.5	65.6	62.8	59.1	55.3	53.5	54.6	56.6	59.8	63.0	64.5
		MCDB	83.8	83.4	79.3	72.0	67.2	61.0	60.4	64.0	68.6	76.3	79.5	85.1
	10%	WB	65.6	65.9	64.2	61.4	57.2	53.6	52.1	53.0	55.1	58.3	61.2	62.9
		MCDB	81.0	80.4	76.1	70.9	65.0	60.3	58.9	62.1	67.0	73.2	77.2	81.0
Mean Daily Temperature Range	5% DB	MDBR	27.7	26.1	24.9	24.0	22.7	19.8	19.7	22.4	26.0	27.4	27.8	28.6
		MCDBR	36.7	33.7	32.2	28.9	26.7	23.5	23.9	29.3	33.6	35.5	35.9	37.4
		MCWBR	10.4	9.6	9.7	11.3	13.2	13.4	13.1	14.5	14.7	13.1	11.1	10.8
	5% WB	MCDBR	28.6	27.5	24.5	21.9	20.8	18.3	19.2	23.4	28.1	29.9	30.1	31.9
		MCWBR	10.3	9.7	9.0	9.8	12.1	12.0	12.0	13.3	13.6	12.2	10.7	10.6
Clear-Sky Solar Irradiance	taub	0.343	0.340	0.320	0.310	0.294	0.283	0.283	0.292	0.309	0.322	0.328	0.329	
	taud	2.540	2.561	2.600	2.618	2.636	2.642	2.639	2.599	2.537	2.522	2.528	2.553	
	Ebn at Noon	316	310	306	292	282	277	283	294	305	312	318	321	
	Edh at Noon	35	33	30	26	23	21	22	26	31	34	35	35	
All-Sky Solar Radiation	RadAvg	2383	2092	1730	1306	978	836	904	1189	1593	1963	2246	2467	
	RadStd	136	148	112	71	58	36	48	60	63	125	147	153	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (6 neighbors)	+0.41	N/A	N/A	N/A	N/A	N/A	N/A	-108	+167	+79

Nomenclature: See separate page