

WANDERING, Australia

WMO: 956400

Lat: 32.6724S

Lon: 116.6700E

Elev: 276

StdP: 98.06

Time Zone: 8.00 (E08)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	-0.5	0.7	-2.6	3.1	14.2	-1.4	3.5	11.0	8.2	14.8	7.4	15.2	1.1	330	0.474

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	16.0	36.8	18.5	34.8	18.2	33.0	17.8	21.0	30.4	19.9	29.8	19.1	28.9	4.0	350

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.5	13.8	22.9	17.1	12.6	22.4	16.1	11.8	21.5	61.8	30.3	58.1	29.3	55.4	28.8	26.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
9.2	7.7	6.7	-2.3	40.4	1.3	1.8	-3.2	41.7	-4.0	42.8	-4.7	43.8	-5.6	45.2		
			-2.6	22.7	1.4	1.7	-3.6	24.0	-4.4	25.0	-5.2	26.0	-6.2	27.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	15.8	23.0	22.8	20.5	16.6	12.7	10.6	9.6	10.0	11.1	14.1	18.5	21.0	(6)
(7)		DBStd	5.77	3.17	3.37	3.63	3.20	2.53	2.42	2.33	2.28	2.55	3.18	3.60	3.65	(7)
(8)		HDD10.0	111	0	0	0	0	6	21	36	29	17	3	0	0	(8)
(9)		HDD18.3	1444	3	6	20	71	176	233	270	258	217	136	42	13	(9)
(10)		CDD10.0	2239	403	357	325	198	89	38	24	29	50	131	254	342	(10)
(11)		CDD18.3	532	148	129	87	18	1	0	0	0	0	6	46	97	(11)
(12)		CDH23.3	6984	1889	1607	1043	239	14	0	0	1	12	133	718	1328	(12)
(13)		CDH26.7	3252	966	798	449	59	1	0	0	1	33	301	644	644	(13)
(14)	Wind	WSAvg	3.1	4.1	3.9	3.5	2.5	2.3	2.5	2.4	2.6	2.9	3.1	3.6	3.8	(14)
(15)	Precipitation	PrecAvg	563	15	16	18	35	69	102	106	83	53	34	20	12	(15)
(16)		PrecMax	795	156	67	94	100	147	246	222	144	107	130	52	84	(16)
(17)		PrecMin	362	0	0	0	0	13	18	39	20	17	1	0	0	(17)
(18)		PrecStd	98	30	19	21	28	36	47	46	31	23	23	14	16	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	DB	39.0	38.7	36.8	31.4	25.2	20.3	18.7	21.0	24.9	30.2	35.8	38.7	38.7	(19)
(20)		MCWB	19.3	19.2	18.1	16.6	14.0	12.3	13.0	13.5	14.7	16.6	17.0	18.3	18.3	(20)
(21)		DB	36.5	35.9	33.7	28.2	22.7	18.5	17.1	18.5	21.6	26.7	32.7	35.8	35.8	(21)
(22)		MCWB	18.6	18.9	18.2	16.2	13.4	12.5	12.2	12.9	14.3	15.9	16.3	18.1	18.1	(22)
(23)		DB	34.2	33.7	31.3	26.1	20.7	17.2	15.9	16.9	19.2	24.2	30.3	33.1	33.1	(23)
(24)		MCWB	18.4	18.7	17.8	15.6	13.5	12.4	12.0	12.6	13.4	15.0	16.0	17.2	17.2	(24)
(25)		DB	32.1	31.7	29.0	23.9	18.9	15.9	14.8	15.5	17.3	21.8	27.7	30.3	30.3	(25)
(26)		MCWB	17.8	18.2	17.2	15.2	13.2	11.9	11.6	11.9	12.6	14.1	15.2	16.4	16.4	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	WB	22.8	22.7	21.1	19.2	16.9	15.6	14.7	15.3	16.4	18.0	18.8	20.2	20.2	(27)
(28)		MCDWB	30.6	28.7	29.3	24.0	19.8	17.4	16.4	18.2	21.7	25.8	29.9	31.7	31.7	(28)
(29)		WB	21.1	21.0	20.0	18.1	15.9	14.4	13.5	14.1	15.2	16.7	17.8	19.1	19.1	(29)
(30)		MCDWB	29.6	31.6	27.6	23.7	19.0	16.6	15.4	17.0	19.9	24.4	27.7	31.1	31.1	(30)
(31)		WB	19.8	19.8	19.1	17.2	15.0	13.5	12.6	13.2	14.0	15.7	17.0	18.2	18.2	(31)
(32)		MCDWB	30.1	30.5	27.5	22.9	18.4	15.8	14.7	15.9	18.3	22.5	26.9	29.7	29.7	(32)
(33)		WB	18.7	18.9	18.2	16.3	14.1	12.6	11.9	12.4	13.0	14.7	16.1	17.2	17.2	(33)
(34)		MCDWB	29.0	29.1	26.0	21.9	17.5	14.8	14.2	14.9	16.8	20.8	25.4	28.3	28.3	(34)
(35)	Mean Daily Temperature Range	MDBR	16.0	15.6	14.7	13.7	13.0	11.2	10.6	11.1	12.5	14.3	15.5	15.5	15.5	(35)
(36)		5% DB	19.9	19.5	18.4	17.6	16.6	13.0	11.8	13.6	16.5	18.5	20.3	20.1	20.1	(36)
(37)		MCWBR	6.1	6.0	6.2	7.6	8.8	8.2	7.9	8.7	9.6	8.4	6.6	6.0	6.0	(37)
(38)		5% WB	15.7	16.2	14.1	12.4	10.9	10.1	9.9	11.2	13.9	15.6	16.9	17.4	17.4	(38)
(39)		MCWBR	5.7	5.7	5.3	6.1	7.0	7.2	7.1	7.7	8.4	7.8	6.2	5.9	5.9	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.329	0.326	0.313	0.304	0.295	0.290	0.288	0.295	0.316	0.318	0.319	0.317	0.317	(40)
(41)		taud	2.545	2.574	2.600	2.614	2.612	2.612	2.611	2.585	2.492	2.513	2.533	2.562	2.562	(41)
(42)		Ebn at Noon	1009	993	972	929	886	866	885	925	953	990	1012	1025	1025	(42)
(43)		Edh at Noon	109	102	93	82	73	69	72	83	102	108	110	108	108	(43)
(44)	All-Sky Solar Radiation	RadAvg	8.12	7.28	5.93	4.27	3.16	2.59	2.75	3.54	4.75	6.22	7.51	8.26	8.26	(44)
(45)		RadStd	0.43	0.28	0.30	0.28	0.22	0.16	0.17	0.19	0.27	0.33	0.41	0.43	0.43	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (22 neighbors)	N/A	N/A	N/A	+0.52	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page