

NORSEMAN AP, Australia

WMO: 956420

Lat: 32.2147S

Lon: 121.7547E

Elev: 263

StdP: 98.21

Time Zone: 8.00 (E08)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	-0.2	1.0	-4.0	2.8	15.7	-2.8	3.1	14.1	12.0	15.9	11.2	16.0	1.0	210	0.530

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	15.3	38.4	19.0	36.3	18.8	34.2	18.2	21.9	31.0	20.7	30.4	19.9	29.2	6.4	10

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.4	14.6	23.2	18.3	13.6	22.6	17.2	12.7	22.3	65.2	30.6	61.1	30.4	58.0	29.6	26.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.0	10.3	9.0	DB	-2.9	42.4	1.1	1.6	-3.7	43.5	-4.3	44.5	-4.9	45.4	-5.7	46.6	(4)
(5)			WB	-3.4	23.9	1.0	1.3	-4.2	24.8	-4.8	25.6	-5.4	26.3	-6.1	27.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	17.2	23.9	23.5	21.2	18.0	13.7	11.1	10.3	11.6	13.8	17.5	20.1	22.2	(6)
(7)		DBStd	5.91	3.63	3.72	3.79	3.54	3.06	2.56	2.47	3.00	3.52	3.87	4.05	4.06	(7)
(8)		HDD10.0	67	0	0	0	0	3	16	27	16	6	1	0	0	(8)
(9)		HDD18.3	1133	2	3	14	49	149	216	250	210	142	64	26	8	(9)
(10)		CDD10.0	2697	430	379	348	239	117	50	36	65	119	232	304	379	(10)
(11)		CDD18.3	722	173	149	104	38	4	0	0	1	6	37	80	129	(11)
(12)		CDH23.3	8956	2123	1721	1139	374	52	2	1	37	153	564	1061	1730	(12)
(13)	CDH26.7	4355	1147	884	520	114	9	0	0	8	44	223	489	916	(13)	
(14)	Wind	WSAvg	4.3	4.8	4.6	4.3	3.8	3.6	3.7	3.8	4.0	4.4	4.7	4.9	4.9	(14)
(15)	Precipitation	PrecAvg	305	23	28	27	25	33	33	30	23	23	18	23	24	(15)
(16)		PrecMax	610	116	159	189	92	113	104	80	65	66	72	87	151	(16)
(17)		PrecMin	177	0	0	0	0	1	5	2	4	0	0	0	0	(17)
(18)		PrecStd	86	29	36	40	20	28	21	18	14	18	15	19	29	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	41.2	40.1	38.1	33.0	28.1	22.6	22.0	27.8	30.7	34.5	37.8	40.2	(19)
(20)			MCWB	19.8	19.4	18.2	17.9	15.8	12.9	12.2	13.3	14.6	16.0	17.3	18.5	(20)
(21)		2%	DB	38.0	37.1	34.8	29.9	24.4	20.2	19.8	23.4	27.4	31.8	34.6	37.5	(21)
(22)			MCWB	19.2	19.9	18.0	16.7	14.4	12.5	11.6	12.5	14.0	15.8	17.3	18.6	(22)
(23)		5%	DB	35.6	34.7	31.9	27.3	22.2	18.5	18.1	20.9	24.7	29.2	31.9	34.7	(23)
(24)			MCWB	19.1	19.5	18.0	16.3	13.8	11.9	11.4	12.0	13.4	15.3	16.7	18.1	(24)
(25)	10%	DB	32.9	32.1	29.4	25.1	20.4	17.0	16.5	18.7	22.2	26.4	29.3	31.9	(25)	
(26)		MCWB	18.6	18.8	17.5	15.7	13.3	11.4	10.8	11.4	12.6	14.7	15.9	17.4	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	23.6	23.4	20.9	19.7	17.8	15.1	14.4	15.2	16.5	18.5	20.1	21.9	(27)
(28)			MCDWB	31.7	30.3	28.6	27.0	23.5	19.7	17.7	21.2	25.4	27.6	29.6	31.5	(28)
(29)		2%	WB	22.0	21.9	19.9	18.4	16.2	14.0	13.1	14.0	15.1	17.1	19.1	20.3	(29)
(30)			MCDWB	30.7	31.5	28.1	24.8	21.0	17.7	17.1	19.4	23.9	27.1	29.1	31.6	(30)
(31)		5%	WB	20.8	20.7	19.1	17.6	15.1	13.0	12.2	13.0	14.1	16.1	18.0	19.1	(31)
(32)			MCDWB	30.7	30.3	26.9	23.7	19.8	16.5	16.2	19.4	22.4	26.0	27.4	30.8	(32)
(33)	10%	WB	19.7	19.8	18.3	16.7	14.0	12.1	11.3	12.0	13.1	15.2	17.0	18.0	(33)	
(34)		MCDWB	29.0	28.9	26.3	23.1	19.2	15.8	15.5	17.7	21.0	24.7	27.0	29.6	(34)	
(35)	Mean Daily Temperature Range	5% DB	MDBR	15.3	14.5	13.7	13.5	13.2	12.1	12.4	13.9	15.2	14.9	15.0	15.8	(35)
(36)			MCDBR	19.6	18.2	17.5	16.0	15.9	14.3	15.2	17.7	19.0	19.4	18.7	19.8	(36)
(37)			MCWBR	5.8	5.1	5.5	6.0	7.8	8.1	8.5	8.9	8.2	7.1	5.9	5.9	(37)
(38)		5% WB	MCDBR	15.9	15.1	13.6	12.5	12.3	11.3	12.2	14.1	16.1	15.8	16.0	17.5	(38)
(39)			MCWBR	5.8	5.2	5.0	5.5	6.7	7.1	7.6	7.7	7.4	6.3	5.8	6.1	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.338	0.338	0.320	0.309	0.293	0.281	0.280	0.288	0.307	0.319	0.326	0.326	(40)	
(41)		taud	2.591	2.603	2.637	2.652	2.667	2.679	2.683	2.639	2.565	2.555	2.564	2.596	(41)	
(42)		Ebn at Noon	1001	981	967	927	894	883	901	936	964	989	1006	1016	(42)	
(43)		Edh at Noon	104	100	90	80	70	65	68	79	95	104	107	105	(43)	
(44)	All-Sky Solar Radiation	RadAvg	7.62	6.70	5.61	4.28	3.24	2.75	2.97	3.92	5.24	6.40	7.26	7.94	(44)	
(45)		RadStd	0.46	0.54	0.37	0.25	0.20	0.14	0.16	0.20	0.21	0.40	0.46	0.49	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (6 neighbors)	+0.23	N/A	N/A	N/A	N/A	N/A	N/A	-62	+87	+40

Nomenclature: See separate page