

FORREST, Australia

WMO: 956460

Lat: 30.8453S

Lon: 128.1092E

Elev: 525

StdP: 14.42

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	35.8	37.9	13.8	11.3	76.4	18.0	13.9	72.9	31.9	59.5	29.0	60.6	7.1	50	0.615

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	28.6	105.6	65.9	101.4	65.1	97.0	64.2	72.9	86.7	70.6	85.9	68.8	84.9	14.2	350

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
69.7	111.4	75.5	66.7	100.3	73.5	64.6	93.1	71.5	37.0	87.4	34.9	85.3	33.3	85.4	86.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
28.3	25.2	22.9	31.6	111.7	1.9	3.1	30.3	114.0	29.2	115.8	28.1	117.6	26.8	119.8
			29.0	76.8	2.7	3.2	27.1	79.0	25.5	80.9	24.0	82.7	22.1	85.0
			DB											
			WB											

Monthly Climatic Design Conditions

			Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
			(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	64.9	75.8	75.1	71.1	65.9	59.3	54.1	53.1	55.7	60.5	65.8	70.0	73.3	(6)
(7)		DBStd	10.03	6.96	6.85	6.66	5.57	5.10	4.02	4.15	5.31	6.47	7.38	7.35	6.88	(7)
(8)		HDD50	23	0	0	0	0	0	5	12	5	1	0	0	0	(8)
(9)		HDD65	1541	2	2	14	55	194	329	368	296	168	80	28	5	(9)
(10)		CDD50	5466	800	702	654	476	287	127	109	180	317	490	600	724	(10)
(11)		CDD65	1512	337	284	203	81	16	1	1	6	34	106	179	264	(11)
(12)		CDH74	19676	4106	3202	2370	1035	275	18	28	223	721	1738	2540	3420	(12)
(13)		CDH80	10449	2395	1811	1226	409	75	1	2	54	287	883	1380	1926	(13)
(14)	Wind	WSAvg	12.4	14.2	13.8	12.3	10.8	9.9	10.3	11.1	11.7	12.6	13.6	14.0	14.1	(14)
(15)	Precipitation	PrecAvg	7.9	0.6	0.8	0.7	0.7	0.7	0.6	0.5	0.6	0.6	0.6	0.7	0.8	(15)
(16)		PrecMax	13.3	4.2	5.6	4.6	3.9	2.9	3.1	2.0	3.1	3.3	3.3	2.5	4.3	(16)
(17)		PrecMin	3.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	(17)
(18)		PrecStd	2.7	0.9	1.1	0.9	0.9	0.7	0.6	0.4	0.6	0.7	0.6	0.6	0.8	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	110.8	108.8	104.0	94.8	87.1	76.5	77.3	86.0	94.4	101.7	105.9	108.0	(19)
(20)			MCWB	67.8	67.7	64.6	62.2	59.2	57.4	54.5	55.7	59.2	62.3	64.1	66.3	(20)
(21)		2%	DB	105.2	103.4	98.4	89.5	81.2	71.9	72.6	80.3	88.1	96.0	100.0	102.6	(21)
(22)			MCWB	66.3	67.3	64.3	61.9	58.9	54.8	53.3	54.7	58.3	61.2	63.5	64.7	(22)
(23)		5%	DB	98.9	97.1	92.8	84.5	76.1	68.4	68.9	75.2	82.3	89.7	93.9	96.9	(23)
(24)			MCWB	66.0	66.3	63.6	60.3	57.6	53.9	52.9	53.9	56.9	59.9	62.1	64.2	(24)
(25)		10%	DB	93.1	91.3	86.4	80.1	71.7	65.6	65.3	69.8	77.0	83.8	87.8	91.0	(25)
(26)			MCWB	65.6	66.6	63.0	60.2	56.0	53.2	51.7	52.3	55.8	58.5	61.6	63.6	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	75.9	76.5	72.2	68.3	64.8	62.2	60.5	60.1	64.5	67.2	69.2	73.6	(27)
(28)			MCDWB	86.5	90.0	82.8	80.5	74.0	68.7	67.2	71.1	77.6	84.7	85.4	85.4	(28)
(29)		2%	WB	72.4	73.4	69.7	66.0	62.5	58.9	57.1	57.8	60.9	64.3	66.8	70.3	(29)
(30)			MCDWB	88.9	87.8	83.3	76.7	72.4	66.4	65.4	70.7	79.4	84.1	86.1	85.4	(30)
(31)		5%	WB	69.8	70.9	67.8	64.3	60.5	56.5	54.8	55.7	58.8	62.0	65.1	68.1	(31)
(32)			MCDWB	87.7	85.2	81.3	74.4	69.4	63.9	63.6	69.3	76.4	82.6	84.7	86.0	(32)
(33)		10%	WB	67.8	68.6	65.9	62.7	58.7	54.8	53.3	54.0	57.1	60.1	63.4	66.1	(33)
(34)			MCDWB	85.9	83.5	78.1	74.2	67.9	62.4	62.1	66.7	73.3	79.7	82.4	83.2	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	28.6	26.7	25.8	25.5	23.9	23.4	24.0	26.6	28.6	29.9	29.3	29.1	(35)
(36)			MCDBR	39.0	37.3	36.2	33.3	30.9	28.2	30.2	35.0	37.4	39.7	39.2	39.1	(36)
(37)			MCWBR	10.5	10.3	11.3	12.6	13.8	15.1	15.8	16.0	14.2	13.8	11.8	11.5	(37)
(38)		5% WB	MCDBR	28.7	26.3	25.0	24.1	22.4	22.0	23.5	27.6	30.7	32.6	31.4	29.6	(38)
(39)			MCWBR	10.7	10.2	10.4	11.0	12.1	13.5	14.3	14.4	13.1	12.4	11.4	11.4	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.362	0.364	0.340	0.327	0.306	0.291	0.294	0.304	0.334	0.345	0.355	0.351	(40)	
(41)		taud	2.457	2.472	2.521	2.544	2.569	2.595	2.569	2.524	2.434	2.417	2.426	2.462	(41)	
(42)		Ebn at Noon	310	304	301	288	279	278	281	292	297	306	310	314	(42)	
(43)		Edh at Noon	38	36	32	29	25	23	24	29	35	38	39	38	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2425	2172	1817	1422	1102	950	1039	1348	1758	2128	2350	2505	(44)	
(45)		RadStd	193	195	127	84	71	42	64	70	107	103	131	114	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page