

NORTH WALPOLE, Australia

WMO: 956470

Lat: 34.9469S

Lon: 116.7222E

Elev: 241

StdP: 14.57

Time Zone: 8.00 (E08)

Period: 04-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	44.0	45.3	37.0	32.6	51.9	38.5	34.6	51.2	24.3	54.3	21.8	55.2	4.2	310	0.477

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	15.0	84.2	67.9	80.1	67.0	77.0	65.7	70.0	80.2	68.4	76.9	67.0	74.4	9.3	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.8	99.6	72.8	65.5	95.2	71.5	64.3	91.1	70.3	34.1	80.6	32.8	76.8	31.7	74.3	78.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 20.8	18.5	16.6	DB	40.1	95.8	1.7	4.3	38.9	98.8	37.9	101.3	36.9	103.7	35.6	106.8	(4)
(5)			WB	38.9	72.8	1.3	1.4	38.0	73.8	37.2	74.6	36.5	75.4	35.6	76.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	59.9	65.8	66.7	65.4	61.7	58.8	55.9	54.0	54.4	55.2	57.6	60.4	62.8	(6)	
	DBStd	5.94	4.35	4.33	4.74	4.35	3.66	3.21	3.07	3.41	3.86	4.01	4.51	4.10	(7)	
	HDD50	10	0	0	0	0	0	1	3	4	2	0	0	0	(8)	
	HDD65	2145	37	25	49	119	195	274	340	329	295	234	155	93	(9)	
	CDD50	3608	491	468	477	351	273	177	129	140	158	235	311	398	(10)	
	CDD65	266	63	73	61	19	3	0	0	0	1	4	16	26	(11)	
	CDH74	1492	384	355	331	77	9	0	0	0	10	26	112	188	(12)	
	CDH80	382	102	85	105	15	0	0	0	0	1	2	29	43	(13)	
(14) Wind	WSAvg	8.2	8.6	8.6	8.0	7.1	7.1	8.2	8.7	8.8	8.9	8.3	8.0	8.0	(14)	
(15) Precipitation	PrecAvg	46.3	0.9	1.0	1.8	3.2	5.6	7.0	8.0	6.6	5.4	3.2	2.4	1.5	(15)	
	PrecMax	54.8	4.3	3.1	4.4	6.5	9.4	11.5	13.3	10.2	10.7	5.0	6.6	4.6	(16)	
	PrecMin	31.7	0.1	0.2	0.3	0.6	3.0	3.6	4.4	3.1	2.1	1.6	0.6	0.3	(17)	
	PrecStd	6.0	0.9	0.7	1.0	1.7	1.8	1.9	2.2	1.7	2.2	1.0	1.3	1.0	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	88.6	87.8	89.4	81.9	75.0	68.4	66.1	70.0	74.1	77.3	84.6	85.1	(19)	
		MCWB	72.1	69.7	68.2	64.4	60.7	59.0	57.0	57.4	60.0	62.8	65.2	68.6	(20)	
	2%	DB	82.4	81.9	81.5	75.5	70.6	65.5	63.6	65.7	68.1	71.9	76.4	79.0	(21)	
		MCWB	69.8	68.4	66.3	63.8	59.8	57.0	56.3	56.9	59.0	62.3	65.3	67.5	(22)	
	5%	DB	77.9	77.9	76.7	71.7	67.8	63.5	61.5	63.0	64.8	67.8	71.8	74.5	(23)	
		MCWB	67.1	66.8	65.6	62.5	59.3	56.3	55.5	55.8	57.8	60.4	63.1	64.9	(24)	
	10%	DB	74.3	74.8	73.1	69.0	65.3	61.6	59.7	60.6	62.3	65.0	68.5	71.1	(25)	
		MCWB	65.2	65.3	64.2	61.7	58.6	55.3	54.7	55.0	56.4	58.8	61.3	62.6	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	73.6	71.6	70.3	67.3	64.6	61.3	60.3	61.0	63.2	66.2	68.7	70.8	(27)	
		MCDB	85.7	83.0	81.4	73.9	70.0	64.9	62.7	65.7	69.2	72.9	77.9	82.2	(28)	
	2%	WB	70.3	69.3	68.3	65.4	62.5	59.3	58.2	58.7	60.4	63.4	66.1	67.9	(29)	
		MCDB	80.1	78.9	76.5	71.7	66.5	62.8	61.4	62.9	65.8	69.6	74.1	77.0	(30)	
	5%	WB	68.0	67.7	66.8	64.0	61.0	58.0	56.6	56.9	58.6	61.2	64.0	65.7	(31)	
		MCDB	76.1	75.5	73.5	69.4	65.1	61.5	60.0	61.0	63.8	66.4	70.6	72.7	(32)	
	10%	WB	66.1	66.4	65.4	62.7	59.8	56.8	55.3	55.6	56.8	59.3	62.0	63.7	(33)	
		MCDB	73.2	72.8	71.1	67.5	63.8	60.2	58.6	59.8	61.5	64.0	67.6	69.6	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	15.5	15.0	14.5	13.3	12.3	10.8	10.5	11.5	12.8	13.4	14.5	14.9	(35)	
		MCDBR	22.3	21.8	22.5	18.2	16.4	13.6	13.1	15.4	17.2	19.5	21.3	22.2	(36)	
	5% WB	MCWBR	11.6	10.2	10.5	9.4	9.1	8.5	8.4	9.1	10.1	12.1	12.3	12.3	(37)	
		MCWBR	20.6	19.3	17.7	15.5	13.0	11.6	11.1	13.0	16.0	17.9	19.9	20.3	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.340	0.340	0.329	0.318	0.309	0.306	0.305	0.314	0.333	0.330	0.339	0.334	(40)	
		taud	2.579	2.591	2.619	2.647	2.642	2.630	2.625	2.592	2.522	2.547	2.544	2.582	(41)	
	Ebn at Noon		316	309	301	287	272	265	271	284	295	309	314	319	(42)	
		Edh at Noon	33	32	29	25	22	21	22	26	31	33	34	34	(43)	
(44) All-Sky Solar Radiation	RadAvg		2327	2030	1603	1161	850	689	747	1003	1357	1766	2107	2324	(44)	
	RadStd		155	108	108	67	58	39	34	50	56	107	124	127	(45)	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (11 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	-142	N/A	N/A

Nomenclature: See separate page