

WUDINNA, Australia

WMO: 956540

Lat: 33.0431S

Lon: 135.4519E

Elev: 285

StdP: 14.55

Time Zone: 9.50 (AUA)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	34.3	37.0	14.0	11.3	85.7	19.1	14.5	83.9	29.6	59.8	27.0	58.6	3.4	40	0.559

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	29.8	105.3	64.8	101.2	64.1	97.0	63.3	70.2	86.1	68.4	87.3	66.8	86.1	14.3	10

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.6	98.8	73.4	63.9	89.9	72.0	61.3	81.9	70.2	34.4	83.8	32.8	86.6	31.5	85.7	79.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 27.8	24.3	21.4	DB	29.9	112.0	2.1	2.9	28.4	114.1	27.2	115.8	26.0	117.5	24.4	119.6	(4)
(5)			WB	29.2	72.8	2.2	2.6	27.7	74.8	26.4	76.3	25.2	77.8	23.6	79.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	63.3	75.4	74.2	69.8	64.6	58.1	53.1	52.5	53.2	57.7	62.7	67.8	71.7	(6)	
	DBStd	10.61	8.06	7.77	7.46	6.70	5.55	4.26	4.15	5.25	6.73	7.86	8.41	8.46	(7)	
	HDD50	65	0	0	0	0	2	16	20	22	4	1	0	0	(8)	
	HDD65	1939	4	7	30	88	228	358	387	369	242	142	61	23	(9)	
	CDD50	4933	788	677	615	438	254	109	98	120	233	394	535	672	(10)	
	CDD65	1334	327	264	180	76	15	1	0	2	21	71	147	230	(11)	
	CDH74	18990	4579	3463	2346	954	107	4	1	36	380	1279	2323	3518	(12)	
	CDH80	10225	2735	1981	1184	353	16	0	0	4	111	572	1239	2030	(13)	
(14) Wind	WSAvg	10.4	11.3	10.3	9.9	9.2	9.5	9.5	10.6	10.5	10.7	11.3	11.2	11.1	(14)	
(15) Precipitation	PrecAvg	12.6	0.6	0.7	0.6	0.7	1.1	1.7	1.7	1.6	1.3	0.9	0.8	0.9	(15)	
	PrecMax	22.0	4.6	3.1	2.4	1.9	2.4	3.5	3.1	3.1	3.0	3.0	2.1	4.1	(16)	
	PrecMin	6.0	0.0	0.0	0.0	0.0	0.1	0.6	0.4	0.2	0.1	0.0	0.0	0.0	(17)	
	PrecStd	2.9	0.9	0.8	0.7	0.6	0.6	0.8	0.7	0.8	0.8	0.8	0.6	0.9	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	110.7	108.4	103.3	95.7	82.5	71.9	71.7	78.5	89.2	97.0	104.9	108.9	(19)	
		MCWB	66.8	67.6	63.1	62.6	58.1	54.4	53.7	54.6	57.3	60.2	62.4	65.4	(20)	
	2%	DB	106.0	102.3	96.5	88.3	76.9	66.9	66.5	72.7	83.0	91.5	97.9	102.8	(21)	
		MCWB	65.5	66.1	62.8	60.2	56.4	53.0	52.2	53.6	55.9	59.0	61.6	63.7	(22)	
	5%	DB	100.4	98.3	91.7	83.4	72.5	63.9	63.3	68.4	78.3	86.4	92.8	97.7	(23)	
		MCWB	64.3	64.9	62.8	59.0	55.2	52.7	52.0	52.6	54.9	57.6	60.5	62.6	(24)	
	10%	DB	94.7	92.3	86.7	79.4	68.7	61.2	60.8	64.3	73.4	81.4	87.3	91.7	(25)	
		MCWB	63.8	63.7	61.5	57.7	54.8	52.5	51.5	53.8	56.0	59.1	61.6	61.6	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	72.0	72.9	71.1	66.2	61.4	58.9	57.5	58.7	60.3	64.1	68.6	70.8	(27)	
		MCDB	84.4	90.3	82.1	75.5	71.4	65.7	62.3	68.0	79.4	83.9	81.1	83.5	(28)	
	2%	WB	69.6	70.4	68.3	63.7	59.6	56.5	55.5	56.4	58.2	61.4	65.1	68.1	(29)	
		MCDB	91.2	85.6	82.2	76.3	68.0	61.6	60.9	65.1	74.2	81.0	83.2	85.6	(30)	
	5%	WB	67.9	68.0	66.2	62.1	58.3	55.2	54.2	54.7	56.6	59.6	63.3	65.8	(31)	
		MCDB	91.2	87.2	81.6	75.8	66.1	60.0	59.8	63.6	71.7	78.3	84.5	86.0	(32)	
	10%	WB	66.2	66.2	64.1	60.4	56.9	54.0	52.9	53.2	55.1	58.0	61.5	63.6	(33)	
		MCDB	88.1	86.0	79.6	73.3	65.0	58.9	58.7	61.4	68.6	75.3	82.2	84.9	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	29.8	28.7	27.1	25.5	20.0	17.4	17.2	21.4	26.0	29.4	30.1	30.1	(35)	
		MCDBR	38.1	36.7	34.0	31.2	24.4	20.4	20.3	27.9	34.0	36.8	37.6	38.7	(36)	
		MCWBR	10.4	10.0	10.2	11.0	10.3	11.0	10.4	12.8	13.1	12.9	12.1	11.8	(37)	
	5% WB	MCDBR	28.1	27.7	25.2	23.9	18.1	14.8	16.5	22.4	28.3	30.9	29.8	28.3	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.342	0.342	0.324	0.315	0.306	0.295	0.295	0.302	0.331	0.342	0.344	0.334	(40)	
		taud	2.507	2.528	2.560	2.569	2.569	2.587	2.583	2.547	2.459	2.431	2.458	2.514	(41)	
	Ebn at Noon		316	310	304	290	276	272	278	290	297	306	313	320	(42)	
		Edh at Noon	36	34	31	27	24	22	23	27	33	37	37	36	(43)	
(44) All-Sky Solar Radiation	RadAvg		2496	2232	1831	1354	976	828	892	1180	1597	2015	2301	2469	(44)	
	RadStd		119	124	102	85	42	39	39	70	108	137	111	121	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (10 neighbors)	+0.49	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+171	+92

Nomenclature: See separate page