

OLYMPIC DAM, Australia

WMO: 956580

Lat: 30.4828S

Lon: 136.8772E

Elev: 327

StdP: 14.52

Time Zone: 9.50 (AUA)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	32.8	35.9	7.7	8.3	80.8	12.7	10.6	75.5	23.2	65.8	21.1	65.3	2.7	150	0.519

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	26.2	108.0	66.5	104.7	65.6	101.5	65.2	73.4	88.1	71.4	89.4	69.7	89.1	11.5	350

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
70.1	112.2	77.0	66.5	98.8	77.1	63.5	88.7	77.8	37.3	86.8	35.4	88.8	33.9	88.8	81.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years						
Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max			
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
25.6	22.3	19.9	DB	28.0	111.7	2.4	2.8	26.2	113.7	24.8	115.4	23.5	117.0	21.7	119.1	
			WB	25.6	76.2	2.9	3.2	23.5	78.5	21.9	80.4	20.2	82.2	18.1	84.5	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	68.2	84.2	81.9	76.5	68.8	59.6	53.3	52.7	55.4	62.3	69.2	75.3	79.8
	DBStd	12.81	7.55	7.48	6.81	6.30	5.64	4.66	4.95	5.71	7.01	7.72	7.86	7.60
	HDD50	54	0	0	0	0	1	20	24	9	0	0	0	0
	HDD65	1441	0	0	3	30	188	352	382	304	138	40	4	0
	CDD50	6688	1060	893	821	563	299	118	108	178	368	596	760	924
	CDD65	2601	595	474	359	144	21	0	1	7	56	171	314	459
	CDH74	36842	9015	6787	4494	1637	202	3	22	121	892	2508	4473	6688
	CDH80	21048	5789	4181	2364	631	34	0	1	22	330	1220	2470	4006
(14) Wind	WSAvg	9.7	11.9	11.2	10.0	8.5	7.7	7.0	7.8	8.9	9.9	11.1	11.3	11.5
(15) Precipitation	PrecAvg	6.4	0.5	0.9	0.2	0.7	0.5	0.6	0.3	0.4	0.5	0.4	0.6	0.6
	PrecMax	13.3	3.1	5.0	0.9	5.4	2.5	3.3	1.1	1.3	1.8	1.5	1.9	2.7
	PrecMin	1.6	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	2.8	0.8	1.3	0.2	1.2	0.6	0.8	0.3	0.4	0.6	0.5	0.5	0.6
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	113.0	110.9	103.8	95.9	83.9	73.7	76.8	83.1	93.9	100.3	107.1	110.0
		MCWB	67.6	69.8	65.2	62.6	57.8	57.4	55.8	56.4	58.5	62.3	64.4	66.6
	2%	DB	108.5	106.5	99.7	91.0	79.4	68.9	71.9	77.0	88.1	96.0	101.8	105.7
		MCWB	67.0	67.2	63.9	61.4	57.8	54.1	53.6	53.2	57.0	60.6	63.7	65.2
	5%	DB	104.8	102.5	95.7	87.0	75.4	66.1	68.0	73.1	83.5	91.6	97.5	101.6
		MCWB	66.2	66.6	63.4	59.9	56.3	53.4	52.4	52.7	55.8	59.2	62.0	64.4
	10%	DB	101.4	98.9	91.9	83.2	71.7	63.6	64.7	69.3	78.9	86.9	93.1	97.4
		MCWB	65.6	65.7	63.1	59.4	55.1	52.2	51.0	51.6	54.3	58.1	61.2	63.4
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	76.4	77.1	74.2	69.1	62.2	60.4	59.3	60.0	62.5	65.9	70.8	74.6
		MCDB	86.6	82.4	81.7	73.0	73.1	67.6	68.3	73.2	76.6	86.5	85.6	85.3
	2%	WB	72.7	73.2	71.4	66.1	60.2	57.6	55.4	56.4	59.4	63.5	68.0	71.1
		MCDB	89.9	92.1	83.8	75.3	72.5	64.1	66.8	70.2	79.1	84.9	83.9	87.9
	5%	WB	70.9	70.8	68.7	63.5	58.5	55.6	53.6	54.5	57.6	61.8	66.1	69.0
		MCDB	91.9	91.2	85.3	79.6	70.2	62.5	65.8	69.3	77.3	84.3	85.0	88.3
	10%	WB	69.1	68.6	65.8	61.5	56.9	53.8	52.0	52.7	56.0	60.0	64.0	66.6
		MCDB	93.3	90.5	87.2	79.8	68.8	61.3	63.1	66.9	75.5	82.4	87.8	90.6
(35) Mean Daily Temperature Range	5% DB	MDBR	26.2	25.3	24.1	24.2	22.7	21.4	23.9	25.9	27.1	27.1	26.2	26.4
		MCDBR	30.1	29.7	29.9	29.2	26.0	24.5	27.6	30.4	32.9	32.8	31.3	31.5
		MCWBR	9.5	9.3	11.0	11.4	11.7	13.5	14.5	14.6	13.4	12.7	10.9	10.7
	5% WB	MCDBR	22.4	22.6	19.2	20.1	20.5	18.9	24.6	26.5	27.6	26.0	23.6	23.3
		MCWBR	9.1	8.3	7.9	9.5	10.0	11.0	13.6	13.6	12.3	11.2	9.9	10.2
(40) Clear-Sky Solar Irradiance	taub		0.363	0.356	0.336	0.326	0.307	0.293	0.298	0.315	0.349	0.355	0.362	0.352
	taud		2.401	2.448	2.477	2.485	2.510	2.538	2.511	2.446	2.355	2.350	2.371	2.414
	Ebn at Noon		310	306	302	289	279	277	279	288	292	303	308	314
	Edh at Noon		40	37	34	30	26	24	26	31	38	41	41	40
(44) All-Sky Solar Radiation	RadAvg		2561	2330	2005	1550	1178	1004	1098	1416	1849	2194	2417	2565
(45)	RadStd		127	138	122	67	66	56	42	56	91	117	115	101

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)	+0.72	N/A	N/A	+1.93	N/A	N/A	N/A	N/A	+284	+193

Nomenclature: See separate page