

MINLATON, Australia

WMO: 956590

Lat: 34.7481S

Lon: 137.5275E

Elev: 107

StdP: 14.64

Time Zone: 9.50 (AUA)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	38.5	40.3	26.7	20.8	78.2	30.5	24.7	72.2	35.6	54.4	32.2	56.3	8.3	80	0.651

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	23.5	100.5	67.0	96.4	65.8	92.3	64.8	71.6	88.6	69.5	85.4	67.6	84.3	14.0	350

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
67.7	102.1	75.2	64.7	91.8	73.1	62.5	85.0	71.7	35.4	87.3	33.6	84.8	32.1	84.6	82.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 33.9	29.0	25.6	DB	34.8	107.5	1.5	3.3	33.8	109.9	32.9	111.8	32.1	113.7	31.0	116.1	(4)
(5)			WB	34.2	73.8	1.6	3.3	33.1	76.2	32.1	78.1	31.2	80.0	30.0	82.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	62.0	72.8	71.6	68.4	63.7	58.2	53.6	52.1	52.5	55.8	60.8	65.6	69.1	(6)
(7)		DBStd	9.66	8.24	7.50	6.74	5.51	4.40	3.77	3.36	4.19	5.33	7.73	8.24	8.53	(7)
(8)		HDD50	49	0	0	0	0	0	9	17	18	4	1	0	0	(8)
(9)		HDD65	2097	11	11	34	89	218	343	400	388	283	184	91	45	(9)
(10)		CDD50	4414	707	606	571	410	255	116	82	95	178	334	468	592	(10)
(11)		CDD65	988	253	197	140	49	8	1	0	0	6	53	109	172	(11)
(12)		CDH74	11717	3142	2211	1432	426	53	7	0	7	74	690	1372	2303	(12)
(13)		CDH80	5852	1733	1128	633	126	11	2	0	1	9	288	661	1260	(13)
(14)	Wind	WSAvg	13.8	15.1	14.9	14.0	12.8	12.9	12.6	13.3	12.9	13.6	14.1	14.3	14.7	(14)
(15)	Precipitation	PrecAvg	15.9	0.5	0.6	0.6	1.3	1.9	2.2	2.4	2.0	1.7	1.3	0.8	0.7	(15)
(16)		PrecMax	24.1	2.5	3.8	2.3	4.2	4.2	6.2	4.6	3.9	4.0	3.3	2.7	3.3	(16)
(17)		PrecMin	10.4	0.0	0.0	0.0	0.0	0.2	0.4	0.9	0.6	0.6	0.1	0.0	0.0	(17)
(18)		PrecStd	3.4	0.6	0.9	0.6	1.1	0.9	1.1	0.9	0.9	0.9	0.9	0.6	0.6	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	107.1	102.5	98.4	89.3	80.6	71.8	68.1	73.5	81.0	93.8	99.9	105.2	(19)
(20)			MCWB	68.1	68.6	66.0	63.0	58.1	57.2	55.0	56.2	58.4	64.0	65.6	67.1	(20)
(21)		2%	DB	101.0	97.1	91.7	83.6	73.4	65.3	63.1	67.7	75.6	87.7	93.7	98.4	(21)
(22)			MCWB	67.4	67.7	64.6	60.5	57.3	54.8	52.6	54.3	57.2	61.9	64.2	66.2	(22)
(23)		5%	DB	95.9	92.6	87.3	78.8	69.2	62.2	60.4	63.6	71.3	81.9	88.4	93.1	(23)
(24)			MCWB	66.4	66.3	64.3	59.8	56.8	54.7	52.9	53.4	55.7	59.0	62.0	64.2	(24)
(25)		10%	DB	90.4	87.3	82.7	74.6	66.1	60.3	58.6	60.2	66.9	75.9	82.4	87.1	(25)
(26)			MCWB	65.1	65.1	63.0	58.8	56.5	54.3	52.9	53.0	55.1	57.9	60.7	62.7	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	74.8	74.3	71.6	66.1	62.5	60.3	58.4	58.8	62.8	69.3	70.8	73.5	(27)
(28)			MCDWB	86.3	93.8	82.6	75.0	69.4	64.7	61.8	65.7	72.9	84.5	86.8	91.7	(28)
(29)		2%	WB	71.0	71.0	68.7	64.2	60.9	57.8	56.3	57.0	59.9	63.1	66.5	69.2	(29)
(30)			MCDWB	90.5	87.1	82.2	72.6	66.5	61.4	59.1	62.7	69.7	79.3	85.1	84.8	(30)
(31)		5%	WB	68.9	68.8	66.7	62.7	59.4	56.5	54.9	55.6	58.0	60.8	64.4	66.7	(31)
(32)			MCDWB	87.8	84.0	79.8	72.0	64.9	60.4	58.1	60.5	66.4	74.0	81.0	84.2	(32)
(33)		10%	WB	66.8	66.9	64.9	61.1	58.1	55.3	53.8	54.2	56.4	59.1	62.4	64.5	(33)
(34)			MCDWB	85.7	82.2	78.2	70.9	63.9	59.1	57.2	58.8	64.1	71.8	77.3	81.9	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	23.5	21.4	20.4	18.7	15.3	13.4	13.4	16.0	18.8	22.1	23.1	23.4	(35)
(36)			MCDBR	32.0	29.4	27.4	24.4	20.2	15.5	15.6	20.6	25.9	30.4	30.9	32.9	(36)
(37)			MCWBR	9.6	9.0	8.9	9.5	9.8	9.4	9.5	11.3	11.9	11.6	10.2	9.6	(37)
(38)		5% WB	MCDBR	24.9	23.1	22.5	18.7	14.5	12.3	12.2	16.0	20.8	25.2	25.4	25.0	(38)
(39)			MCWBR	9.9	9.2	9.6	9.6	9.1	8.8	9.2	10.7	11.6	11.4	10.4	10.4	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.344	0.343	0.324	0.317	0.310	0.301	0.300	0.308	0.334	0.340	0.346	0.338	(40)	
(41)		taud	2.537	2.559	2.609	2.614	2.614	2.629	2.622	2.582	2.495	2.480	2.487	2.538	(41)	
(42)		Ebn at Noon	315	308	303	287	272	266	273	286	294	305	312	318	(42)	
(43)		Edh at Noon	35	33	29	26	23	21	22	26	32	35	36	35	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2417	2123	1713	1252	873	724	788	1081	1474	1892	2228	2367	(44)	
(45)		RadStd	117	96	63	69	37	36	33	62	109	114	108	89	45	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (29 neighbors)		+0.74	N/A	N/A	N/A	N/A	N/A	N/A	-166	+283	+124

Nomenclature: See separate page