

PORT LINCOLN, Australia

WMO: 956610

Lat: 34.5992S

Lon: 135.8783E

Elev: 28

StdP: 14.68

Time Zone: 9.50 (AUA)

Period: 94-14

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	41.0	42.8	28.9	22.9	71.7	33.8	28.5	63.5	30.9	58.1	28.5	57.8	6.8	310	0.577

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	14.3	91.0	65.3	86.0	65.1	81.7	64.5	70.1	81.8	68.3	79.9	66.8	77.3	16.5	350

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
66.5	97.5	73.0	64.6	91.3	72.3	62.9	86.0	71.4	34.1	82.2	32.6	80.1	31.4	77.6	75.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 27.9	24.9	22.5	37.7	106.3	1.6	3.9	36.5	109.2	35.6	111.5	34.6	113.7	33.5	116.5		
(5)			36.7	72.9	1.7	2.1	35.5	74.4	34.5	75.6	33.5	76.8	32.2	78.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	60.5	68.6	68.9	66.0	62.2	58.6	54.6	52.9	53.2	55.5	58.5	62.5	65.3
	DBStd	7.16	5.24	4.92	4.82	4.33	4.23	3.10	3.00	3.57	4.40	5.23	5.20	5.02
	HDD50	18	0	0	0	0	0	3	6	7	2	0	0	0
	HDD65	2097	12	10	38	107	208	312	376	366	289	217	110	52
	CDD50	3855	576	530	497	365	266	141	96	106	166	263	374	475
	CDD65	457	123	119	70	22	8	0	0	0	3	15	34	63
	CDH74	3591	908	756	520	176	64	1	0	4	45	235	376	506
	CDH80	1359	389	283	189	61	12	0	0	0	8	82	140	195
Wind	WSAvg	11.7	13.4	12.9	12.0	10.8	10.2	11.0	11.0	11.0	11.6	11.7	12.5	12.8
Precipitation	PrecAvg	19.1	0.6	0.7	0.9	1.1	2.1	3.3	2.8	2.6	1.9	1.3	0.9	1.0
	PrecMax	31.3	2.3	3.5	2.2	2.8	3.7	5.7	5.5	5.3	3.9	2.9	1.9	4.9
	PrecMin	14.1	0.1	0.0	0.2	0.0	0.5	1.7	1.1	0.7	0.6	0.1	0.1	0.1
	PrecStd	3.8	0.5	0.8	0.6	0.8	0.8	1.1	1.0	1.1	0.9	0.8	0.5	1.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	101.4	96.9	93.3	87.1	81.2	68.8	67.0	72.5	78.6	88.3	91.5	95.1
		MCWB	67.3	65.7	64.0	62.1	58.5	57.3	54.2	56.4	57.8	58.6	64.6	63.8
	2%	DB	88.9	88.0	84.8	78.6	74.1	64.5	63.1	66.9	73.4	80.9	83.6	85.1
		MCWB	66.8	67.4	65.2	60.7	56.9	56.0	54.2	54.9	57.5	58.7	62.9	63.5
	5%	DB	83.0	82.2	79.5	73.4	68.9	62.2	60.9	63.2	68.4	73.9	77.3	79.0
		MCWB	66.7	67.3	65.9	60.9	57.4	55.2	53.6	54.1	56.2	58.0	61.9	63.7
	10%	DB	77.8	78.0	74.8	70.1	65.4	60.3	58.9	60.3	64.4	68.4	72.7	74.5
		MCWB	65.3	66.1	64.3	60.2	57.1	54.3	52.8	53.2	55.9	58.0	61.1	62.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	72.0	72.6	71.5	66.7	62.7	60.3	57.9	58.9	61.9	64.1	67.9	69.1
		MCDB	82.2	80.7	79.7	76.1	69.4	65.2	62.2	65.9	71.1	78.2	83.5	79.9
	2%	WB	69.5	70.4	68.8	64.4	61.2	58.2	56.2	57.0	59.9	61.6	65.2	66.6
		MCDB	83.2	81.3	79.5	71.9	66.9	61.9	60.3	62.8	67.9	71.3	77.8	77.3
	5%	WB	67.6	68.4	66.7	62.8	59.8	56.7	54.9	55.6	58.1	59.9	63.2	65.0
		MCDB	80.3	78.8	75.8	69.4	64.9	60.5	58.9	61.0	65.2	68.6	74.2	75.5
	10%	WB	65.9	66.8	64.7	61.5	58.4	55.3	53.7	54.3	56.5	58.5	61.5	63.5
		MCDB	76.6	76.3	72.9	68.0	63.4	59.0	57.7	59.4	63.0	66.8	71.2	73.4
Mean Daily Temperature Range	5% DB	MDBR	15.4	14.3	14.4	14.9	13.7	11.8	12.5	14.7	16.7	17.8	16.3	16.0
		MCDBR	27.8	25.5	25.3	23.0	20.4	14.2	15.1	20.0	24.9	30.6	27.7	26.1
		MCWBR	10.2	9.9	11.1	10.7	9.4	8.7	9.2	11.2	12.0	13.2	11.1	10.1
	5% WB	MCDBR	22.5	20.7	20.8	18.1	15.2	12.5	13.2	17.4	20.6	22.4	23.1	21.1
		MCWBR	9.8	9.2	10.6	10.1	8.7	8.7	9.2	11.1	11.7	11.8	11.0	9.7
Clear-Sky Solar Irradiance	taub	0.345	0.345	0.327	0.322	0.314	0.303	0.300	0.309	0.339	0.343	0.345	0.337	
	taud	2.551	2.568	2.612	2.612	2.613	2.631	2.633	2.592	2.491	2.487	2.506	2.557	
	Ebn at Noon	314	308	302	286	271	266	273	286	293	305	312	318	
	Edh at Noon	34	32	29	26	23	21	22	26	32	35	36	34	
All-Sky Solar Radiation	RadAvg	2401	2103	1703	1239	870	725	795	1082	1483	1890	2204	2368	
	RadStd	108	103	73	75	41	35	36	68	102	121	125	101	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.74	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (14 neighbors)	+0.54	N/A	N/A	N/A	N/A	N/A	N/A	-155	+230	+94

Nomenclature: See separate page