

PORT LINCOLN, Australia

WMO: 956610

Lat: 34.5992S

Lon: 135.8783E

Elev: 9

StdP: 101.22

Time Zone: 9.50 (AUA)

Period: 94-14

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	5.0	6.0	-1.7	3.3	22.1	1.0	4.1	17.5	13.8	14.5	12.8	14.3	3.0	310	0.577

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	7.9	32.8	18.5	30.0	18.4	27.6	18.0	21.1	27.6	20.2	26.6	19.3	25.2	7.4	350

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.1	13.9	22.8	18.1	13.0	22.4	17.2	12.3	21.9	61.3	27.9	58.0	26.7	55.2	25.4	24.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
12.5	11.1	10.1	DB	3.2	41.3	0.9	2.2	2.5	42.9	2.0	44.1	1.5	45.4	0.8	47.0
			WB	2.6	22.7	1.0	1.2	1.9	23.6	1.4	24.2	0.8	24.9	0.1	25.7

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	15.8	20.3	20.5	18.9	16.8	14.8	12.6	11.6	11.8	13.0	14.7	16.9	18.5
	DBStd	3.98	2.91	2.73	2.68	2.41	2.35	1.72	1.67	1.98	2.44	2.91	2.89	2.79
	HDD10.0	10	0	0	0	0	0	2	3	4	1	0	0	0
	HDD18.3	1165	7	6	21	59	116	173	209	203	161	121	61	29
	CDD10.0	2142	320	294	276	203	148	78	53	59	92	146	208	264
	CDD18.3	254	68	66	39	12	4	0	0	0	2	8	19	35
	CDH23.3	1995	504	420	289	98	36	1	0	2	25	131	209	281
	CDH26.7	755	216	157	105	34	7	0	0	0	4	46	78	108
Wind	WSAvg	5.2	6.0	5.8	5.3	4.8	4.6	4.9	4.9	4.9	5.2	5.2	5.6	5.7
Precipitation	PrecAvg	486	15	19	22	29	53	83	71	66	49	33	22	26
	PrecMax	795	58	88	56	71	93	146	140	135	99	74	48	124
	PrecMin	357	2	0	4	1	13	43	28	19	14	2	3	2
	PrecStd	97	12	21	15	20	20	29	25	29	24	20	13	25
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	38.6	36.1	34.1	30.6	27.3	20.4	19.4	22.5	25.9	31.3	33.0	35.1
		MCWB	19.6	18.7	17.8	16.7	14.7	14.1	12.3	13.6	14.3	14.8	18.1	17.6
	2%	DB	31.6	31.1	29.4	25.9	23.4	18.1	17.3	19.4	23.0	27.2	28.7	29.5
		MCWB	19.4	19.7	18.4	15.9	13.8	13.3	12.3	12.7	14.2	14.9	17.2	17.5
	5%	DB	28.3	27.9	26.4	23.0	20.5	16.8	16.0	17.3	20.2	23.3	25.1	26.1
		MCWB	19.3	19.6	18.8	16.1	14.1	12.9	12.0	12.3	13.4	14.4	16.6	17.6
	10%	DB	25.4	25.5	23.8	21.2	18.6	15.7	14.9	15.7	18.0	20.2	22.6	23.6
		MCWB	18.5	19.0	17.9	15.7	14.0	12.4	11.6	11.8	13.3	14.4	16.2	17.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	22.2	22.6	21.9	19.3	17.1	15.7	14.4	14.9	16.6	17.8	19.9	20.6
		MCDB	27.9	27.0	26.5	24.5	20.8	18.5	16.8	18.8	21.7	25.7	28.6	26.6
	2%	WB	20.8	21.3	20.4	18.0	16.2	14.6	13.4	13.9	15.5	16.5	18.4	19.2
		MCDB	28.4	27.4	26.4	22.2	19.4	16.6	15.7	17.1	19.9	21.8	25.4	25.2
	5%	WB	19.8	20.2	19.3	17.1	15.4	13.7	12.7	13.1	14.5	15.5	17.3	18.3
		MCDB	26.9	26.0	24.4	20.8	18.3	15.8	15.0	16.1	18.4	20.4	23.5	24.2
	10%	WB	18.8	19.3	18.2	16.4	14.7	12.9	12.0	12.4	13.6	14.7	16.4	17.5
		MCDB	24.8	24.6	22.7	20.0	17.5	15.0	14.3	15.2	17.2	19.4	21.8	23.0
Mean Daily Temperature Range	5% DB	MDBR	8.5	7.9	8.0	8.3	7.6	6.6	7.0	8.2	9.3	9.9	9.0	8.9
		MCDBR	15.4	14.2	14.0	12.8	11.3	7.9	8.4	11.1	13.8	17.0	15.4	14.5
		MCWBR	5.7	5.5	6.2	6.0	5.2	4.8	5.1	6.2	6.7	7.3	6.2	5.6
	5% WB	MCDBR	12.5	11.5	11.6	10.0	8.4	6.9	7.3	9.7	11.4	12.5	12.9	11.7
		MCWBR	5.5	5.1	5.9	5.6	4.9	4.8	5.1	6.2	6.5	6.6	6.1	5.4
Clear-Sky Solar Irradiance	taub	0.345	0.345	0.327	0.322	0.314	0.303	0.300	0.309	0.339	0.343	0.345	0.337	
	taud	2.551	2.568	2.612	2.612	2.613	2.631	2.633	2.592	2.491	2.487	2.506	2.557	
	Ebn at Noon	991	970	953	902	854	839	862	902	923	961	985	1003	
	Edh at Noon	108	102	91	81	72	66	69	81	101	110	112	108	
All-Sky Solar Radiation	RadAvg	7.57	6.63	5.37	3.90	2.74	2.29	2.51	3.41	4.67	5.96	6.95	7.47	
	RadStd	0.34	0.33	0.23	0.24	0.13	0.11	0.11	0.21	0.32	0.38	0.39	0.32	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.41	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (14 neighbors)	+0.30	N/A	N/A	N/A	N/A	N/A	N/A	-86	+128	+52

Nomenclature: See separate page