

CUMMINS, Australia

WMO: 956630

Lat: 34.2525S

Lon: 135.7136E

Elev: 61

StdP: 100.60

Time Zone: 9.50 (AUA)

Period: 07-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	1.5	2.7	-2.3	3.1	28.4	-0.4	3.7	22.2	12.8	12.3	11.7	12.8	1.1	40	0.561

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	13.6	38.7	18.6	35.9	18.2	33.4	17.7	21.2	29.2	20.2	29.2	19.4	28.6	6.6	350

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.6	14.4	22.4	17.8	12.9	21.4	16.6	11.9	20.6	61.9	29.0	58.4	29.3	55.4	28.4	23.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.2	10.0	9.0	DB	-0.5	43.1	1.4	1.9	-1.5	44.4	-2.3	45.6	-3.1	46.6	-4.1	48.0	(4)
(5)			WB	-0.6	22.8	1.5	0.9	-1.6	23.4	-2.5	23.9	-3.3	24.4	-4.4	25.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	16.1	22.3	21.7	19.9	17.2	14.0	11.2	10.5	10.6	12.3	15.5	18.2	20.2	(6)	
	DBStd	5.55	4.51	4.29	4.14	3.44	2.56	1.95	1.94	2.15	2.95	4.19	4.83	4.63	(7)	
	HDD10.0	53	0	0	0	0	1	11	17	17	7	1	0	0	(8)	
	HDD18.3	1327	7	8	27	61	138	214	244	239	184	113	62	31	(9)	
	CDD10.0	2279	382	329	307	217	124	46	32	36	74	171	246	315	(10)	
	CDD18.3	513	131	104	76	28	3	0	0	0	2	24	58	87	(11)	
	CDH23.3	6100	1582	1107	771	277	29	0	0	1	37	374	779	1146	(12)	
	CDH26.7	3100	884	574	358	93	3	0	0	0	6	154	404	624	(13)	
(14) Wind	WSAvg	4.4	5.4	5.2	4.7	4.0	3.9	3.6	4.1	3.9	4.0	4.4	4.8	5.0	(14)	
(15) Precipitation	PrecAvg	463	13	18	19	30	48	85	69	62	45	31	22	23	(15)	
	PrecMax	776	45	79	57	80	84	154	120	125	96	76	49	127	(16)	
	PrecMin	291	1	1	1	1	10	43	33	10	10	1	2	0	(17)	
	PrecStd	103	11	19	15	21	21	31	24	28	22	21	13	27	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	42.1	40.4	38.5	32.8	26.4	19.8	19.7	21.7	26.7	33.7	39.4	40.4	(19)	
		MCWB	19.2	19.5	17.9	17.3	15.2	13.1	13.0	14.6	15.4	16.0	17.8	18.7	(20)	
	2%	DB	39.0	36.3	33.8	29.3	23.4	18.0	17.1	19.2	23.9	30.8	34.9	36.9	(21)	
		MCWB	19.1	18.8	17.9	15.9	14.2	12.7	12.9	13.5	14.6	15.6	16.9	17.9	(22)	
	5%	DB	35.4	33.6	30.7	26.5	20.6	16.7	15.7	17.1	21.3	27.6	31.5	33.5	(23)	
		MCWB	18.9	18.4	17.8	15.2	13.6	12.8	12.5	12.9	14.5	15.3	16.3	17.3	(24)	
	10%	DB	31.6	30.1	27.4	23.9	18.7	15.5	14.6	15.4	18.5	24.1	27.8	29.9	(25)	
		MCWB	18.1	18.0	17.4	15.1	13.5	12.3	12.0	12.3	13.3	14.8	15.8	16.9	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	22.1	22.4	22.2	19.0	16.7	15.2	15.2	15.8	17.5	18.5	19.4	21.3	(27)	
		MCDB	33.1	30.6	27.2	25.5	20.6	16.4	16.5	18.5	23.4	27.8	29.9	27.6	(28)	
	2%	WB	21.0	21.0	20.6	17.6	15.7	14.3	14.0	14.6	15.9	17.2	18.2	19.9	(29)	
		MCDB	32.4	27.3	26.0	23.3	19.4	16.1	15.6	17.7	21.8	25.6	30.2	29.8	(30)	
	5%	WB	20.0	19.9	19.4	16.8	15.0	13.6	13.2	13.5	14.8	16.2	17.4	18.8	(31)	
		MCDB	30.9	29.1	26.4	21.9	18.6	15.6	14.9	16.1	19.3	24.3	28.1	28.8	(32)	
	10%	WB	19.0	18.9	18.4	16.1	14.3	12.9	12.4	12.6	13.7	15.2	16.4	17.7	(33)	
		MCDB	29.2	28.1	25.4	21.3	17.7	15.0	14.1	15.0	17.9	22.5	25.3	27.0	(34)	
(35) Mean Daily Temperature Range	MDBR		13.6	12.3	12.2	12.0	9.8	9.2	8.9	10.2	12.1	14.7	14.0	14.1	(35)	
	5% DB	MCDBR	19.2	17.9	16.7	15.6	13.0	11.0	10.0	12.8	16.7	20.0	19.4	19.7	(36)	
		MCWBR	5.5	5.0	5.2	5.9	6.1	7.0	6.7	8.1	8.7	8.0	6.0	6.1	(37)	
	5% WB	MCDBR	15.6	13.3	12.5	12.2	9.8	9.0	8.9	11.6	14.6	16.2	15.4	15.5	(38)	
		MCWBR	5.6	5.0	5.0	5.6	5.7	6.5	6.8	8.1	8.4	7.5	5.7	6.0	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.343	0.342	0.324	0.319	0.310	0.301	0.298	0.305	0.333	0.338	0.342	0.334	(40)	
	taud		2.521	2.543	2.582	2.584	2.596	2.608	2.611	2.570	2.475	2.465	2.476	2.530	(41)	
	Ebn at Noon		994	974	956	905	860	842	866	907	930	966	988	1007	(42)	
	Edh at Noon		112	105	94	83	73	68	71	83	103	112	116	111	(43)	
(44) All-Sky Solar Radiation		RadAvg	7.67	6.75	5.48	3.99	2.81	2.35	2.57	3.47	4.74	6.06	7.04	7.57	(44)	
(45)		RadStd	0.34	0.34	0.24	0.24	0.12	0.11	0.11	0.21	0.33	0.40	0.39	0.34	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (13 neighbors)	+0.28	N/A	N/A	N/A	N/A	N/A	N/A	-102	+121	N/A

Nomenclature: See separate page