

PORT AUGUSTA, Australia

WMO: 956660

Lat: 32.5092S

Lon: 137.7144E

Elev: 47

StdP: 14.67

Time Zone: 9.50 (AUA)

Period: 97-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	35.5	38.3	13.9	11.2	81.1	19.5	14.7	78.1	27.6	63.6	25.0	63.0	4.5	230	0.568

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	23.3	106.7	66.5	102.3	65.7	98.2	64.7	73.0	87.0	71.4	86.7	69.8	85.7	14.0	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
69.2	107.6	77.8	66.9	99.0	77.5	64.8	91.9	76.5	36.7	86.7	35.2	86.6	33.8	85.5	81.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
27.1	24.4	22.4	DB	30.7	112.7	2.4	2.9	29.0	114.8	27.6	116.5	26.3	118.1	24.6	120.2	
			WB	29.2	76.0	2.3	2.4	27.6	77.7	26.2	79.1	24.9	80.4	23.2	82.1	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	66.1	79.9	78.7	73.9	67.1	59.2	53.5	52.2	54.8	60.8	66.4	72.0	75.5
	DBStd	11.44	7.79	7.39	7.13	5.73	4.76	3.92	3.78	4.66	6.10	7.00	7.75	7.86
	HDD50	39	0	0	0	0	1	12	19	7	0	0	0	0
	HDD65	1544	0	1	7	40	189	346	397	321	159	65	16	3
	CDD50	5917	927	804	741	514	287	116	87	154	325	510	661	791
	CDD65	1946	462	385	283	104	10	0	0	3	33	110	227	329
	CDH74	23079	5675	4514	2905	1011	114	2	2	61	549	1502	2765	3979
	CDH80	12264	3302	2492	1441	381	18	0	0	10	197	711	1480	2232
(14) Wind	WSAvg	11.4	14.7	13.6	12.2	10.0	8.5	8.0	8.8	9.9	11.1	12.7	13.2	13.8
(15) Precipitation	PrecAvg	9.9	0.7	0.7	0.5	0.6	1.0	1.0	0.9	0.9	1.0	1.0	0.8	0.6
	PrecMax	20.9	2.7	4.3	4.1	2.0	4.8	2.8	2.5	2.5	3.2	5.2	3.9	2.5
	PrecMin	5.4	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	3.7	0.6	1.0	0.7	0.7	1.0	0.8	0.7	0.6	0.8	1.1	0.8	0.7
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	112.1	109.8	103.9	94.7	82.7	71.6	72.0	80.3	92.1	99.5	106.0	110.0
		MCWB	67.3	68.8	64.8	63.0	58.9	55.4	54.0	55.9	59.4	61.3	63.8	66.1
	2%	DB	107.6	103.7	98.2	88.6	77.0	67.4	68.1	74.5	85.5	93.1	99.3	103.8
		MCWB	66.9	67.5	64.4	61.3	57.6	54.2	53.0	53.6	57.5	60.1	63.1	64.7
	5%	DB	101.7	99.2	93.1	84.3	73.1	64.7	64.7	70.2	80.4	88.1	94.1	98.3
		MCWB	66.3	66.8	64.3	60.6	56.6	53.4	52.0	52.8	56.2	58.6	62.0	64.0
	10%	DB	96.1	94.0	87.9	80.0	69.7	62.3	62.0	66.3	75.1	82.5	88.7	92.6
		MCWB	65.7	66.4	63.8	59.5	55.9	52.7	51.3	51.7	55.1	57.1	61.5	62.9
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	74.8	76.5	72.4	69.2	62.9	60.4	58.0	58.5	63.5	66.0	70.5	72.5
		MCDB	86.7	85.8	84.9	75.4	72.9	65.3	64.6	70.8	75.0	84.1	86.6	86.1
	2%	WB	72.5	73.9	70.6	66.2	60.7	57.3	55.5	56.4	60.6	63.5	67.9	69.8
		MCDB	86.7	87.7	83.9	74.6	69.5	62.5	63.2	67.8	75.6	80.3	84.2	85.5
	5%	WB	70.9	71.9	68.5	63.8	59.1	55.5	53.8	54.7	58.6	61.7	66.2	67.9
		MCDB	87.5	87.4	82.6	75.9	68.2	61.7	61.3	64.9	74.3	78.3	83.2	86.4
	10%	WB	69.2	70.1	66.6	62.0	57.6	54.0	52.4	53.4	56.7	60.0	64.4	66.2
		MCDB	87.4	85.9	81.4	75.4	66.6	60.2	59.8	63.5	71.1	76.3	81.4	83.3
(35) Mean Daily Temperature Range	5% DB	MDBR	23.3	22.5	21.2	21.6	20.3	18.8	20.8	22.6	24.3	24.3	23.5	23.5
		MCDBR	33.1	30.9	29.6	30.0	25.9	22.8	25.8	29.8	34.3	35.5	34.0	34.1
		MCWBR	9.6	9.4	10.2	12.1	12.3	12.4	13.8	14.2	13.9	13.2	10.5	10.4
	5% WB	MCDBR	24.1	21.3	21.5	20.5	20.5	17.6	21.1	23.7	26.5	26.3	24.9	23.9
		MCWBR	9.1	8.4	8.9	10.1	10.7	10.5	12.5	12.6	12.1	10.7	9.1	9.4
(40) Clear-Sky Solar Irradiance	taub		0.348	0.347	0.328	0.320	0.307	0.296	0.297	0.307	0.338	0.342	0.350	0.341
	taud		2.502	2.530	2.563	2.565	2.578	2.593	2.582	2.536	2.446	2.446	2.465	2.507
	Ebn at Noon		314	308	303	289	277	272	278	289	295	306	312	318
	Edh at Noon		36	34	31	28	24	22	23	28	34	36	37	36
(44) All-Sky Solar Radiation	RadAvg		2539	2291	1917	1441	1042	868	947	1241	1693	2091	2344	2530
	RadStd		129	116	114	71	47	55	45	75	115	113	114	110

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A
Regional (9 neighbors)	+0.67	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+218	+155

Nomenclature: See separate page