

PORT AUGUSTA, Australia

WMO: 956660

Lat: 32.5092S

Lon: 137.7144E

Elev: 14

StdP: 101.15

Time Zone: 9.50 (AUA)

Period: 97-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	1.9	3.5	-10.0	1.6	27.3	-6.9	2.1	25.6	12.3	17.5	11.2	17.2	2.0	230	0.568

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	12.9	41.5	19.2	39.1	18.7	36.8	18.2	22.8	30.6	21.9	30.4	21.0	29.9	6.3	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
20.7	15.4	25.4	19.4	14.1	25.3	18.2	13.1	24.7	67.5	30.4	64.0	30.3	60.8	29.7	27.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.1	10.9	10.0	-0.7	44.9	1.3	1.6	-1.7	46.0	-2.4	46.9	-3.2	47.8	-4.1	49.0		
(5)			-1.5	24.4	1.3	1.3	-2.5	25.4	-3.2	26.1	-3.9	26.9	-4.9	27.8	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	18.9	26.6	26.0	23.3	19.5	15.1	11.9	11.2	12.6	16.0	19.1	22.2	24.2	(6)	(7)
	DBStd	6.36	4.33	4.10	3.96	3.18	2.65	2.18	2.10	2.59	3.39	3.89	4.31	4.36	(7)	(8)
	HDD10.0	22	0	0	0	0	1	7	11	4	0	0	0	0	(8)	(9)
	HDD18.3	858	0	1	4	22	105	192	221	178	88	36	9	2	(9)	(10)
	CDD10.0	3287	515	447	412	286	159	64	48	86	181	283	367	439	(10)	(11)
	CDD18.3	1081	257	214	157	58	6	0	0	2	18	61	126	183	(11)	(12)
	CDH23.3	12822	3153	2508	1614	562	63	1	1	34	305	834	1536	2211	(12)	(13)
	CDH26.7	6813	1834	1384	801	212	10	0	0	6	109	395	822	1240	(13)	(14)
(14) Wind	WSAvg	5.1	6.6	6.1	5.4	4.5	3.8	3.6	3.9	4.4	5.0	5.7	5.9	6.2	(14)	(15)
(15) Precipitation	PrecAvg	252	17	18	12	15	26	25	23	22	26	25	21	16	(15)	(16)
	PrecMax	530	69	110	103	50	123	72	64	63	82	132	100	64	(16)	(17)
	PrecMin	137	0	0	0	0	0	0	0	0	1	0	0	0	(17)	(18)
	PrecStd	94	16	25	18	17	25	20	17	15	21	28	21	17	(18)	(19)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	44.5	43.2	40.0	34.8	28.2	22.0	22.2	26.8	33.4	37.5	41.1	43.3	(19)	(20)
		MCWB	19.6	20.4	18.2	17.2	14.9	13.0	12.2	13.3	15.2	16.3	17.7	18.9	(20)	(21)
	2%	DB	42.0	39.8	36.8	31.4	25.0	19.6	20.1	23.6	29.7	34.0	37.4	39.9	(21)	(22)
		MCWB	19.4	19.7	18.0	16.3	14.2	12.4	11.7	12.0	14.2	15.6	17.3	18.2	(22)	(23)
	5%	DB	38.7	37.3	34.0	29.1	22.8	18.2	18.2	21.2	26.9	31.2	34.5	36.9	(23)	(24)
		MCWB	19.0	19.3	18.0	15.9	13.7	11.9	11.1	11.5	13.4	14.8	16.6	17.8	(24)	(25)
	10%	DB	35.6	34.4	31.0	26.7	20.9	16.9	16.7	19.0	24.0	28.0	31.5	33.6	(25)	(26)
		MCWB	18.7	19.1	17.6	15.3	13.3	11.5	10.7	10.9	12.9	14.0	16.4	17.2	(26)	(27)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	23.8	24.7	22.4	20.7	17.2	15.8	14.5	14.7	17.5	18.9	21.4	22.5	(27)	(28)
		MCDB	30.4	29.9	29.4	24.1	22.7	18.5	18.1	21.6	23.9	29.0	30.3	30.1	(28)	(29)
	2%	WB	22.5	23.3	21.4	19.0	16.0	14.1	13.1	13.5	15.9	17.5	19.9	21.0	(29)	(30)
		MCDB	30.4	31.0	28.8	23.6	20.8	17.0	17.3	19.9	24.2	26.8	29.0	29.7	(30)	(31)
	5%	WB	21.6	22.1	20.3	17.7	15.0	13.1	12.1	12.6	14.8	16.5	19.0	20.0	(31)	(32)
		MCDB	30.8	30.8	28.1	24.4	20.1	16.5	16.3	18.3	23.5	25.7	28.4	30.2	(32)	(33)
	10%	WB	20.7	21.1	19.2	16.6	14.2	12.2	11.4	11.9	13.7	15.6	18.0	19.0	(33)	(34)
		MCDB	30.8	29.9	27.4	24.1	19.2	15.6	15.4	17.5	21.7	24.6	27.5	28.5	(34)	(35)
(35) Mean Daily Temperature Range	5% DB	MDBR	12.9	12.5	11.8	12.0	11.3	10.4	11.5	12.6	13.5	13.5	13.1	13.1	(35)	(36)
		MCDBR	18.4	17.2	16.5	16.7	14.4	12.6	14.3	16.5	19.1	19.7	18.9	19.0	(36)	(37)
	5% WB	MCWBR	5.3	5.2	5.6	6.7	6.8	6.9	7.7	7.9	7.7	7.3	5.8	5.8	(37)	(38)
		MCWBR	13.4	11.8	12.0	11.4	11.4	9.8	11.7	13.1	14.7	14.6	13.8	13.3	(38)	(39)
(40) Clear-Sky Solar Irradiance	taub		0.348	0.347	0.328	0.320	0.307	0.296	0.297	0.307	0.338	0.342	0.350	0.341	(40)	(41)
		taud	2.502	2.530	2.563	2.565	2.578	2.593	2.582	2.536	2.446	2.446	2.465	2.507	(41)	(42)
	Ebn at Noon		990	971	956	910	872	859	875	910	930	965	982	1001	(42)	(43)
		Edh at Noon	114	107	97	87	76	70	74	87	107	115	118	114	(43)	(44)
(44) All-Sky Solar Radiation	RadAvg		8.00	7.22	6.04	4.54	3.29	2.74	2.98	3.91	5.34	6.59	7.39	7.98	(44)	(45)
	RadStd		0.41	0.36	0.36	0.22	0.15	0.17	0.14	0.23	0.36	0.36	0.36	0.35	(45)	(46)

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (9 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		+0.37	N/A	N/A	N/A	N/A	N/A	N/A	+121	+86	

Nomenclature: See separate page