

CLARE, Australia

WMO: 956670

Lat: 33.8225S

Lon: 138.5933E

Elev: 1299

StdP: 14.02

Time Zone: 9.50 (AUA)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	32.5	34.8	21.3	16.7	75.1	25.0	20.0	73.8	21.1	52.0	19.6	50.7	0.3	100	0.480

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	25.5	98.6	63.6	94.7	62.6	90.7	61.7	68.9	81.5	66.9	82.2	65.1	82.2	10.4	310

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.7	99.5	72.8	62.7	89.5	70.3	60.0	81.1	68.4	33.9	80.4	32.2	82.7	30.7	81.9	76.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 19.4	17.0	15.2	DB	28.5	104.4	1.9	2.9	27.1	106.5	26.0	108.2	24.9	109.8	23.5	111.9	(4)
(5)			WB	28.0	72.0	1.9	2.6	26.7	73.9	25.6	75.4	24.5	76.9	23.2	78.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	58.8	72.1	71.7	66.1	59.9	52.8	48.0	46.9	48.2	52.5	57.4	63.5	67.4	(6)	
	DBStd	11.05	8.41	8.31	7.69	6.29	4.99	3.88	3.75	4.38	5.62	7.13	8.12	8.29	(7)	
	HDD50	349	0	0	0	2	23	83	111	89	31	9	1	0	(8)	
	HDD65	3111	25	26	80	180	380	510	562	521	376	256	127	68	(9)	
	CDD50	3559	685	607	499	297	110	23	14	33	107	240	405	539	(10)	
	CDD65	847	245	213	114	26	1	0	0	0	2	22	81	143	(11)	
	CDH74	10920	3167	2571	1305	309	11	0	0	1	35	386	1130	2005	(12)	
	CDH80	5150	1667	1270	544	79	0	0	0	0	4	120	479	987	(13)	
(14) Wind	WSAvg	6.7	7.6	6.9	6.3	5.6	5.3	6.0	6.5	6.6	7.0	7.3	7.6	7.5	(14)	
(15) Precipitation	PrecAvg	25.8	1.1	0.9	1.1	1.7	3.0	2.9	3.6	3.3	3.2	2.3	1.5	1.1	(15)	
	PrecMax	37.4	3.7	6.5	4.1	6.3	8.7	6.7	7.2	5.5	7.8	6.5	4.1	7.0	(16)	
	PrecMin	12.4	0.0	0.0	0.0	0.0	0.5	0.1	0.6	0.5	0.8	0.2	0.0	0.0	(17)	
	PrecStd	5.5	1.1	1.2	1.0	1.5	1.9	1.7	1.7	1.4	1.6	1.7	1.0	1.3	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	103.9	101.8	96.5	87.8	75.1	64.3	63.4	69.5	78.3	89.4	96.5	102.0	(19)	
		MCWB	64.9	66.2	61.6	60.2	55.8	54.3	51.7	54.0	56.6	58.0	61.1	63.9	(20)	
	2%	DB	99.3	96.9	90.4	81.5	69.9	60.4	59.2	64.5	73.2	83.0	90.4	95.6	(21)	
		MCWB	64.0	64.2	61.4	57.8	55.0	51.5	50.3	51.8	55.5	57.1	60.4	61.5	(22)	
	5%	DB	94.5	92.5	86.4	77.1	65.9	57.7	56.4	60.5	68.7	78.0	85.6	90.2	(23)	
		MCWB	63.2	63.1	61.1	56.7	53.6	50.8	49.5	50.5	54.5	55.9	59.4	60.6	(24)	
	10%	DB	89.2	88.1	81.4	72.9	62.4	55.4	54.1	57.1	64.5	72.9	80.7	85.2	(25)	
		MCWB	61.7	62.4	60.0	55.6	52.7	49.8	48.6	49.2	53.1	55.0	57.8	59.6	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	71.0	73.0	68.2	64.0	59.7	57.2	54.7	56.5	61.4	62.7	66.4	68.7	(27)	
		MCDB	80.1	85.1	79.7	70.3	66.3	61.0	58.7	64.3	70.7	77.5	79.6	82.2	(28)	
	2%	WB	68.5	69.7	65.8	61.2	57.3	53.8	52.4	53.7	58.3	60.1	63.8	65.8	(29)	
		MCDB	82.1	83.0	79.3	71.1	64.8	57.7	56.1	60.9	68.4	73.6	79.0	80.9	(30)	
	5%	WB	66.5	67.3	63.7	59.4	55.5	52.1	50.7	51.9	55.9	58.3	61.9	63.6	(31)	
		MCDB	85.3	81.3	78.2	71.0	62.2	55.5	54.5	58.0	65.4	71.8	78.8	81.9	(32)	
	10%	WB	64.6	64.9	61.8	57.7	54.0	50.7	49.4	50.3	53.8	56.4	60.1	61.6	(33)	
		MCDB	84.3	82.7	77.1	69.2	60.0	53.9	52.9	55.6	62.3	69.6	76.4	79.4	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	25.5	24.1	22.5	21.0	17.2	14.1	14.0	16.1	19.0	22.6	24.0	25.1	(35)	
		MCDBR	31.3	28.8	27.7	27.7	22.8	18.2	18.4	22.6	27.2	31.6	30.8	31.8	(36)	
	5% WB	MCWBR	10.0	9.7	9.6	11.1	11.0	11.0	11.5	12.9	13.4	12.3	10.6	10.7	(37)	
		MCWBR	23.8	21.8	22.1	20.7	17.2	13.9	14.9	18.7	23.3	25.1	25.1	25.1	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.327	0.326	0.308	0.303	0.290	0.279	0.280	0.290	0.316	0.325	0.331	0.322	(40)	
		taud	2.514	2.542	2.582	2.572	2.595	2.613	2.602	2.548	2.466	2.451	2.469	2.520	(41)	
	Ebn at Noon		320	314	309	293	281	276	282	293	301	311	317	323	(42)	
		Edh at Noon	36	33	30	27	23	21	23	27	33	36	37	36	(43)	
(44) All-Sky Solar Radiation	RadAvg		2514	2246	1848	1354	945	773	838	1131	1546	1984	2291	2478	(44)	
	RadStd		134	124	100	71	41	53	39	79	122	128	118	101	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.81	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (26 neighbors)		+0.79	N/A	N/A	N/A	N/A	N/A	N/A	-162	+277	+130

Nomenclature: See separate page