

CLARE, Australia

WMO: 956670

Lat: 33.8225S

Lon: 138.5933E

Elev: 396

StdP: 96.66

Time Zone: 9.50 (AUA)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	0.3	1.5	-6.0	2.4	23.9	-3.9	2.9	23.2	9.4	11.1	8.8	10.4	0.1	100	0.480

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	14.2	37.0	17.5	34.8	17.0	32.6	16.5	20.5	27.5	19.4	27.9	18.4	27.9	4.6	310

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.7	14.2	22.7	17.1	12.8	21.3	15.6	11.6	20.2	60.9	26.9	57.0	28.2	53.5	27.7	24.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
8.7	7.6	6.8	-1.9	40.2	1.1	1.6	-2.7	41.4	-3.4	42.3	-4.0	43.2	-4.7	44.4		
			-2.2	22.2	1.0	1.5	-3.0	23.3	-3.6	24.1	-4.1	24.9	-4.9	26.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	14.9	22.3	22.0	18.9	15.5	11.6	8.9	8.3	9.0	11.4	14.1	17.5	19.7
	DBStd	6.14	4.67	4.62	4.27	3.49	2.77	2.15	2.09	2.43	3.12	3.96	4.51	4.61
	HDD10.0	194	0	0	0	1	13	46	62	49	17	5	1	0
	HDD18.3	1728	14	14	44	100	211	283	312	289	209	142	71	38
	CDD10.0	1977	381	337	277	165	61	13	8	18	59	133	225	299
	CDD18.3	471	136	118	63	14	1	0	0	0	1	12	45	79
	CDH23.3	6067	1759	1428	725	172	6	0	0	1	19	214	628	1114
	CDH26.7	2861	926	706	302	44	0	0	0	0	2	67	266	548
Wind	WSAvg	3.0	3.4	3.1	2.8	2.5	2.4	2.7	2.9	2.9	3.1	3.3	3.4	3.3
Precipitation	PrecAvg	656	29	23	27	43	75	74	91	83	81	59	39	28
	PrecMax	951	94	164	105	159	220	169	184	140	197	164	104	178
	PrecMin	316	0	0	0	0	12	2	16	13	21	6	1	1
	PrecStd	140	27	31	26	38	47	43	42	36	40	43	25	32
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	40.0	38.8	35.8	31.0	23.9	18.0	17.5	20.8	25.7	31.9	35.8	38.9
		MCWB	18.3	19.0	16.5	15.7	13.2	12.4	11.0	12.2	13.7	14.5	16.2	17.7
	2%	DB	37.4	36.0	32.5	27.5	21.1	15.8	15.1	18.0	22.9	28.3	32.5	35.4
		MCWB	17.8	17.9	16.4	14.3	12.8	10.8	10.2	11.0	13.1	14.0	15.8	16.4
	5%	DB	34.7	33.6	30.2	25.1	18.8	14.3	13.6	15.9	20.4	25.6	29.8	32.3
		MCWB	17.3	17.3	16.1	13.7	12.0	10.4	9.7	10.3	12.5	13.3	15.2	15.9
	10%	DB	31.8	31.2	27.5	22.7	16.9	13.0	12.3	14.0	18.1	22.7	27.0	29.6
		MCWB	16.5	16.9	15.5	13.1	11.5	9.9	9.2	9.5	11.7	12.8	14.4	15.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.7	22.8	20.1	17.8	15.4	14.0	12.6	13.6	16.3	17.0	19.1	20.4
		MCDB	26.7	29.5	26.5	21.3	19.1	16.1	14.8	18.0	21.5	25.3	26.4	27.9
	2%	WB	20.3	20.9	18.8	16.2	14.1	12.1	11.3	12.1	14.6	15.6	17.7	18.8
		MCDB	27.9	28.3	26.3	21.7	18.2	14.3	13.4	16.0	20.2	23.1	26.1	27.2
	5%	WB	19.2	19.6	17.6	15.2	13.1	11.2	10.4	11.1	13.3	14.6	16.6	17.5
		MCDB	29.6	27.4	25.7	21.7	16.8	13.1	12.5	14.4	18.6	22.1	26.0	27.7
	10%	WB	18.1	18.3	16.5	14.3	12.2	10.4	9.7	10.2	12.1	13.5	15.6	16.5
		MCDB	29.1	28.2	25.0	20.7	15.5	12.2	11.6	13.1	16.8	20.9	24.7	26.3
Mean Daily Temperature Range	5% DB	MDBR	14.2	13.4	12.5	11.7	9.5	7.8	7.8	9.0	10.6	12.6	13.3	13.9
		MCDBR	17.4	16.0	15.4	15.4	12.7	10.1	10.2	12.6	15.1	17.6	17.1	17.7
		MCWBR	5.5	5.4	5.3	6.2	6.1	6.1	6.4	7.2	7.4	6.8	5.9	5.9
	5% WB	MCDBR	13.2	12.1	12.3	11.5	9.6	7.7	8.3	10.4	12.9	13.9	13.9	14.0
		MCWBR	5.6	5.3	5.2	5.7	5.4	5.2	5.7	6.5	7.3	6.4	5.8	5.9
Clear-Sky Solar Irradiance	taub	0.327	0.326	0.308	0.303	0.290	0.279	0.280	0.290	0.316	0.325	0.331	0.322	
	taud	2.514	2.542	2.582	2.572	2.595	2.613	2.602	2.548	2.466	2.451	2.469	2.520	
	Ebn at Noon	1010	991	975	925	885	871	888	924	949	980	1000	1019	
	Edh at Noon	112	105	94	84	73	67	71	85	104	114	117	112	
All-Sky Solar Radiation	RadAvg	7.93	7.08	5.83	4.27	2.98	2.44	2.64	3.56	4.88	6.26	7.22	7.81	
	RadStd	0.42	0.39	0.31	0.22	0.13	0.17	0.12	0.25	0.39	0.40	0.37	0.32	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (26 neighbors)	+0.44	N/A	N/A	N/A	N/A	N/A	N/A	-90	+154	+72

Nomenclature: See separate page