

SNOWTOWN, Australia

WMO: 956700

Lat: 33.7675S

Lon: 138.2183E

Elev: 109

StdP: 100.02

Time Zone: 9.50 (AUA)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	0.3	1.5	-6.7	2.2	26.4	-4.5	2.6	25.9	14.4	14.9	13.2	14.8	2.4	0	0.592

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	16.5	39.8	18.6	37.4	17.9	35.0	17.3	21.2	29.5	20.3	29.2	19.4	28.9	6.8	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.4	14.3	23.0	17.9	13.0	22.3	16.7	12.0	21.6	62.2	29.8	58.8	29.1	55.5	28.9	25.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 13.3	11.3	9.9	-1.4	43.3	1.0	1.5	-2.1	44.4	-2.7	45.3	-3.2	46.2	-3.9	47.2		
(5)			-1.9	23.0	1.0	1.2	-2.6	23.8	-3.2	24.5	-3.8	25.2	-4.5	26.0	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	16.3	23.0	22.4	20.3	17.3	13.6	10.7	10.0	10.2	12.5	15.7	18.8	20.9	(6)	(7)
	DBStd	5.83	4.34	4.17	4.01	3.43	2.67	2.25	2.10	2.45	2.96	3.91	4.35	4.44	(7)	(8)
	HDD10.0	78	0	0	0	0	2	18	27	26	6	1	0	0	(8)	(9)
	HDD18.3	1329	4	6	22	61	151	229	259	252	177	103	47	19	(9)	(10)
	CDD10.0	2361	404	348	319	219	112	39	26	33	81	178	264	339	(10)	(11)
	CDD18.3	569	151	121	83	29	2	0	0	0	2	22	61	99	(11)	(12)
	CDH23.3	8407	2098	1579	1085	398	31	1	0	4	82	505	1041	1583	(12)	(13)
	CDH26.7	4456	1217	878	533	140	3	0	0	1	18	217	548	902	(13)	(14)
(14) Wind	WSAvg	4.9	5.4	5.2	4.7	4.4	4.6	4.7	5.0	4.7	4.7	5.0	5.1	5.3	(14)	(15)
(15) Precipitation	PrecAvg	413	21	19	17	29	43	50	58	48	49	39	26	19	(15)	(16)
	PrecMax	646	114	116	83	101	106	127	110	94	121	116	74	62	(16)	(17)
	PrecMin	208	0	0	0	1	1	2	4	5	13	2	0	0	(17)	(18)
	PrecStd	102	26	26	19	26	25	32	28	24	28	31	18	16	(18)	(19)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	42.9	41.5	38.4	34.2	26.6	20.2	19.6	23.3	29.0	35.6	39.0	41.6	(19)	(20)
		MCWB	19.3	19.7	18.0	17.1	14.2	12.9	11.8	13.1	14.5	15.8	17.6	18.7	(20)	(21)
	2%	DB	40.3	38.0	35.0	30.4	23.6	18.0	17.2	20.2	25.5	32.0	35.6	38.8	(21)	(22)
		MCWB	18.8	18.7	17.5	15.5	13.5	11.7	11.4	12.0	13.4	14.6	16.6	17.6	(22)	(23)
	5%	DB	37.1	35.5	32.4	27.8	21.2	16.5	15.7	17.8	23.0	28.9	33.1	35.3	(23)	(24)
		MCWB	18.1	18.2	17.3	14.8	12.9	11.6	11.0	11.8	13.0	14.0	16.4	16.8	(24)	(25)
	10%	DB	33.5	32.5	29.4	25.3	19.2	15.2	14.5	15.8	20.2	25.8	29.8	32.0	(25)	(26)
		MCWB	17.6	17.8	16.5	14.2	12.8	11.3	10.8	11.0	12.3	13.4	15.3	16.5	(26)	(27)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	22.3	23.0	21.4	18.9	16.2	14.6	14.0	15.0	16.5	17.5	20.4	21.6	(27)	(28)
		MCDB	28.7	33.4	27.3	22.0	21.9	17.2	16.4	19.1	22.2	27.7	28.8	31.2	(28)	(29)
	2%	WB	21.0	21.3	20.3	17.5	15.1	13.3	12.7	13.4	14.9	16.3	18.7	19.8	(29)	(30)
		MCDB	30.3	29.7	27.7	24.2	19.7	15.8	15.2	17.8	21.9	25.6	28.5	29.1	(30)	(31)
	5%	WB	20.0	20.2	19.0	16.4	14.2	12.5	11.8	12.4	13.8	15.4	17.7	18.6	(31)	(32)
		MCDB	30.5	28.7	27.1	23.8	18.6	15.1	14.6	16.4	20.2	24.2	27.8	29.8	(32)	(33)
	10%	WB	19.1	19.1	18.0	15.6	13.4	11.8	11.1	11.5	12.8	14.5	16.7	17.6	(33)	(34)
		MCDB	29.7	28.6	26.9	22.8	17.6	14.3	13.8	15.1	18.9	23.0	26.2	27.9	(34)	(35)
(35) Mean Daily Temperature Range	5% DB	MDBR	16.5	15.8	14.9	13.8	11.0	9.4	9.5	11.5	14.2	16.6	16.6	16.5	(35)	(36)
		MCDBR	21.7	20.5	18.8	17.5	14.3	11.3	11.2	15.1	19.5	22.0	21.5	22.0	(36)	(37)
		MCWBR	6.6	6.5	6.4	7.0	6.7	6.6	6.9	8.7	9.1	8.7	7.5	7.1	(37)	(38)
	5% WB	MCDBR	15.7	15.3	15.0	13.1	10.6	8.4	9.3	12.6	15.6	17.4	17.1	16.3	(38)	(39)
		MCWBR	6.0	5.5	5.3	6.1	5.8	5.5	6.4	8.1	8.5	7.7	6.7	6.1	(39)	(40)
(40) Clear-Sky Solar Irradiance	taub		0.340	0.339	0.320	0.315	0.301	0.291	0.292	0.301	0.328	0.337	0.343	0.333	(40)	(41)
	taud		2.494	2.520	2.561	2.553	2.582	2.594	2.582	2.534	2.453	2.436	2.454	2.505	(41)	(42)
	Ebn at Noon		997	978	962	910	872	857	874	912	937	968	988	1007	(42)	(43)
	Edh at Noon		115	108	96	86	74	69	73	86	105	116	119	114	(43)	(44)
(44) All-Sky Solar Radiation	RadAvg		7.94	7.08	5.82	4.29	3.01	2.47	2.68	3.62	4.94	6.30	7.27	7.83	(44)	(45)
	RadStd		0.41	0.39	0.30	0.22	0.12	0.16	0.12	0.23	0.37	0.38	0.36	0.32	(45)	(46)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (22 neighbors)	+0.43	N/A	N/A	N/A	N/A	N/A	N/A	-93	+160	+73

Nomenclature: See separate page